

**Bangladesh Power Generation Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month April, 2023		Day: Thursday		Date: 27.04.23							
Probable Maximum Demand :		13000 MW		Probable Maximum Generation : 15840 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.25 ft		Today = 75.22 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.04.23 (Yesterday)		27.04.23 (Today)		Rule Curve = 82.80 ft.		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	150	150	150		Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	74	76	16	76	32	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	337	333	300	330		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	395	399	350	400		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	39	99	90	100	105	1 Unit under maint
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	150	142	120	120	193	ST Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	285	281	280	300		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	15		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	8	48	92		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	13	10	18		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	31	41	41	41		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	0	32	32		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	42	48	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	105	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	48	130	149		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	35	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	70	0	70		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300		
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	80		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	37	37		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	35	54	70		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	72	108	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	13	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	35	17	35		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	40	90	90		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	9	16	50		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	100	0	90	90		
Dhaka Zone Total			6004	5847	2200	2704	3552	4107	137	1038	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	0	25	205	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	18	26	35		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	216	224	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	45	210	120	300		
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	50	74	50	100		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	84	66	84		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	45	60		
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13		
*	Malancha, Clq EPZ (United)	Gas	5x8.73+3x9.34			12	38	10	35		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	50		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	51		
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	42	90	63	90		
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	10	10	50	70		
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	28	34	34	34		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			163	163	162	162		on test
Chattogram Zone Total			2442	2382	771	1162	1173	1638	205	330	
58	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	35	40	40	40		
59	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+17x5	221	221	182	207	210	210		
60	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	300	310	270	310		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	310	300	300	305		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0	400	Under maint.
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55	Gas Shortage
64	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'116	195	195	153	197	100	195		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	80	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	46	31	46		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	34	17	34		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	18	18		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	8	8	8		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	21	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	40	52	25	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	0	0	0	0		
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	88	106	17	106		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	36	114	9	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35		
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	73	94	94	94		
**	limpoort (Tripura)	India		160	160	122	140	143	165		
Cumilla Zone Total			3159	3151	1496	1806	1490	1986	55	563	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	200	202	200	202		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	16	19		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	88	108	75	108		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	134	164	160	170		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0		
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	23	12	12	12		
Mymensingh Zone Total			622	614	506	505	515	511	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.04.23 (Yesterday)		27.04.23 (Today)		26.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)			
87	Fenchugon CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	31	32	33	33			GT-1 & ST-1 Under maint.	
88	Fenchugon CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	28	28	28			GT-4 Under maint.	
89	Fenchugon 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	61	61				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330 Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	80	85	84				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	203	202	190	202				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	280	310				
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	369	408	400	400				
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	388	396	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			100 Under project work	
103	Fenchugon 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	39	45	44	45				
Sylhet Zone Total					2472	2427	1582	1667	1624	1666	9	584	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	370	410	300	410				
106	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	22	35				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	55	74				
108	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x8.445	105	105	0	17	17	17				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x8.415	105	105	0	0	0	100				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	81	0	100	0				
113	Khulna 115 MW PP (KCL-2)	HFO (NENP)	7x17	115	115	0	44	85	98				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
**	Khulna 330 MW CAPP	Gas/HSD				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	911	806	930	930				
Khulna Zone Total					3005	3001	1362	1277	1509	1704	0	0	
116	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	64	16	64				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	31	25	31				
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	60	60	60	60				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	820	1244	750	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	21	17	150				
121	Bansal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD	2x75+1x70	220	220	0	0	0	0			220 Under maint.	
Barishal Zone Total					2265	2265	903	1420	868	1549	0	220	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	65	65	65	65				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	26	26				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	34				
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	80	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	42				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	35	35				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	176	190	190	190				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	175	197	160	200				
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	412	376	380	380				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	20	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
138	Baquara 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	113	95	113				
139	Baquara 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	88	35	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				508	0	500	750				
Raishahi Zone Total					2129	2129	1363	1057	1660	2108	320	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	75	75	75	10		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	260	250	260			Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	107	42	107				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thekurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	5	115	35	115				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0				
	Teesla Solar Limited	Solar (IPP)				132	0	130	0				
Rangpur Zone Total					830	750	472	557	570	557	10	85	
Sub-total: Plants in operation					22928	22566	10655.0	12155	12961	15826	736	2820	

(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kalpatoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	52	0	0	0	0	0				
151	Bosilia 108MW PP(CCL)	HFO (IPP)	12x8.775+1x3.5	119	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Ambari 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	14				
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	14			
Gross Total					23332	22566	10655	12155	12961	15840	736	2820	

(C) Actual data of 26.04.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	: 12155 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 11541 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 12194 MW, at = 22:00 hrs	Dhaka	3460	3460	0	Mymensingh	1112	1112	0		
04.	Minimum Generation (Generation end)	: 9128 MW, at = 6:00 hrs	Chattogram	1176	1176	0	Sylhet	536	536	0		
05.	Day-peak Generation (Generation end)	: 10655 MW, at = 12:00 hrs	Khulna	1455	1455	0	Barishal	410	410	0		
06.	Evening-peak Generation (Generation end)	: 12155 MW, at = 21:00 hrs	Rajshahi	1196	1196	0	Rangpur	852	852	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs	Cumilla	1345	1345	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9512 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :		13. Fuel cost : (a) Gas = 181962195 Taka (c) Coal = 277127668 Taka Total = 893458898 Taka									
	a) Gas/LF limitation	: 521 MW										
	d) Coal supply Limitation	: 10 MW										
	b) Low water level in Kaptai lake	: 205 MW										
	c) Plants under shut down/ maintenance	: 2820 MW										
10.	Total Energy (Generation + India Import)	: 261.12 MWh	14. Maximum Temperature in Dhaka was : 37.5° C									
	By Gas = 155.614 MKWH	By Oil = 36.845 MKWH	15. Export through East-West interconnections : At evening peak-hour : 10655 MW, at 21:00 hrs									
	By Coal = 41.247 MKWH	By Hydro = 0.320 MKWH	Maximum : -100 MW, at 3:00 hrs									
	By Solar= 2.725 MKWH		Energy : 0.4455 MKWh									
11.	Total Gas Supplied	: 1198.95 MMCFD										

(D) Forecast of 27.04.23 (Today) Thursday :					
01.	Maximum Demand	: 13000 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)
02.	Maximum Generation	: 15840 MW (Generation end)	05.	Total Generation	: 278.38 MKWh
03.	Reserve / Shortage	: 2840 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	37° C

* Coactive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00 (Md. Helalur Rahman) Deputy Secretary, Generation