

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	0	270281	
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4284000	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
6	Ghorasal 108MW PP (Regent)	IPP	34.3 35	108	12	1095636	Bad weather
7	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1273+1139	412	379	903570	Bad weather
9	Haripur 360MW CCGP(HPL)	IPP	1235+1125	360	303	7416000	Bad weather
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	330	9609250	Bad weather
11	Meghnaghat 100 MW(IEI)	NENP	12*9	100	0	502080	Reserve
12	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	285	6857513	FGMO
13	Madaniganj 102 PP(Summit)	NENP	6*17	102	0	0	Reserve
14	Madaniganj-55 MW PPS(Summit)	IPP	3*17.08+11*1.3	55	0	105728	Reserve
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	0	201960	
17	210 MW Siddhirganj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirganj 2120 MW GTTP	EGCB	2105	210	0	1038000	Bad weather
19	Siddhirganj 100 PP(Dutch) Bangla	NENP	12*8	100	0	927360	
20	Siddhirganj 335 MW CCGP	EGCB	1217+118	335	0	2660056	Bad weather
21	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	0	272880	Reserve
22	Katipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	0	1605600	Reserve
24	Kodda 150 MW PP	BPDB-RPCL	9*17.08	149	0	491040	Reserve
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	0	276038	Reserve
26	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	0	224653	Reserve
27	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	26	890580	Engine problem
29	Machha 33 MW PP(Summit)	SIPP, REB	4*8.73	33	0	469700	
30	Ruaganj 30 MW PP(Summit)	SIPP, REB	4*8.73	33	16	270300	Engine problem
31	Gazipur 52 MW PP	RPCL	6*8.9	52	0	451200	Reserve
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	0	444109	Reserve
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
35	Bramhanaga 100 MW PP (Aggreko)	IPP	114*9.959	100	0	0	Reserve
36	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	0	173950	Reserve
38	Gazipur 100 MW PP	RPCL	6*17.5	105	0	1284979	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	0	904320	Reserve
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	0	496800	Reserve
41	Spectro Solar Plant Ltd.	IPP	35	35	0	189429	
42	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4*3	55	17	407160	Low Demand
Dhaka area Total				5847	1548	53913332	
43	Chattoagram TPP-1	PDB	1210	180	120	2800000	Gas shortage
44	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Raozan 25 MW PP	RPCL	3*8.9	25	0	89778	Reserve
46	Tafal 20MW PP (Sadarlech)	IPP	20	20	0	143100	
47	Palenga 50MW PP (Baraka)	IPP	8*6.98	50	38	223680	Engine problem
48	Kapila Hydro Unit-1,2,3,4, 5	IPP	2*40+3*50	230	25	288660	Low Water level
49	Sikalbaha 225MW	PDB	1150+175	225	220	5187923	
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	17	945827	Low Demand
52	Hathazari 100 MW peaking PP	PDB	11*9.9	102	0	101520	Reserve
53	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	51	867452	Low Demand
54	Jullaha 100 MW Unit-1 (Accorn)	NENP	8*13.45	100	0	692400	Reserve
55	Jullaha 100 MW PP Unit-3 (Accorn)	IPP	8*13.5	100	74	1140480	Low Demand
56	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	206112	Bad weather
57	Manaraha, Ch. EPZ (United)	IPP	5*8.73+9.34	0	0	763200	
58	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	53780	Reserve
59	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	33242	
60	Anwara 300 MW PP (United)	IPP	17*17+24	300	170	2719855	Low Demand
61	Jodiak Power	IPP	3*18.55+1*3.6	54	0	332057	Reserve
62	Kanaphuli Power Ltd.	IPP	18.45*6+8.5	110	17	936726	Low Demand
63	Jullaha unit (Accorn)	IPP	8*13.5	100	12	756480	Reserve
64	Anlima Energy Ltd.	IPP	6*21.2	116	34	840545	Fuel shortage
65	Minshaha 150 MW	BPDB-RPCL	18.5*9	0	163	3910836	On test.
Chattogram area Total				2382	967	23093733	
66	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	Contract Expired
68	Ashuganj TPP Unit-5	APSCL	1150	0	0	0	Contract Expired
69	Ashuganj 225 MW CCGP	APSCL	1142+175	221	189	4855000	FGMO
70	Ashuganj 450 MW CCGP(North)	APSCL	1360	360	285	7577600	FGMO
71	Ashuganj 450 MW CCGP(South)	APSCL	1360	360	275	7168000	FGMO
72	Ashuganj 420 MW CCGP(East)	APSCL	284*1+116*1	400	0	0	Under maint.
73	Ashuganj 50 MW PP	APSCL	14*3.968	45	40	931968	Engine problem
74	Ashuganj 100 MW PP (Precision)	QRPP	15*14	55	0	0	Contract Expired
75	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	2325090	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	10	693286	Low Demand
77	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	5	217454	Low Demand
78	Titas 50 MW Peaking PP	PDB	6*8.92	50	0	843524	Reserve
79	Chandpur 150 MW CCGP	PDB	1210+157	163	0	0	Under maint.
80	Chandpur 200MW (Desh energy)	IPP	12*14.4	200	17	908640	Low Demand
81	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	197244	Bad weather
82	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	0	151560	Bad weather
83	Impoport (Tripura)	Imported power	0	160	50	2547840	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	0	683300	Bad weather
85	Jangalia 50 MW PP (Lakshmi)	IPP	6*8.92	52	0	161156	Reserve
86	Chumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	0	364510	Engine problem
87	Daudkandi 200 MW PP (B. Trac)	IPP	15*1.4	200	0	0	Reserve
88	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	976980	Reserve
89	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	8	442680	Low Demand
90	Bharob 54.5 MW	IPP	3*18.2	54	0	480000	Reserve
91	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	17	1291200	Low Demand
Chumilla Area Total				3157	904	32817631	
92	RPCL 210MW CCGP	IPP	41*35+170	202	119	3565440	
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	255132	Engine problem
94	Jamalpur 95 MW PP (Powerpac)	IPP	12*8.924	0	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10400	
96	Mymensingh 200 MW PP (United)	IPP	9*78*21	163	200	2385900	
97	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	115	1645200	Fuel shortage
98	Suliakhali 50 MW Solar PP	IPP	50	50	0	289170	
99	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	11	253920	Engine problem
Mymensingh Area Total				614	408	8404862	
100	Fenchuganj CCGP Phase-1	PDB	2*32+133	70	32	754000	Machine problem
101	Fenchuganj CCGP Phase-2	PDB	2*35+135	90	28	619590	Machine problem
102	Kushara 163 MW CCGP (KP)	IPP	1109+1154	163	0	0	Under maint.
103	Shahjibazar 330 MW CCGP	PDB	3*110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	20	733200	Low Demand
105	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5.2	50	20	702280	Low Demand
106	Haldiganj 1 MW PP (Confidence-E)	SIPP, REB	4*2.90	11	0	173368	Engine problem
107	Shahjibazar GTTP Unit-3 & 9	PDB	2*35	86	81	1174408	
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	30	1725120	Bad weather
109	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
110	Sylhet 225 MW CCGP	PDB	1142+189	231	0	2652380	Machine problem
111	Sylhet 20 MW GTTP	PDB	1*20	20	17	369000	
112	Sylhet 50MW PP (EPZ)	NENP	2*7	0	0	0	Contract Expired
113	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	367488	Engine problem
114	Bitiyana-III 341 MW CCGP (Summit)	IPP	1222+1119	341	280	6907000	FGMO
115	Bitiyana-III 400 MW CCGP	PDB	285*1+134*1	400	377	8846000	FGMO
116	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	0	226620	
117	Bitiyana South 400 MW	PDB	400 MW	383	274	7389000	Bad weather
Sylhet Area Total				2427	1147	32779424	
118	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2*500	1000	491	13508363	
120	Khulina 115 PP MW (KPCL-2)	NENP	7*17	115	0	563920	Reserve
121	Fardpur 50 MW Peaking PP	PDB	6*8.99	54	0	0	Reserve
122	Khulina 225 MW CCGP	NWPGCL	1150+175	230	0	0	Fuel conservation
123	Casapora 100 MW Peaking PP	PDB	12*8.98	109	0	0	Reserve
124	Bheramara 410 MW CCGP	NWPGCL	1278+1132	410	200	8214336	Bad weather
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	0	34500	Reserve
126	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Reserve
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	0	6240	Reserve
128	Madhumati 180 MW PP	NWPGCL	6*18	105	0	272880	Reserve
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	662400	
130	Khulina 330 MW CCGP (DIL)	BPDB	1220+1110	0	0	327102	On test.
131	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	660*2	617	0	0	On test.
132	Kulina 225 MW CCGP (GAS)	NWPGCL	0	0	0	0	
Khulina Area Total				3001	691	23579741	
133	Baisaal 110 MW PP (Summit)	IPP	7*17.076	110	0	424512	
134	Bhola 33 MW PP (Venture)	NENP	1*34	50	6	561609	Engine problem
135	Bhola 225 MW CCGP	PDB	2*63+158	194	6		