

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2023		Day : Sunday				Date : 30.04.23					
Probable Maximum Demand :		14500 MW		Probable Maximum Generation :		15313 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.16 ft		Today = 75.15 ft		Rule Curve = 82.20 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.04.23 (Yesterday)		30.04.23 (Today)		29.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	200	180	180	180		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	74	76	16	76	32	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	333	308	300	330		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	370	450	450		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	394	400	400		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	96	41	90	100	105	1 Unit under maint
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	213	170	220	220	165	ST Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	302	300	300	300		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	30		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	3	0	48	92		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	0	10	18		
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, PDB)	6x3.67+7x3.73	80	80	44	43	43	43		
18	Maona 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	0	25	25		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	24	32	32		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	41	41		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	0	105	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	0	149	149		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	17	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	15	0	17	70		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300		
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	80		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	0	37	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	0	54	70		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	0	72	162		
33	Manikganj 35MW Solar PP (Inspecta Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	14	0	17	35		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	67	0	25	70		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	90	96		
Dhaka Zone Total			6004	5847	2645	2094	3738	4289	137	1010	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120		
40	Kaptai 7 MW Solar PP	Solar (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	11	5	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	34	26	35		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	221	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	123	260	120	300		
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	38	88	38	76		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	84	66	84		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	45	60		
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	13	13		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	33	15	35		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	5	0	50		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	35	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	52	51	51		
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	50	90	63	90		
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	44	10	50	70		
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			28	18	162	162		on test
Chattogram Zone Total			2442	2382	785	1106	1155	1526	205	330	
58	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	38	43	43	43		
59	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+175	221	221	204	212	210	210		
60	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	325	310	310	310		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	325	310	310	310		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0	400	Under maint. Gas Shortage
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55	
64	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'16	195	195	185	108	150	150		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	10	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	8	0	80	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	31	46		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	85	76	17	150		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	18	18		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	5	0	8	8		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	42	5	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, PDB)	3x3.67+2x6.97	25	25	20	19	20	20		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	20x1.4+40x1.515+15x1.056	200	200	0	0	0	0		
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	114		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	55	23	9	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35		
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	60	79	94	94		
**	limpoort (Tripura)	India		160	160	148	132	143	165		
Cumilla Zone Total			3159	3151	1585	1394	1622	2063	55	563	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	144	72	50	100	130	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	0	16	19		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	69	8	75	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	144	0	160	170		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0		
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	6	0	12	12		
Mymensingh Zone Total			622	614	426	80	365	416	130	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.04.23 (Yesterday)		30.04.23 (Today)		29.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)			
87	Fenchugon CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0			GT-1 & ST-1 Under maint.	
88	Fenchugon CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	29	31	31			GT-4 Under maint.	
89	Fenchugon 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			54 ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	60	61	61				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330 Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	80	85	85				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	120	130	133	133				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	0	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	0	16	16	25		Gas Shortage	
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	270	300	310				
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	400	389	400	400				
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	380	400	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100 Under project work	
103	Fenchugon 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	43	40	46	46				
Sylhet Zone Total					2472	2427	1506	1469	1559	1569	25	615	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	400	410	350	350				
106	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	22	35				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	55	74				
108	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x8.445	105	105	0	0	17	17				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x8.415	105	105	15	0	0	100				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	99	0	100	0				
113	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	0	85	98				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	495	485	496	930				
Khulna Zone Total					3005	3001	1009	895	1125	1644	0	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	0	16	64				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	28	25	31				
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	0	90	189	189				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1190	900	1200	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	150				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD	2x75+1x70	220	220	0	0	0	0			220 Under maint.	
Barishal Zone Total					2265	2265	1229	1018	1447	1678	0	220	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	65	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	26	26				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	34				
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	80	90				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	6	24	42				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	35	35				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	194	183	190	190				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	198	173	160	200				
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	433	400	400				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	16	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	43				
138	Baquara 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	95	113				
139	Baquara 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	94	94	50	95				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				504	0	500	500				
Raishahi Zone Total					2129	2129	1499	940	1630	1840	391	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	74	75	75	75	10		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0			Coal Shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	49	34	84				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thekurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	74	115	55	115				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0				
	Teesta Solar Limited	Solar (IPP)				159	0	130	0				
Rangpur Zone Total					830	750	415	239	332	274	10	85	
Sub-total: Plants in operation					22928	22566	11099.0	9235	12973	15299	953	2823	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kalpatoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	52	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.75+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Ambari 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	14				
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	14			
Gross Total					23332	22566	11099	9235	12973	15313	953	2823	
(C) Actual data of 29.04.23 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 9235 MW, at = 21:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 8917 MW, at = 21:00 hrs											
03.	Highest Generation (Generation end)	: 11670 MW, at = 15:00 hrs											
04.	Minimum Generation (Generation end)	: 9111 MW, at = 6:00 hrs											
05.	Day-peak Generation (Generation end)	: 11099 MW, at = 12:00 hrs											
06.	Evening-peak Generation (Generation end)	: 9235 MW, at = 21:00 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8596 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas/LF limitation	: 738 MW											
c)	Coal supply Limitation	: 10 MW											
b)	Low water level in Kaptai lake	: 205 MW											
c)	Plants under shut down/ maintenance	: 2823 MW											
10.	Total Energy (Generation + India Import)	: 245.46 MWh											
	By Gas = 155.413 MKWh	By Oil = 35.224 MKWh											
	By Coal = 37.613 MKWh	By Hydro = 0.303 MKWh											
	By Solar= 2.399 MKWh												
11.	Total Gas Supplied	: 1200.90 MMCFD											
(D) Forecast of 30.04.23 (Today) Sunday :													
01.	Maximum Demand	: 14500 MW (Generation end)											
02.	Maximum Generation	: 15313 MW (Generation end)											
03.	Reserve / Shortage	: 813 MW (Generation end)											
04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)											
05.	Total Generation	: 304.98 MKWh											
06.	Probable Max. Temperature in Dhaka :	: 36.9° C											
12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :													
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
	Dhaka	3058	3058	0	Mymensingh	356	356	0					
	Chattogram	1275	1275	0	Sylhet	127	127	0					
	Khulna	978	978	0	Barishal	347	347	0					
	Rajshahi	967	967	0	Rangpur	759	759	0					
	Cumilla	1050	1050	0									
					Total	8917	8917	0					
13.	Fuel cost :	(a) Gas = 180369452 Taka		(c) Coal = 255342893 Taka									
		(b) Oil = 446946528 Taka		Total = 882658873 Taka									
14.	Maximum Temperature in Dhaka was :	36.6° C											
15													