

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023		Day : Wednesday				Date : 03.05.23						
Probable Maximum Demand :		14500 MW		Probable Maximum Generation :		14712 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.12 ft		Today = 75.09 ft		Rule Curve = 81.81 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.05.23 (Yesterday)		03.05.23 (Today)		Gen. shortfall for : Gas/Coal/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	160	220	180	180			Under project work
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	80	81	75	80	27		Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	340	337	320	320			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	406	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	37	38	100	100			105
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	211	219	220	220			116
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	302	272	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	33	84	40	92		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	16	19	18			
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	8x3.67+7x3.73	80	80	49	50	47	47			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	39	41	16	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	82	88	88	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	130	114	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	17	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	146	285	145	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	120	143	115	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	70	100			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	70	80			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	50	48	54	54			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	35	108	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	35	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	34	34	34	34			
35	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	55	75	70	70			
36	Meghnaghat 100 MW (EEL)	HFO (NENP)	12x8.9	100	100	74	52	80	70			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	50	97	95	97			
Dhaka Zone Total			6004	5847	3232	3567	3928	4348	132	961		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120			180
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	10	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	37	6	38			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	47	17	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	216	227	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	122	280	120	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	63	38	63			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	49	63	84	84			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	40	35	60			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	10	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	26	2	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	50	0	50			
53	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	17	35	35			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	54	54	54			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	50	38	50			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	56	22	44			
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			45	163	142	163			on test
Chattogram Zone Total			2442	2382	953	1387	1057	1451	205	330		
58	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	38	40	40	40			
59	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+175	221	221	118	118	170	180			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	295	230	220	250			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	300	280	280	300			
62	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0			400
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55		Gas Shortage
64	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'16	195	195	45	0	0	0	195		Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	10	130	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	37	39	39			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	155	100	150			Under overhauling
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	0	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	7	7			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	0	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	0	0	0	0			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	70	17	115			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	55	58	113	55			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	115	94	94			
**	limoport (Tripura)	India		160	160	158	164	129	152			
Cumilla Zone Total			3159	3151	1390	1475	1496	1741	250	563		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	136	108	40	100	94		Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	19	19			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	108	100	108			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	152	172	150	180			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0			
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	470	418	373	419	94	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.05.23 (Yesterday)		03.05.23 (Today)		02.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)			
87	Fenchugon CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	43	43	43	27	GT-1 & ST-1 Under maint.		
88	Fenchugon CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	29	29	29	61	GT-4 Under maint.		
89	Fenchugon 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	112	0	0	54	ST Under maint.		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	10	10				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	59	61	62				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	80	82	82				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	203	203	202	202				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	18	0	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9	Gas Shortage		
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	265	300	300				
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	379	369	400	400				
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	385	390	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
103	Fenchugon 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	40	46	44	44				
Sylhet Zone Total					2472	2427	1601	1704	1648	1667	9	572	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	170	160	160	160	250	Gas Shortage		
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	38				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70				
108	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	0	17				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	105	50	100				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	104	0	100	0				
113	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	18	9	85	98				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD (PDB)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	903	898	920	920				
Khulna Zone Total					3005	3001	1210	1324	1315	1443	250	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	64				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	32	25	30				
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	174	182	183	183				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1142	1244	1244	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	81	50	150				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0	220	Under maint.		
Barishal Zone Total					2265	2265	1339	1555	1518	1671	0	220	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	26	26				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	8	0	34				
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	80	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	24	40				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	35	35				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	150	170	170	170	40	Gas Shortage		
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	220		Gas Shortage		
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	135	154	150	150	66	Gas Shortage		
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	225	203	200	200	211	Gas Shortage		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	43	43				
138	Baigura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	70	113	35	113				
139	Baigura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	80	95	35	75				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				408	399	400	400				
Raishahi Zone Total					2129	2129	1098	1347	1268	1438	708	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	75	75	75	10	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	250	250	250		Coal Shortage		
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	42	113	35	80				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thekurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	56	114	35	115				
148	Lalmohit 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	0	30	0				
	Teesta Solar Limited	Solar (IPP)				162	0	130	0				
Rangpur Zone Total					830	750	540	552	563	520	10	85	
Sub-total: Plants in operation					22928	22566	11833.0	13329	13166	14698	1658	2731	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kalpatoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	52	0	0	0	0	0				
151	Bosila 108MW PP(CCL)	HFO (IPP)	12x8.75+1x3.5	109	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Ambari 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	7	0	14				
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	7	0	14			
Gross Total					23332	22566	11833	13336	13166	14712	1658	2731	
(C) Actual data of 02.05.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	: 13542 MW, at = 21:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 12976 MW, at = 21:00 hrs											
03.	Highest Generation (Generation end)	: 13336 MW, at = 21:00 hrs											
04.	Minimum Generation (Generation end)	: 9212 MW, at = 6:00 hrs											
05.	Day-peak Generation (Generation end)	: 11833 MW, at = 12:00 hrs											
06.	Evening-peak Generation (Generation end)	: 13336 MW, at = 21:00 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 197 MW, at = 21:00 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10618 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
	a) Gas/LF limitation	: 1443 MW											
	c) Coal supply Limitation	: 10 MW											
	b) Low water level in Kaptai lake	: 205 MW											
	c) Plants under shut down/ maintenance	: 2731 MW											
10.	Total Energy (Generation + India Import)	: 272.86 MWh											
	By Gas = 149.189 MKWH	By Oil = 51.684 MKWH											
	By Coal = 43.058 MKWH	By Hydro = 0.312 MKWH											
	By Solar= 3.051 MKWH												
11.	Total Gas Supplied	: 1159.38 MMCFD											
(D) Forecast of 03.05.23 (Today) Wednesday :													
01.	Maximum Demand	: 14500 MW (Generation end)											
02.	Maximum Generation	: 14712 MW (Generation end)											
03.	Reserve / Shortage	: 212 MW (Generation end)											
04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)											
05.	Total Generation	: 296.67 MWh											
06.	Probable Max. Temperature in Dhaka :	: 36.6° C											
				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
				Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
				Dhaka	4414	4389	25	Mymensingh	1142	1022	120		
				Chattogram	1407	1407	0	Sylhet	588	566	22		
				Khulna	1543	1543	0	Barishal	424	424	0		
				Rajshahi	1347	1347	0	Rangpur	756	756	0		
				Cumilla	1355	1325	30						
				Total		12976		12779		197			
				13. Fuel cost :		(a) Gas = 171842591 Taka	(c) Coal = 274694114 Taka						