

Bangladesh Power Generation Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month May, 2023													Day : Friday		Date : 05.05.23	
Probable Maximum Demand :			11800 MW			Probable Maximum Generation :			14821 MW			Rule Curve = 81.24 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.05.23 (Yesterday)		05.05.23 (Today)		04.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :							
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)						
											Description/ Remarks	Probable start-up date				
(A) Plants in operation:																
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	0	260	Under project work				
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	110	110	110							
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180							
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	0	365	Under maint.				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	20	30	96		Gas Shortage				
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0							
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	337	345	360	360							
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	225	225							
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling				
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	404	399	400	400							
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	95	100	100	100		105	1 Unit under maint				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	215	210	220	220		125	ST Under maint.				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	285	260	300	300							
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	30							
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	58	40	90							
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	17	15	15	15							
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x4.73	80	80	50	39	46	46							
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33							
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	31	33	33							
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	49	40	50							
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	88	105							
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	115	64	130	149							
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	17	35							
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	195	145	300							
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	70	149	115	149							
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	113	0	300	300							
27	Bramhangsan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	0	70	100							
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	48	0	70	80							
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	50	35	55							
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35							
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	51	50	54	54							
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	108	162							
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	17	0	30	0							
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	40	34	34	34							
35	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	64	55	70	70							
36	Meghnaghat 100 MW (IEL)	HFO (NENP)	12x8.9	100	100	42	65	30	70							
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	95	92	90	92							
Dhaka Zone Total				6004	5847	2858	3167	3558	4237	201	970					
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level				
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120							
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.				
40	Kapali 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0							
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25							
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	6	0	20	0							
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	7	31	6	35							
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	17	51							
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.				
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	228	225	225							
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	123	245	120	300							
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	63	38	63							
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	84	84	84							
50	Hathazeri 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	40	35	40							
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	10	12							
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	20	10	30							
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	38	0	40							
53	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	34							
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54							
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	12	38	50							
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	44	22	44							
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	17	17							
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test				
Chattogram Zone Total				2442	2382	792	1143	888	1249	205	330					
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	38	41	40	41							
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	200	212	200	210							
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	290	295	270	300							
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	290	290	280	300							
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0		400	Under maint.				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55		Gas Shortage				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	8	8	8	187		Gas Shortage				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51							
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	26	50	130	150							
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	38	38	38							
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	152	100	150							
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	18	18							
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	6	6	6	6							
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33							
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52							
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	21							
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	20x14.4+40x1.515+15x1.056	200	200	0	0	0	0							
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	34	17	115							
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	58	55	55							
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	28	35	35	35							
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	95	94	95							
**	Impoport (Tripura)	India		160	160	148	160	129	152							
Cumilla Zone Total				3159	3151	1484	1649	1576	1830	242	563					
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	47	60	100	155		Gas Shortage				
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	18	18							
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	88	90	90							
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	132	163	150	160							
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0							
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	33	0	50	0							
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12							
Mymensingh Zone Total				622	614	315	328	382	380	155	0					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.05.23 (Yesterday)		05.05.23 (Today)		04.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)			
87	Fenchugon CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.	
88	Fenchugon CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	29	29	29		61	GT-4 Under maint.	
89	Fenchugon 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	52	51	51				
90	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	10	10				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	60	61	62				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	83	82	84				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	196	203	202	210				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	17	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16	9		Gas Shortage	
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	270	300	300				
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	367	367	400	400				
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	325	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchugon 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	41	49	44	50				
Sylhet Zone Total					2472	2427	1561	1532	1666	1683	9	572	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	130	135	160	160	275		Gas Shortage	
106	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	38				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70				
108	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	36	0	36				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	22	15	50	100				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	41	0	100	0				
113	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	36	32	85	98				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	24	0	0	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
**	Khulna 330 MW CAPP	Gas/HSD				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	905	904	922	922				
Khulna Zone Total					3005	3001	1175	1122	1317	1464	275	0	
116	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	64				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	27	25	27				
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	184	182	183	183				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1212	1244	1244				
120	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	50	150				
121	Bansal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total					2265	2265	1464	1456	1518	1668	0	220	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	0	32	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	20	0	34				
127	Chapanawaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	46	85	80	85				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	5	24	40				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	0	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	34	8	35	35				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	173	167	170	170	43		Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	144	146	150	150	74		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	170	162	200	200	252		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	21	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	0	8	8				
138	Baigura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	70	35	75				
139	Baigura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	75				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhand Ltd	Coal				450	753	750	750				
Raishahi Zone Total					2129	2129	1196	1515	1589	1726	760	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	75	75	75	10		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	260	260	260			Coal Shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	70	35	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Maijpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thekgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	115	74	35	115				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	13	0	30	0				
	Teesta Solar Limited	Solar (IPP)				5	0	130	0				
Rangpur Zone Total					830	750	508	479	573	563	10	85	
Sub-total: Plants in operation					22928	22566	11353.0	12411	13067	14800	1857	2740	
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kalpatthi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bozila 108MW PP(CLC)	HFO (IPP)	12x8.75+1x3.5	119	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Amitur 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	21	0	21	21				
Sub-Total: Plants under long term maintenance/ contract expired					404	0	21	0	21	21			
Gross Total					23332	22566	11374	12411	13088	14821	1857	2740	
(C) Actual data of 04.05.23 (Yesterday) Thursday :													
01. Max. Demand at eve. peak (Generation end) : 12411 MW, at = 19:30 hrs				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02. Max. Demand at eve. peak (Sub-station end) : 11981 MW, at = 19:30 hrs				Zone Demand MW Supply MW Load Shed MW				Zone Demand MW Supply MW Load Shed MW					
03. Highest Generation (Generation end) : 12411 MW, at = 19:30 hrs				Dhaka 4579 4579 0				Mymensingh 842 842 0					
04. Minimum Generation (Generation end) : 9762 MW, at = 6:00 hrs				Chittogram 1325 1325 0				Sylhet 475 475 0					
05. Day-peak Generation (Generation end) : 11374 MW, at = 12:00 hrs				Khulna 1450 1450 0				Barishal 363 363 0					
06. Evening-peak Generation (Generation end) : 12411 MW, at = 19:30 hrs				Rajshahi 1024 1024 0				Rangpur 711 711 0					
07. Evening Peak Load-shed (Sub-station end) : 0 MW, at = 19:30 hrs				Cumilla 1212 1212 0									
08. Minimum Generation Forecast up to 8:00 hrs. : 9352 MW, at = 5:00 hrs								Total 11981 11981 0					
09. Generation shortfall at evening peak due to :								(a) Gas = 159545231 Taka (c) Coal = 312721038 Taka					
a) Gas/LF limitation : 1642 MW								Total = 1179440397 Taka					
d) Coal supply Limitation : 10 MW													
b) Low water level in Kaptai lake : 205 MW													
c) Plants under shut down/ maintenance : 2740 MW													
10. Total Energy (Generation + India Import) : 268.99 MWh				By Gas = 137.969 MKWH By Oil = 52.753 MKWH				By Coal = 50.748 MKWH By Hydro = 0.304 MKWH					
				By Solar= 1.937 MKWH									
11. Total Gas Supplied : 1073.00 MMCFD													
(D) Forecast of 05.05.23 (Today) Friday :													
01. Maximum Demand : 11800 MW (Generation end)				04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02. Maximum Generation : 14821 MW (Generation end)				05. Total Generation : 255.75 MWh									
03. Reserve / Shortage : 3021 MW (Generation end)				06. Probable Max. Temperature in Dhaka : 37.5° C									

* Coactive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21.00

(Md. Helalur Rahman)
Deputy Secretary, Generation