

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel.: 9564667, 9551095

Month May, 2023	Day: Monday	Date: 08.05.23									
Probable Maximum Demand : 15000 MW		Probable Maximum Generation : 14826 MW									
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 74.83 ft									
		Today = 74.71 ft									
		Rule Curve = 80.67 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.05.23 (Yesterday)		08.05.23 (Today)		Gen. shortfall for : Gas/Coal/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	150	120	120	120		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	22	22	22	22	86	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	334	323	330	330		
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	397	402	412	412		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	1 Unit under maint
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	195	200	200	200	135	ST under maint.
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	295	300	300	300		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15	30	
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	41	40	40	92	
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	22	21	
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	41	48	46	51	52	
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33	33	
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	31	33	33	33	
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	49	16	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	88	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	148	100	149		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	17	17	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	278	145	300		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	35	149		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	303	301	300	300		
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	78	74	70	100		
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	78	70	80		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	0	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	0	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	52	53	54	54		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	54	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	34	34	34	34		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	50	0	75		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	67	33	70	70		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	95	97	97	97		
Dhaka Zone Total			6004	5847	3713	3866	3450	4145	191	980	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	8	39	6	39		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	17	51		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	223	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	300	85	300		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	84	84	84		
50	Hathazeri 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	20	74	35	60		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	8	8	8	8		
*	Malancha, Clg EPZ (United)	Gas	5x8.73+3x9.34			2	30	5	20		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	48	0	50		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	17	17	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	38	38	38		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	22	44		
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			126	163	163	163		on test
Chattogram Zone Total			2442	2382	904	1399	996	1427	205	330	
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	36	39	41	42		
59	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	201	204	200	200		
60	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	305	305	305	305		
61	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	310	310	310	310		
62	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	55		Gas Shortage
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	55	63	63	63	132	Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	43	35	40	43		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	123	20	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	35	36	34		
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	85	34	85		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	7	7		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	29	32	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	20		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	28x1.4+40x1.515+15x1.059	200	200	0	0	0	0		
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	0	114		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	56	56	9	55		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	17	35		
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	95	94	94	94		
**	limoport (Tirpura)	India		160	160	156	148	143	166		
Cumilla Zone Total			3159	3151	1498	1776	1442	1826	187	563	
80	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	28	74	44	70	128	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	16	16	17		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	88	98	50	98		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	141	97	57	98		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0		
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total			622	614	327	297	231	295	128	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.05.23 (Yesterday)		08.05.23 (Today)		07.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
87	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27		GT-1 & ST-1 Under maint.
88	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	29	29	29	61		GT-4 Under maint.
89	Fenchuganj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	50	50	50	50			
90	Kushlora 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	54		ST Under maint.
91	Hobignaj 111MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	10	10			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	57	56	60			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330		Under maint.
94	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	79	83	84	84			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	200	210	210	210			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	17			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x3.34	25	25	16	16	16	16	9		Gas Shortage
99	Biobara-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	300	300			
100	Biobara-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	367	408	400	400			
101	Biobara South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	353	390	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	43	49	44	50			
Sylhet Zone Total			2472	2427	1542	1662	1669	1679	1679	9	572	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CAPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	125	140	150	150	270		Gas Shortage
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	14	29	0	43			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	77	0	76			
108	Khulna 225 MW CAPP	HSD/ Gas (NWP/CGCL)	1 x 150+1x75	230	230	0	0	0	0			
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0			
110	Rupsa 105 MW PP (Orion nusha)	HFO (IPP)	6x18.445	105	105	30	53	35	48			
111	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	50	105	50	105			
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	98	0	100	0			
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	78	95	85	98			
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	40	40	0	40			
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIF/PCCL)	1x617	617	617	0	0	0	0			
	Khulna 330 MW CAPP	Gas/HSD (B/PPD)		0	0	0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	908	913	929	929			
Khulna Zone Total			3005	3001	1343	1452	1349	1489	1489	270	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	16	64			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	27	34	20	32			
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	174	180	180	181			
119	Payra 1320 MW TPP	Coal (BC/PCCL)	2x622	1244	1244	1244	1244	1244	1244			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	50	150			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0			
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0	220		Under maint.
Barishal Zone Total			2265	2265	1462	1640	1510	1671	1671	0	220	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	30	0	24			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	42	0	31			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	72	80	83			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	24	40			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	34	34	34	34			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	166	170	160	164	40		Gas Shortage
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/CGCL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	134	143	140	142	77		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	125	157	200	200	257		Gas Shortage
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	12	20	22	22			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	43	8	43			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	75	35	75			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70			
140	Ammura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	50	21	28	21	21			
141	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	4	0	6	0			
	Adani Power Jharkhanda Ltd	Coal				731	760	750	750			
Rajshahi Zone Total			2179	2129	1446	1726	1557	1741	1741	765	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	75	75	75	10		Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	250	250	250			Coal Shortage
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	34	113	34	113			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatulia 3 MW Solar PP (Synpa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
148	Thekgagan 103MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	35	115			
149	Lamorinhet 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0			
	Teesta Solar Limited	Solar (IPP)				183	0	130	0			
Rangpur Zone Total			830	750	561	513	562	553	553	10	85	
Sub-total: Plants in operation			22978	22566	12796.0	14331	12766	14826	14826	1765	2750	

(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Kapcotli 32 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PP (CLC)	HFO (IPP)	12x8.175+1x3.5	118	0	0	0	0	0			
153	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired			354	0	0	0	0	0	0	0	0	
Gross Total			23332	22566	12796	14331	12766	14826	14826	1765	2750	

(C) Actual data of 07.05.23 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)			: 14802 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)			: 14091 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)			: 14331 MW, at = 21:00 hrs									
04.	Minimum Generation (Generation end)			: 10825 MW, at = 6:00 hrs	Dhaka	5955	5055	0	Mymensingh	1105	905	200	
05.	Day-peak Generation (Generation end)			: 12796 MW, at = 12:00 hrs	Dhaka	1405	1405	0	Sylhet	572	572	0	
06.	Evening-peak Generation (Generation end)			: 14331 MW, at = 21:00 hrs	Khulna	1767	1697	70	Barishal	439	439	0	
07.	Evening Peak Load-shed (Sub-station end)			: 450 MW, at = 21:00 hrs	Rajshahi	1469	1469	0	Rangpur	902	852	50	
08.	Minimum Generation Forecast up to 8:00 hrs.			: 11358 MW, at = 5:00 hrs	Cumilla	1377	1247	130					
09.	Generation shortfall at evening peak due to :			:	13. Fuel cost :		(a) Gas = 16572749 Taka		(c) Coal = 325848744 Taka		450		
	a) Gas/LF limitation	:	1550 MW					(b) Oil = 948806910 Taka		Total = 1440383404 Taka			
	d) Coal supply Limitation	:	10 MW										
	b) Low water level in Kaptai lake	:	205 MW										
	c) Plants under shut down maintenance	:	2750 MW		14. Maximum Temperature in Dhaka was :			37.7° C					
10.	Total Energy (Generation + India Import)	:	301.08 MMKWh		15. Export through East-West Interconnections :								
	By Gas = 144.560 MKWh	By Oil = 70.348 MKWh			At evening peak-hour :			12796 MW	at 21:00 hrs				
	By Coal = 57.307 MKWh	By Hydro = 0.308 MKWh			Maximum :			466 MW	at 21:00 hrs				
	By Solar = 3.050 MKWh				Energy :			0 MKWh					
11.	Total Gas Supplied	:	1110.69 MMCFD										

(D) Forecast of 08.05.23 (Today) Monday :												
01.	Maximum Demand	:										