

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023			Day : Tuesday						Date : 16.05.23		
Probable Maximum Demand : 14300 MW			Probable Maximum Generation : 12126 MW						Rule Curve = 79.15 ft.		
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 73.87 ft.		Today = 73.83 ft.		16.05.23 (Today)		15.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.05.23 (Yesterday)		16.05.23 (Today)		15.05.23 (Yesterday)		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gas/Coal/Water Limitation (MW)	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	100	120	120	120	60	Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	280	272	280	300	88	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	1 Unit under maint
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	15	15		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	50	24	50		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.87+7x3.73	80	80	51	49	48	48		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	33	33	33	33		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	26	24	24	24		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	48	16	48		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	150	100	148		
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	195	50	195		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	133	135	135	135		
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x11.4	300	300	300	254	300	300		
27	Banarhanganj 100 MW PP (Agreko)	HSD (IPP)	23x0.85+91x.958	100	100	80	83	80	80		
28	Kurathal 100MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	75	75	80		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	33	17	17		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	34		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	26	25	16	16		
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	8	25	8	25		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	17	17	17		
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0		
Dhaka Zone Total			6104	5867	1972	2451	1986	2484	1668	845	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	27	25	25	25	205	Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0		
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	44	6	44		
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	87	17	105		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	61	145	150		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	88	278	88	300		
49	Juldah 100 MW PP Unit 3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	25	25	25		
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	84	84	84		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	55	54	54	57		
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10		
*	Malancha, City EPZ (United)	Gas	5x8.73+3x9.34			0	6	0	5		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	29	0	30		
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	100	92	100		
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	20	25	25	25		
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	22	22	22	22		
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17		
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	35	163		
Chattogram Zone Total			2605	2545	554	1062	713	1204	385	330	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	37	39	40	40		
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	202	207	205	210		
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360	Gas Shortage
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	340	355	350	350		
64	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	177	184	185	185		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	43	43	43		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	31	85	20	150		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	35	35	35		
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	18	18		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	5	7		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	0	21	21		
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	52	0	0		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	57	95	55	96		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	53	85	75	94		
**	Impoort (Tripura)	India		160	160	152	162	129	152		
Cumilla Zone Total			2904	2896	1166	1394	1258	1478	360	563	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	49	101	70	101	101	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	77	87	68	94		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	2	84	28	90		
84	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0		
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total			622	614	214	303	249	316	101	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.05.23 (Yesterday)		16.05.23 (Today)		15.05.23 Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	42	43	43	28		GT-1 & ST-1 Under maint.
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	29	29	29	61		GT-4 Under maint.
89	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	50	53	51	51			
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	54		ST Under maint.
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	3	3	3	3			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	61	61	61			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330		Under maint.
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	76	80	84	84			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	207	202	210	210			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	18	17	17			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	255	290	300			
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	373	403	400	400			
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	396	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	46	49	44	44			
Sylhet Zone Total												
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	27	20	43			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	73	60	82			
108	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Kushta 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	32	85	85	105			
111	Mongla Oron 100 MW Solar PP	Solar (IPP)		100	100	97	0	100	0			
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	46	39	66	98			
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	8	0	24	40			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0			
**	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	913	853	643	645			
Khulna Zone Total												
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	28	22	32			
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	177	179	184	184			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1110	1100	1244	1244			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	201	258	300	300			
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0	220		Under maint.
Barishal Zone Total												
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	28	28	28			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	21	15	35			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	80	80	80	83			
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	24	40			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	28	28	28	28			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	164	159	170	170	51		Gas Shortage
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	140	155	160	160	65		Gas Shortage
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	303	328	380	380	86		Gas Shortage
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	21	20	20			
135	Lillaipara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	35	50	35	50			
139	Amritara 30 MW PP (Srinah)	HFO (NENP)	7x7.79	50	28	21	21	21	21			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	6	0	6	0			
**	Adani Power Jharkhand Ltd	Coal (Import)	1x748	748	748	324	401	400	400			
Rajshahi Zone Total												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	75	75	75	10		Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	260	260	260			Coal Shortage
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	33	54	34	50			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	35	114	35	115			
148	Lalmohat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	29	0	30	0			
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	165	0	130	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PPI(LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired												
Gross Total												
(C) Actual data of 15.05.23 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	: 13585 MW, at = 20:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 12950 MW, at = 20:00 hrs										
03.	Highest Generation (Generation end)	: 11496 MW, at = 20:00 hrs										
04.	Minimum Generation (Generation end)	: 8943 MW, at = 6:00 hrs										
05.	Day-peak Generation (Generation end)	: 9984 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 11496 MW, at = 20:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 1995 MW, at = 20:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8843 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :	:										
a)	Gas/LF limitation	: 3229 MW										
d)	Coal supply Limitation	: 10 MW										
b)	Low water level in Kaptai lake	: 205 MW										
c)	Plants under shut down/ maintenance	: 2716 MW										
10.	Total Energy (Generation + India Import)	: 792.28 MMCFD										
	By Gas = 103.154 MKWH	By Oil = 55.829 MKWH										
	By Coal = 52.378 MKWH	By Hydro = 0.316 MKWH										
	By Solar= 2.678 MKWH											
11.	Total Gas Supplied	: 792.28 MMCFD										
			12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
			Dhaka	5142	4511	631	Mymensingh	1155	930	225		
			Chattogram	1123	981	142	Sylhet	546	444	102		
			Khulna	759	759	0	Barishal	415	415	0		
			Rajshahi	1484	1233	251	Rangpur	945	719	226		
			Cumilla	1381	963	418						
							Total	12950	10955	1995		
			13.	Fuel cost :	(a) Gas = 117326515 Taka	(c) Coal = 311024631 Taka						
					(b) Oil = 812866452 Taka	Total = 1241217597 Taka						
			14.	Maximum Temperature in Dhaka was :	34.9° C							
			15.	Export through East-West interconnections :								
				At evening peak-hour :	9984 MW, at 20:00 hrs							
				Maximum :	652 MW, at 7:00 hrs							
				Energy :	0 MKWH							
			16.	Probable Max. Temperature in Dhaka :	34.9° C							
(D) Forecast of 16.05.23 (Today) Tuesday :												
01.	Maximum Demand	: 14300 MW (Generation end)										
02.	Maximum Generation	: 12126 MW (Generation end)										
03.	Reserve / Shortage	: -2174 MW (Generation end)										
04.	Maximum Load-shed	: 2004 MW At evening peak (Sub-station end)										
05.	Total Generation	: 297.79 MKWH										
06.	Probable Max. Temperature in Dhaka :	34.9° C										

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation