

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023		Day : Sunday				Date : 21.05.23						
Probable Maximum Demand :		14500 MW		Yesterday = 73.66 ft		Today = 73.62 ft		Probable Maximum Generation : 14231 MW		Rule Curve = 78.39 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.05.23 (Yesterday)		21.05.23 (Today)		20.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	317	327	310	330			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	402	409	410	410			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	278	310	290	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	24	0	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	41	16	42			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.87+7x8.73	80	80	42	48	47	47			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	29	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	48	16	48			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	86	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	150	100	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	195	45	195			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	133	17	149			
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	246	263	300	300			
27	Biramhasanj 100 MW PP (Agreko)	HSD (IPP)	23x0.85+91x.958	100	100	0	50	40	50			
28	Auraha 100MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	40	25	40	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	53			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	108	35	108			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	15	42	40	42			
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	9	32	8	33			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	85	17	85			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0			
Dhaka Zone Total			6104	5867	2610	3445	2791	3527	758	375		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	22	25	205		Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	9	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	40	6	44			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	26	68	17	87			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	163	226	226	226			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	87	280	88	300			
49	Juldah 100 MW PP Unit 3 (Acorn)	HFO (IPP)	8x13.45	100	100	38	38	38	38			
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	51	51	51			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	47	56	64	64			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	23	5	15			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	30			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	74	74	72	72			
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	38	38	25	25			
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	22	22	22	22			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	163	35	163			
Chattogram Zone Total			2605	2545	634	1175	765	1231	385	330		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	37	40	40			
61	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	181	182	200	200			
62	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	305	305	320	320			
63	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	280	310	310	310			
64	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400		Under maint.
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	163	168	179	179			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	129	20	150			
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	43	43	43			
69	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	12	15	15	15			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	8	7	7			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	24	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	51	0	51			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	31	97	28	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	9	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	24	72	54	75			
**	Impoport (Tripura)	India		160	160	148	146	129	152			
Cumilla Zone Total			2904	2896	1346	1710	1493	1803	0	563		
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	34	69	40	70	133		Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	18	18	18			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	84	18	88			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	87	68	85			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	56	0	50	0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	203	270	208	273	133	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.05.23 (Yesterday)		21.05.23 (Today)		20.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :						
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date		
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.			
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	28	28	28		62	GT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	42	50	50	50						
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.			
91	Hobignaj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11						
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	56	59	60						
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x90	86	86	78	78	78	84						
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	135	133	135	135						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	17						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage			
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	285	290	300						
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	408	402	400	400						
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	325	330	330	330						
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	50	50	50	50						
Sylhet Zone Total															
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage			
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	22	22	43						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	80	60	80						
108	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Kushtia 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	18	18	17	17						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	105	85	105						
111	Mongla Oron 100 MW Solar PP	Solar (IPP)		100	100	102	0	100	0						
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	34	65	66	83						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	8	32	8	40						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	314	326	330	330						
**	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0						
**	Bheramara (HVDC)	India		1000	1000	911	726	935	935						
Khulna Zone Total															
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16						
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	32	22	35						
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	50	160	150	160						
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1020	1244	1160	1244						
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	150	17	150						
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	151	309	175	307						
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.			
Barishal Zone Total															
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage			
b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	0		100	Under maint.			
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	28	28						
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	15	35						
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	47	80	60	80						
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	24	40						
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	42	42	42						
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	28	34						
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	165	162	170	170						
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	177	148	150	150						
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage			
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	416	357	350	380						
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	20	20						
135	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	0	43						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50						
139	Amritara 30 MW PP (Srinia)	HFO (NENP)	7x7.79	50	28	28	21	21	21						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0						
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	410	597	605	605						
Rajshahi Zone Total															
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	73	75	75		12	Coal Shortage			
b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	260	260	260			Coal Shortage			
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	78	40	107						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	113	50	115						
148	Lalmohat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0						
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	202	0	130	0						
Rangpur Zone Total															
Sub-total: Plants in operation															
(B) Plants under long term maintenance/ contract expired															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
152	Bosilia 108MW PPI(LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
153	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired															
Gross Total															
(C) Actual data of 20.05.23 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	14250	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):									
02.	Max. Demand at eve. peak (Sub-station end)	:	13654	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	13626	MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	8609	MW, at =	6:00 hrs	Dhaka	4951	4861	90	Mymensingh	1055	915	140		
05.	Day-peak Generation (Generation end)	:	10970	MW, at =	12:00 hrs	Chattogram	1392	1392	0	Sylhet	507	507	0		
06.	Evening-peak Generation (Generation end)	:	13626	MW, at =	21:00 hrs	Khulna	1683	1683	0	Barishal	437	437	0		
07.	Evening Peak Load-shed (Sub-station end)	:	596	MW, at =	21:00 hrs	Rajshahi	1427	1427	0	Rangpur	861	735	126		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10714	MW, at =	5:00 hrs	Cumilla	1341	1101	240						
09.	Generation shortfall at evening peak due to :	:								Total	13654	13058	596		
a)	Gas/LF limitation	:	1781	MW						(a) Gas =	147700603	Taka	(c) Coal =	276659763	Taka
d)	Coal supply Limitation	:	12	MW						(b) Oil =	641204489	Taka	Total =	1065564655	Taka
b)	Low water level in Kaptai lake	:	205	MW											
c)	Plants under shut down/ maintenance	:	2246	MW											
10.	Total Energy (Generation + India Import)	:	260.84	MKWh						14. Maximum Temperature in Dhaka was :	35.1° C				
	By Gas =	130.905	MKWh	By Oil =	45.694	MKWh				Export through East-West interconnections :					
	By Coal =	56.607	MKWh	By Hydro =	0.318	MKWh				At evening peak-hour	:	10970	MW, at	21:00 hrs	
	By Solar =	3.188	MKWh							Maximum	:	750	MW, at	7:00 hrs	
11.	Total Gas Supplied	:	1025.28	MMCFD						Energy	:	0	MKWh		
(D) Forecast of 21.05.23 (Today) Sunday :															
01.	Maximum Demand	:	14500	MW	(Generation end)	04.	Maximum Load-shed	:	248	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14231	MW	(Generation end)	05.	Total Generation	:	277.57	MKWh					
03.	Reserve / Shortage	:	-269	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.1° C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation