

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	129	281438	Gas shortage
3	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.
4	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
5	Ghorasal 108MW PP (Regent)	IPP	343.35	208	6	54363	Gas shortage
6	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
7	Haripur 412 MW CCGP	EGCB	1273+1139	412	389	9400320	Gas shortage
8	Haripur 360MW CCGP(HPL)	IPP	1235+1125	360	327	758000	Gas shortage
9	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	420	9975500	Gas shortage
10	Meghnaghat 100 MW(IEL)	NENP	12*9	100	33	273600	Fuel shortage
11	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	290	7219491	FGMO
12	Madangan 102 PP(Summit)	NENP	6*17	102	80	536638	Engine problem
13	Madangan-55 MW PPS(Summit)	IPP	3*17.08+111.3	55	15	69084	Fuel shortage
14	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	20	0	644550	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	0	364896	Engine problem
16	210 MW Siddhirgonj TFP	PDB	1210	115	0	0	Under maint.
17	Siddhirgonj 2120 MW GTTP	EGCB	2105	210	0	3200	Gas shortage
18	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12*9	100	42	282374	Fuel shortage
19	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	0	140091	Gas shortage
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	41	383760	Fuel shortage
21	Katipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	17	227520	Fuel shortage
23	Kodda 150 MW PP	BPDB-RPCL	9*17.08	149	249	1588440	
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	447982	
25	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	475341	
26	Bosila 108MW PP(CLC)	IPP	12*8.775+113.5	0	0	0	
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	46	980520	Engine problem
28	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	676500	
29	Ruaganj 100 MW PP(Summit)	SIPP, REB	4*8.73	33	30	694000	
30	Gazipur 52 MW PP	RPCL	6*8.9	52	49	262560	0.00
31	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	195	1472836	Fuel shortage
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	10	2582185	Low demand
34	Bramharata 100 MW PP (Aggreko)	IPP	1149.959	50	50	631611	Low demand
35	Aurahat 100MW PP (Aggreko)	IPP	0.85*23.05*91	100	69	618692	Low demand
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	134	1248192	Fuel shortage
37	Gazipur 100 MW PP	RPCL	6*17.5	105	88	1588416	Engine problem
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	17	567360	Low demand
39	Manikganj 162MW PP(MPGL)	IPP	9*18	162	90	812160	Low demand
40	Spectro Solar Plant Ltd.	IPP	35	35	0	198467	
41	Kanchan Fultbachal Power Generation Ltd.	IPP	18.4*3	55	35	462240	Fuel shortage
Dhaka area Total				5867	3065	59456027	
41	Chattogram TPP-1	PDB	1210	180	0	0	Gas shortage
42	Chattogram TPP-2	PDB	1210	180	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	3*8.9	25	25	312577	
44	Tafail 20MW PP (Sadarlech)	IPP	20	20	0	130815	
45	Palenga 50MW PP (Baraka)	IPP	6*8.98	50	2	204480	Low demand
46	Kapila Hydro Unit-1,2,3,4, 5	PDB	240+3*50	230	25	306000	Low Water level
47	Sikalbaha 225MW	PDB	1150+175	225	227	5250489	
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	68	679627	Fuel shortage
50	Haziganj 100 MW peaking PP	PDB	11*9.9	98	57	1064928	Engine problem
51	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	51	121818	Engine problem
52	Juldah 100 MW Unit-1 (Accorn)	NENP	8*13.45	100	33	670080	Fuel shortage
53	Juldah 100 MW Unit-3 (Accorn)	IPP	8*13.5	100	38	619200	Fuel shortage
54	Barakkunda 22 MW PP (Regent)	SIPP, PDB	6*2.90	22	0	500	Engine problem
55	Malancha, Ch. EPZ Unit-1	IPP	5*8.73+9.34	0	25	500160	
56	Chattogram 108 MW PP (ECPV)	PDB	16*7	108	12	99540	Fuel shortage
57	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	33598	
58	Anwara 300 MW PP (United)	IPP	17*17+24	300	294	2770036	
59	Jodiach Power	IPP	3*18.55+113.6	54	17	448943	Fuel shortage
60	Kanapahuli Power Ltd.	IPP	18.415*6+8.5	110	54	1405920	Fuel shortage
61	Juldah unit-3 (Accorn)	IPP	8*13.5	100	38	712320	
62	Anlima Energy Ltd.	IPP	6*21.2	116	17	416590	Fuel shortage
63	Mirsharai 150 MW	BPDB-RPCL	18.5*9	163	18	426545	
Chattogram area Total				2545	1001	17466985	
61	Ashuganj TPP Unit- 3	APSCL	1150	0	0	0	Contract Expired
62	Ashuganj TPP Unit- 4	APSCL	1150	0	0	0	Contract Expired
63	Ashuganj TPP Unit- 5	APSCL	1150	0	0	0	Contract Expired
64	Ashuganj 225 MW CCGP	APSCL	1142+175	221	213	4856000	11/1994
65	Ashuganj 450 MW CCGP(North)	APSCL	1360	360	305	792760	
66	Ashuganj 450 MW CCGP(South)	APSCL	1360	360	300	7563000	FGMO
67	Ashuganj 420 MW CCGP(East)	APSCL	284*1+116*1	400	0	0	Under maint.
68	Ashuganj 50 MW PP	APSCL	14*3.968	45	34	805392	Machine problem
69	Ashuganj 55 MW PP (Precision)	QRPP	0	0	0	0	Contract Expired
70	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+116	195	189	4048000	
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	987870	
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	145	705890	
73	Titas 50 MW Peaking PP	PDB	6*8.92	52	44	1007168	Engine problem
74	Chandpur 150 MW CCGP	PDB	1106+157	163	0	0	Under maint.
75	Chandpur 200MW (Desh energy)	IPP	1212+4	200	17	431040	Fuel shortage
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	15	345564	Engine problem
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	7	196660	Engine problem
78	Impoport (Tripura)	Imported power	0	160	156	3596160	
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	526600	Engine problem
80	Jangalia 33 MW PP (Lakshmi)	IPP	6*8.92	52	48	719820	Engine problem
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	20	426150	Engine problem
82	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Contract Expired
83	Feni Lanka Power	IPP	7*18.415+19.78	114	114	647520	
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	95	879480	Fuel shortage
85	Bharob 54.5 MW	IPP	3*18.2	54	17	762120	Fuel shortage
86	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	72	691200	Fuel shortage
Cumilla Area Total				3096	1667	37112834	
87	RPCL 210MW CCGP	IPP	4155+170	202	49	1198160	Gas shortage
88	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	301824	Engine problem
89	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10600	
91	Mymensingh 200 MW PP (United)	IPP	9*78*21	200	57	1430400	Fuel shortage
92	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	85	537600	Fuel shortage
93	Suliakhali 50 MW Solar PP	IPP	50	50	0	229000	
94	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	12	245520	Engine problem
Mymensingh Area Total				614	203	39511704	
91	Fenchuganj CCGP Phase-1	PDB	2*32+133	70	43	1017000	Machine problem
92	Fenchuganj CCGP Phase-2	PDB	2*35+135	90	40	681990	Machine problem
93	Kushara 163 MW CCGP (KP)	IPP	1109+154	163	0	0	Gas shortage
94	Shahjibazar 330 MW CCGP	PDB	3*110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	47	1069200	
96	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5.2	50	50	1059048	
97	Haldiganj 1 MW PP (Confidence-E)	SIPP, REB	4*2.90	11	0	134000	
98	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	86	83	1277184	
99	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	75	1614720	
100	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
101	Sylhet 225 MW CCGP	PDB	1142+189	231	133	3167690	ST Under maint.
102	Sylhet 20 MW GTTP	PDB	1*20	20	17	408000	
103	Sylhet 50MW PP (EP)	NENP	2*7	0	0	0	Contract Expired
104	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	370174	Engine problem
105	Bitiyana-II 341 MW CCGP (Summit)	IPP	1222+1119	341	270	6901000	FGMO
106	Bitiyana-III 400 MW CCGP	PDB	285*1+134*1	400	367	9047000	FGMO
107	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	249660	
108	Bitiyana South 400 MW	PDB	400 MW	383	330	7903700	Machine problem
Sylhet Area Total				2427	1461	34990336	
107	Bheramara GTTP Unit- 3	PDB	120	16	0	0	Fuel shortage
108	Bheramara (HVDC)	Imported power	2*500	1000	845	21226181	
109	Khulina 115 PP MW (KPCL-2)	NENP	7*17	115	64	692160	Low demand
110	Fardpur 50 MW Peaking PP	PDB	6*8.89	54	14	126720	Engine problem
111	Khulina 225 MW CCGP	NWPGCL	1150+175	230	0	0	Fuel conservation
112	Casapora 100 MW Peaking PP	PDB	19*8.98	109	87	488224	Engine problem
113	Bheramara 410 MW CCGP	NWPGCL	1278+1132	410	0	0	Gas shortage
114	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	32	193500	Fuel shortage
115	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	0	0	0	Contract Expired
116	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	17	386400	Fuel shortage
117	Madhumati 100 MW PP	NWPGCL	6*18	105	15	746784	Fuel shortage
118	Mongia Orion 100 MW Solar PP	IPP	100	100	0	640080	
119	Khulina 330 MW CCGP (DIL)	BPDB	1220+1110	0	0	705556	On test.
120	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	660*2	617	325	7760000	
121	Kulina 225 MW CCGP (GAS)	NWPGCL	0	0	0	0	
Khulina Area Total				2901	1399	32945605	
117	Baisaal 110 MW PP (Summit)	IPP	7*17.076	110	16	207360	Fuel shortage
118	Bhola 33 MW PP (Venture)	NENP	1*34.50	31	40	646091	Engine problem
119	Bhola 225 MW CCGP	PDB	2*63+168	194	150	3520510	Machine problem
120	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2*622	1244	1110	27798100	
122	Bhola Nutan Biddut BD LTD	IPP	220	220	0	0	Under maint.
123	United Payra Power Ltd.	IPP	8*18.5+19.5	150	17	313200	Transformer OIL
124	Baisaal 307 MW	BCPCL	307*1	307	151	4855300	Transformer OIL
Barisal Area Total				2265	1475	37345571	
124	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
125	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
126	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	28	572720	Engine problem
127	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	98000	Reserve
128	Annura 50 MW PP(Sinha)	QRPP	7*7.98	28	28	486150	Engine problem
129	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	42	819353	Engine problem
130	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	40	535215	Engine problem
131	Sirajgonj Unit-1 225MW	NWPGCL	1150+175	210	151	3923491	Gas shortage
132	Sirajgonj Unit-2 225MW	NWPGCL	1150+175	220	147	3431164	
133	Sirajgonj Unit-3 225MW	NWPGCL	1141	0	0	0	Gas shortage
134	Sirajgonj 400 MW CCGP Unit-4	NWPGCL	1262+1132	414	279	7354154	Gas shortage
135	Santahar 50 MW Peaking PP	PDB	6*8.7	50	28	558127	Engine problem
136	Bogra 22 MW PP (GDB)						