

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2023		Day : Monday				Date : 22.05.23					
Probable Maximum Demand :		13900 MW		Yesterday = 73.62 ft		Today = 73.54 ft		Probable Maximum Generation : 14663 MW		Rule Curve = 78.00 ft.	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.05.23 (Yesterday)		22.05.23 (Today)		21.05.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	6	22	22	102	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	327	350	350		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	420	450	450		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	405	389	410	410		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	120	120	210	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 210+1x118	335	335	0	0	220	220	335	Gas Shortage
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	295	290	310	310		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	0	30		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	41	16	42		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	22	22		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.97+7x8.73	80	80	44	46	47	47		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	33	33	33	33		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	28	30	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	49	16	48		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	70	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	149	100	150		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	195	45	195		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	134	135	135		
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	256x1.4	300	300	300	10	300	300		
27	Biramhasan 100 MW PP (Agreko)	HSD (IPP)	23x0.85+91x.958	100	100	50	50	40	50		
28	Auraha 100MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	40	69	40	50		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	34	17	17	53		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	90		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	34		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	42	8	40		
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	8	33	8	33		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	80	17	102		
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	78	0	0	0		
Dhaka Zone Total			6104	5867	2957	3065	3281	3902	752	375	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	60	70	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25		
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	2	44	44		
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	68	34	68		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	222	227	226	226		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	87	294	88	300		
49	Juldah 100 MW PP Unit 3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	38	38	38		
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	68	68		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	57	54	70		
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	25	5	15		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12		
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	70	54	72	72		
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	38	38	38	38		
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	33	33	33	33		
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17		
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	18	18	163		
Chattogram Zone Total			2605	2545	706	1001	880	1311	385	330	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	34	40	40		
61	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	201	213	200	200		
62	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	305	300	320	320		
63	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	310	305	310	310		
64	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400	Under maint.
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	179	189	179	179		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	145	20	150		
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	44	43	43		
69	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	7	7		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	48	8	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	20	20	20		
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	0	114		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	57	95	27	95		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	22	17	17	17		
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	18	72	18	72		
**	Impoport (Tripura)	India		160	160	160	156	129	152		
Cumilla Zone Total			2904	2896	1458	1867	1446	1879	0	563	
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	30	49	40	90	153	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	0	18	18		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	85	18	88		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	57	68	85		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	50	0	50	0		
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total			622	614	195	203	208	293	153	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.05.23 (Yesterday)		22.05.23 (Today)		21.05.23 Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	40	40	40		50	GT-4 Under maint.
89	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	47	47	50	50			
90	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.
91	Hobignaj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	63	59	60			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x90	86	86	78	75	78	84			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	130	133	90	220			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	17			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	270	300	300			
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	369	367	400	400			
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	330	330	330	330			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	47	50	50	50			
Sylhet Zone Total												
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	14	22	43			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	87	60	80			
108	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Kushtha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	15	85	105			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	99	0	100	0			
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	64	32	98			
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	16	32	24	32			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	321	325	330	330			
**	Khulna 330 MW CAPP	Gas/HSD (BPDB)				156	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	918	845	935	840			
Khulna Zone Total												
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	24	31	22	35			
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	150	150	150	160			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1070	1110	950	1244			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	171	151	175	307			
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.
Barishal Zone Total												
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage
b) Baghabari 100 MW GTTP	Gas (PDB)		1 x 100	100	100	0	0	0	0		100	Under maint.
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	28	28	28			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	60	80	60	80			
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	40	40			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	28	28	28	28			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	151	151	150	150			
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	128	147	150	150			
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	298	279	350	380			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	19	20	20			
135	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
139	Amritara 30 MW PP (Srinia)	HFO (NENP)	7x7.79	50	28	28	28	21	21			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	603	598	605	605			
Rajshahi Zone Total												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	73	72	75	75		13	Coal Shortage
b) Barapukuria TPP Unit-2	Coal (PDB)		1 x 125	125	85	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	260	260	260			Coal Shortage
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	15	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	34	49	55	75			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	113	50	115			
148	Lalmohat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0			
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	74	0	130	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PPI(LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired												
Gross Total												
(C) Actual data of 21.05.23 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	: 12900 MW, at = 19:30 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 12480 MW, at = 19:30 hrs										
03.	Highest Generation (Generation end)	: 12533 MW, at = 19:30 hrs										
04.	Minimum Generation (Generation end)	: 10627 MW, at = 9:00 hrs										
05.	Day-peak Generation (Generation end)	: 11795 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 12533 MW, at = 19:30 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 350 MW, at = 19:30 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8863 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas/LF limitation	: 1795 MW										
d)	Coal supply Limitation	: 13 MW										
b)	Low water level in Kaptai lake	: 205 MW										
c)	Plants under shut down/ maintenance	: 2234 MW										
10.	Total Energy (Generation + India Import)	: 996.61 MMCFD										
			By Gas = 133.326 MKWH	By Oil = 45.762 MKWH								
			By Coal = 62.239 MKWH	By Hydro = 0.306 MKWH								
			By Solar= 2.282 MKWH									
11.	Total Gas Supplied	: 996.61 MMCFD										
(D) Forecast of 22.05.23 (Today) Monday :												
01.	Maximum Demand	: 13900 MW (Generation end)										
02.	Maximum Generation	: 14663 MW (Generation end)										
03.	Reserve / Shortage	: 763 MW (Generation end)										
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
		Dhaka	5192	5192	0	Mymensingh	432	432	0			
		Chattogram	1467	1327	140	Sylhet	308	308	0			
		Khulna	1726	1701	25	Barishal	424	384	40			
		Rajshahi	888	888	0	Rangpur	795	795	0			
		Cumilla	1248	1103	145							
				Total	12480	12130			350			
		13.	Fuel cost :	(a) Gas = 151452169 Taka	(c) Coal = 292567596 Taka							
				(b) Oil = 637317261 Taka	Total = 1081337026 Taka							
		14.	Maximum Temperature in Dhaka was :	35.4° C								
		15.	Export through East-West interconnections :									
					At evening peak-hour	: 11795 MW, at 19:30 hrs						
					Maximum	: 750 MW, at 7:00 hrs						
					Energy	: 0 MKWH						
(E) Maximum Load-shed : 248 MW At evening peak (Sub-station end)												
05. Total Generation : 298.05 MKWh												
06. Probable Max. Temperature in Dhaka : 35.4° C												

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation