

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 3564667, 3551095

Month May, 2023		Day: Saturday				Date: 27.05.23							
Probable Maximum Demand :		13500 MW		Probable Maximum Generation :		13883 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 73.12 ft		Today = 73.07 ft		Rule Curve = 77.00 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	26.05.23 (Yesterday)		27.05.23 (Today)		Gen. shortfall or Limitation (MW)	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	110	110	110				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	22	22	22	86		Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	311	320	320				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	380	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	385	385	385				
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	97	37	60	60	173		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	210	170	220	220	165		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	300	262	300	300				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	0	30				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	25	8	25				
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	17	17	17				
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	29	38	38	38				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	32	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	49	25	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	20	88	70	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	150	150	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	125	45	145				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	15	115	50	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300				
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	40	80				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	40	100				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	90	35	54				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	15	35	17	35				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	1	34	8	40				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	33	9	33				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	79	65	85				
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	12	0	0				
Dhaka Zone Total			6104	5867	2355	2971	3167	3676	529	375			
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	105	100	100	75		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	40	40	40				
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	34	51				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
47	Sikalbaha 25 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	228	225	225				
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	82	290	85	300				
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	90	50	90				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	50	51				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	48	45	50				
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			16	40	10	20				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	10	0	16				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	35	17	17				
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	19	54	54	54				
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	90	70	90				
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	55	79	55	80				
58	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	31	34	34	34				
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	10	52	18	163				
**	SS Power Unit-1	Coal (IPP)				387	280	0	0				
Chattogram Zone Total			2605	2545	1150	1610	955	1441	280	330			
60	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	41	41	40	41				
61	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+17x5	221	221	207	209	200	210				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	340	270	300	330				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	350	280	300	330				
64	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0		400	Under maint.	
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	68	68				
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	30	12	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	37	40	40				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	16	16	16				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	16	8	16				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12				
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	37	100	114	114				
77	Chowmuhanj 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	96	27	95				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	17	35				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	115	35	115				
**	Impoort (Tipture)	India		160	160	98	130	129	152				
Cumilla Zone Total			2904	2896	1308	1499	1430	1836	0	563			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	49	101	100	100	101		Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	75	18	75				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	87	68	88				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutlakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0</						

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.05.23 (Yesterday)		27.05.23 (Today)		26.05.23 Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	39	40	40		51	GT-4 Under maint.
89	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	47	50	50	50			
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	80	112	112		54	ST Under maint.
91	Hobignaj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	55	59	60			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	84	84			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	202	202	200	210			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	17			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0			
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	388	368	400	400			
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	380	390	390	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	44	46	50	50			
Sylhet Zone Total												
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	320	200	200	200			
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	22	22	40			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	71	60	80			
108	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Kushtia 105 MW PP (Oron rupsha)	HFO (IPP)	8x18.445	105	105	0	0	17	17			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	78	85	105			
111	Mongla Oron 100 MW Solar PP	Solar (IPP)		100	100	99	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	27	32	98			
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	40	8	40			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	323	322	330	330			
**	Khulna 330 MW CAPP	Gas/HSD (BFPDB)				0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	903	909	921	921			
Khulna Zone Total												
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	28	22	30			
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	176	173	155	175			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	300	250	250			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	193	309	220	307			
121	Bhola 220MW CAPP (Nutan Bldyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.
Barishal Zone Total												
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage
b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	0		100	Under maint.
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	21	25	25			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	35	35			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	1	90	80	90			
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	40	40			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	42	42			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	35			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	150	147	150	150		63	Gas Shortage
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	99	132	150	150		88	Gas Shortage
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	358	345	350	350		69	Gas Shortage
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	20	21	22			
135	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	95	35	113			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	70	35	50			
139	Amritara 30 MW PP (Srinaha)	HFO (NENP)	7x7.79	50	28	0	0	21	21			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	439	749	748	748			
Rajshahi Zone Total												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	73	73	73		12	Coal Shortage
b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	180	200	200			Coal Shortage
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	0	100	35	100			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	110	50	115			
148	Lalmohat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0			
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	182	0	130	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PPI(LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Aspiganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired												
Gross Total												
(C) Actual data of 26.05.23 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	: 12600 MW, at = 19:30 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 12056 MW, at = 19:30 hrs										
03.	Highest Generation (Generation end)	: 12548 MW, at = 19:30 hrs										
04.	Minimum Generation (Generation end)	: 8035 MW, at = 7:00 hrs										
05.	Day-peak Generation (Generation end)	: 10284 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 12548 MW, at = 19:30 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 50 MW, at = 19:30 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9541 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas/LF limitation	: 1225 MW										
d)	Coal supply Limitation	: 12 MW										
b)	Low water level in Kaptai lake	: 205 MW										
c)	Plants under shut down/ maintenance	: 2235 MW										
10.	Total Energy (Generation + India Import)	: 243.19 MKWh										
	By Gas =	139.253 MKWh	By Oil =	29.490 MKWh								
	By Coal =	46.551 MKWh	By Hydro =	0.313 MKWh								
	By Solar=	3.255 MKWh										
11.	Total Gas Supplied	: 1112.70 MMCFD										
(D) Forecast of 27.05.23 (Today) Saturday :												
01.	Maximum Demand	: 13500 MW (Generation end)										
02.	Maximum Generation	: 13883 MW (Generation end)										
03.	Reserve / Shortage	: 383 MW (Generation end)										
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
	Dhaka	4374	4374	0	Mymensingh	1066	1016	50				
	Chattogram	1307	1307	0	Sylhet	524	524	0				
	Khulna	994	994	0	Barishal	409	409	0				
	Rajshahi	1242	1242	0	Rangpur	845	845	0				
	Cumilla	1295	1295	0					Total	12056	12006	50
13.	Fuel cost :	(a) Gas = 160628136 Taka	(c) Coal = 101428228 Taka									
		(b) Oil = 388247374 Taka	Total = 650303737 Taka									
14.	Maximum Temperature in Dhaka was :	35.6° C										
15.	Export through East-West interconnections :											
	At evening peak-hour	: 10284 MW, at 19:30 hrs										
	Maximum	: 580 MW, at 19:00 hrs										
	Energy	: 0 MKWh										
04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)										
05.	Total Generation	: 261.64 MKWh										
06.	Probable Max. Temperature in Dhaka :	36.6° C										

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation