

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 3564667, 3551095

Month May, 2023		Day: Monday				Date: 29.05.23						
Probable Maximum Demand :		14500 MW		Probable Maximum Generation :		14894 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 73.01 ft		Today = 72.95 ft		Rule Curve = 76.60 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	28.05.23 (Yesterday)		29.05.23 (Today)		Gen. shortfall/ r Limitation (MW)	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	22	86	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	334	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	407	398	400	400			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	97	99	100	100	111	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	210	209	210	210	126	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	312	303	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
15	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	8	16			
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	22	17	17			
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	42	46	42	42			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	5	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	30	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	48	8	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	87	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	133	64	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	49	282	50	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	131	17	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	84	85	300	300			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	50	80	80			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	95	50	100			
29	Nababganj 55 MW PP (Southern power )	HFO (IPP)	3x19.3	55	55	35	35	35	35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	72	17	54			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	17	8	16			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	11	8	32			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	68	76	65	85			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	11	0	12			
<b>Dhaka Zone Total</b>			<b>6104</b>	<b>5867</b>	<b>2928</b>	<b>3497</b>	<b>3179</b>	<b>3873</b>	<b>428</b>	<b>375</b>		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	7	39	18	40			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 25 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	225	225	225			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	87	278	87	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	90	50	90			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	67	51	68			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	48	64	50	64			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	32	4	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	16			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	90	38	90			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	45	79	45	80			
58	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	145	18	144			
**	SS Power Unit-1	Coal (IPP)				0	0	0	0			
<b>Chattogram Zone Total</b>			<b>2605</b>	<b>2545</b>	<b>786</b>	<b>1415</b>	<b>876</b>	<b>1453</b>	<b>285</b>	<b>330</b>		
60	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	41	40	43	43			
61	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+175	221	221	204	207	210	210			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	330	310	310	320			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	335	310	310	320			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0	400	Under maint.	
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	167	168	168	168			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	11	139	13	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	40	40	40			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	58	34	120			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	32	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	52	8	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	12	16	16			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	97	114	100	114			
77	Chowmuhanj 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	29	97	27	95			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	19	115	18	115			
**	Impoort (Tijpura)	India		160	160	170	166	129	152			
<b>Cumilla Zone Total</b>			<b>2904</b>	<b>2896</b>	<b>1604</b>	<b>1973</b>	<b>1572</b>	<b>2061</b>	<b>0</b>	<b>563</b>		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	43	94	45	90	108	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	18	18			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	76	18	75			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	69	88	68	88			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	37	0	50	0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	12	12	12			
<b>Mymensingh Zone Total</b>			<b>622</b>	<b>614</b>	<b>188</b>	<b>289</b>	<b>213</b>	<b>283</b>	<b>108</b>	<b>0</b>		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.05.23 (Yesterday)		29.05.23 (Today)		28.05.23 Gen. shortfall for :		Status of Machines under shut-down/ Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
					Day	Evening	Day	Evening							
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.			
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	38	40	40	40		50	GT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	45	50	50	50						
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.			
91	Hobignaj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	51	60	60						
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	84	84						
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	202	198	200	202						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	17	17						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16	9		Gas Shortage			
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	290	300	300						
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	392	404	400	400						
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	354	390	400	400						
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	49	0	50	50						
<b>Sylhet Zone Total</b>															
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	155	170	180	180	240		Gas Shortage			
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	24	22	40						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	10	88	60	80						
108	Khulina 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Kushia 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	0	55	17	55						
110	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105	105						
111	Mongla Oron 100 MW Solar PP	Solar (IPP)		100	100	101	0	100	0						
112	Khulina 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	30	62	32	98						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	8	24	8	40						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	320	326	330	330						
**	Khulina 330 MW CAPP	Gas/HSD (BPDB)				172	142	0	0						
**	Bheramara (HVDC)	India		1000	1000	913	913	926	926						
<b>Khulina Zone Total</b>															
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16						
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	31	22	30						
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	171	170	175	175						
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	622	350	622						
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150						
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	307						
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.			
<b>Barishal Zone Total</b>															
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	0		100	Under maint.			
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	21	25	25						
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	35	35						
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	40	74	80	90						
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	40	40						
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34						
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35						
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	161	160	160	49		Gas Shortage			
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	119	0	0	0	220		Gas Shortage			
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	125	149	150	150	71		Gas Shortage			
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	236	299	300	115			Gas Shortage			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	21	21	22						
135	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	38	50	35	50						
139	Amritara 30 MW PP (Srinia)	HFO (NENP)	7x7.79	50	28	0	28	28	28						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	6	6	6	6						
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	714	749	748	748						
<b>Rajshahi Zone Total</b>															
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	73	73	73	73	12		Coal Shortage			
b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250			Coal Shortage			
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	104	49	35	49						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	75	114	74	115						
148	Lalmohat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	23	0	30	0						
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	164	0	130	0						
<b>Rangpur Zone Total</b>															
<b>Sub-total: Plants in operation</b>															
<b>(B) Plants under long term maintenance/ contract expired</b>															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
152	Bosilia 108MW PPI(LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
153	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0						
<b>Sub-total: Plants under long term maintenance/ contract expired</b>															
<b>Gross Total</b>															
<b>(C) Actual data of 28.05.23 (Yesterday) Sunday :</b>															
01.	Max. Demand at eve. peak (Generation end)	:	14218	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	13577	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	14136	MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	9649	MW, at =	6:00 hrs	Dhaka	4755	4737	18	Mymensingh	1104	1079	25		
05.	Day-peak Generation (Generation end)	:	11786	MW, at =	12:00 hrs	Chattogram	1433	1433	0	Sylhet	570	570	0		
06.	Evening-peak Generation (Generation end)	:	14136	MW, at =	21:00 hrs	Khulina	1665	1665	0	Barishal	426	426	0		
07.	Evening Peak Load-shed (Sub-station end)	:	78	MW, at =	21:00 hrs	Rajshahi	1392	1367	25	Rangpur	871	871	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10960	MW, at =	5:00 hrs	Cumilla	1361	1351	10						
09.	Generation shortfall at evening peak due to :	:								Total	13577	13499	78		
a)	Gas/LF limitation	:	1391	MW						(a) Gas =	177519719	Taka	(c) Coal =	126384959	Taka
d)	Coal supply Limitation	:	12	MW						(b) Oil =	689938998	Taka	Total =	993843675	Taka
b)	Low water level in Kaptai lake	:	205	MW											
c)	Plants under shut down/ maintenance	:	2234	MW											
10.	Total Energy (Generation + India Import)	:	282.94	MKWh						14. Maximum Temperature in Dhaka was :	35° C				
	By Gas =	154.218	MKWh	By Oil =	52.441	MKWh				15. Export through East-West interconnections :					
	By Coal =	47.322	MKWh	By Hydro =	0.300	MKWh				At evening peak-hour	:	11786	MW, at	21:00 hrs	
	By Solar =	3.155	MKWh							Maximum	:	520	MW, at	22:00 hrs	
11.	Total Gas Supplied	:	1194.32	MMCFD						Energy	:	0	MKWh		
<b>(D) Forecast of 29.05.23 (Today) Monday :</b>															
01.	Maximum Demand	:	14500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14894	MW	(Generation end)	05.	Total Generation	:	290.23	MKWh					
03.	Reserve / Shortage	:	394	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35° C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation