

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2023				Day : Sunday				Date : 04.06.23				
Probable Maximum Demand :				Probable Maximum Generation :				Rule Curve =				
15700 MW				14696 MW				76.78 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday =				Today =				
72.58 ft.				72.51 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.06.23 (Yesterday)		04.06.23 (Today)		03.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	80	63	78	78	45		Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	60	60	0	60	45		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	321	322	330	330			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	398	403	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	189	191	200	200			
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	219	220	335		Gas Shortage
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	286	295	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	0	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	16			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	15	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	34	38	42	45			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	29	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	48	8	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	70	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	145	64	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	147	47	145			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	148	17	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	300	299	300	300			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	94	100	100			
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	18	54			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	17	25	16	24			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	17	24	8	25			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	70	80	80			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0			
Dhaka Zone Total				6104	5867	3047	3534	3305	3871	425	375	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
42	Racozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	44	6	44			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	65	17	51			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	223	223	225	225			
48	Anwara 300 MW PP (Uniled)	HFO (IPP)	17x17.076+3x8.04	300	300	70	262	69	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	90	38	90			
50	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	50	68	68	68			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	31	55	50	64			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	9	10	10			
*	Malancha, Cig EPZ (Uniled)	Gas	5x8.73+3x9.34			2	18	10	30			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	76	38	90			
57	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	44	66	44	66			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	34	17	34			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	163	18	163			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Cox's Bazar Wind PP	(Wind) (IPP)				2	0	0	0			
Chattogram Zone Total				2605	2545	850	1394	839	1456	285	330	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	35	38	40	40			
61	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1x75	221	221	203	142	200	200			
62	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	18	270	270	320			
63	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	305	285	310	320			
64	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0		400	Under maint.
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	167	150	190	185			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	110	6	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	42	45	40	46			
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	120	51	120			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	22	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	42	43	50			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	21	21			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	98	34	98			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	87	26	94			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	115	18	115			
**	Impoport (Tripura)	India		160	160	152	144	129	152			
Cumilla Zone Total				2904	2896	1177	1805	1517	2050	0	563	
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	70	98	45	100	104		Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	16	19	19			
82	Jamalpur 115 MW PP (Uniled)	HFO (IPP)	12x9.87	115	115	18	83	18	84			
83	Mymensingh 200 MW PP (Uniled)	HFO (IPP)	21x9.780	200	200	68	88	68	84			
84	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	50	0	0			
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	234	297	214	299	104	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.06.23 (Yesterday)		04.06.23 (Today)		03.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	38	40	40		52	GT-4 Under maint.
89	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	47	50	50	50			
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.
91	Hobignaj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	60	60	60			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	84	84			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	184	181	190	190			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	17			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	300	305			
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	340	398	400	400			
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	165	255	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	45	48	48	48			
Sylhet Zone Total												
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	160	160	200	200	250		Gas Shortage
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	15	22	22	35			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	25	77	60	80			
108	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Kushtia 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	0	0	0			
111	Mongla Oron 100 MW Solar PP	Solar (IPP)		100	100	99	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	62	83	83			
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	32	32	16	40			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	321	328	320	320			
**	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	909	813	924	924			
Khulna Zone Total												
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	16			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	30	38	23	35			
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	167	168	170	170			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	570	622	622	622			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150			
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.
Barishal Zone Total												
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage
b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	0		100	Under maint.
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	25	30			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	0	30			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	37	87	80	90			
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	23	37	40	40			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	35	35			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	178	172	160	160			
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	158	151	170	170	69		Gas Shortage
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	351	347	400	400	67		Gas Shortage
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	20	22	22			
135	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	43	43			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	57	35	57			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
139	Amritara 30 MW PP (Srinia)	HFO (NENP)	7x7.79	50	28	28	28	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	6	4	0	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	761	748	759	759			
Rajshahi Zone Total												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	72	72	0	70		13	Coal Shortage
b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230			Coal Shortage
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	16	15	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	49	35	55			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	8	0	0			
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	114	34	115			
148	Lalmohat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0			
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	182	0	130	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PPI(LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired												
Gross Total												
(C) Actual data of 03.06.23 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	: 1500 MW, at = 21:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 14689 MW, at = 21:00 hrs										
03.	Highest Generation (Generation end)	: 13635 MW, at = 21:00 hrs										
04.	Minimum Generation (Generation end)	: 11234 MW, at = 8:00 hrs										
05.	Day-peak Generation (Generation end)	: 11647 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 13635 MW, at = 21:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 1781 MW, at = 21:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11134 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :	:										
a)	Gas/LF limitation	: 1295 MW										
d)	Coal supply Limitation	: 13 MW										
b)	Low water level in Kaptai lake	: 205 MW										
c)	Plants under shut down/ maintenance	: 2236 MW										
10.	Total Energy (Generation + India Import)	: 289.14 MKWh										
	By Gas = 156.039 MKWh	By Oil = 56.182 MKWh										
	By Coal = 48.673 MKWh	By Hydro = 0.306 MKWh										
	By Solar= 3.021 MKWh											
11.	Total Gas Supplied	: 1209.20 MMCFD										
(D) Forecast of 04.06.23 (Today) Sunday :												
01.	Maximum Demand	: 15700 MW (Generation end)										
02.	Maximum Generation	: 14696 MW (Generation end)										
03.	Reserve / Shortage	: -1004 MW (Generation end)										
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
	Dhaka	5321	4981	340	Mymensingh	1193	1083	110				
	Chattogram	1432	1162	270	Sylhet	540	450	90				
	Khulna	1768	1477	291	Barishal	462	382	80				
	Rajshahi	1522	1322	200	Rangpur	988	848	140				
	Cumilla	1462	1202	260								
					Total	14689	12908	1781				
13.	Fuel cost :	(a) Gas = 183809737 Taka	(c) Coal = 136201791 Taka									
		(b) Oil = 793618067 Taka	Total = 1113629595 Taka									
14.	Maximum Temperature in Dhaka was :	37.1° C										
15.	Export through East-West interconnections :											
	At evening peak-hour	: 11647 MW, at 21:00 hrs										
	Maximum	: 576 MW, at 22:00 hrs										
	Energy	: 0 MKWh										
04.	Maximum Load-shed	: 949 MW At evening peak (Sub-station end)										
05.	Total Generation	: 332.93 MKWh										
06.	Probable Max. Temperature in Dhaka :	37.1° C										

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation