

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551085

Month June, 2023		Day : Tuesday			Date : 06.06.23							
Probable Maximum Demand :		15800 MW			Probable Maximum Generation : 14389 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 72.43 ft			Today = 72.35 ft							
					Rule Curve = 77.30 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.06.23 (Yesterday)		06.06.23 (Today)		05.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	119	130	130	61		Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	12	12	12	96		Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	40	40	40	40	65		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	332	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	402	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	190	191	200	200			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	208	210	210	210	125		Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	275	281	280	280			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	0	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	19	19			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	43	46	42	46			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	29	30	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	0	8	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	100	98	100	100			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	145	82	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	147	50	150			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	149	17	149			
26	Keraniganj 300 MW PP (ASR)	HSD (IPP)	25x12.4	300	300	55	253	300	300			
27	Birshanganj 100 MW PP (Agreko)	HSD (IPP)	23x8.85+9x1x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Agreko)	HSD (IPP)	23x8.85+9x1x.959	100	100	90	93	100	100			
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	17	54			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	16	25	16	25			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	17	24	8	25			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	94	99	99			
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	6x13.45	100	20	0	0	0	0			
Dhaka Zone Total			6104	5867	3032	3589	3333	3747	347	375		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	120	100	100	60		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	16	8	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	15	0	50	50			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	68	51	68			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	227	225	225			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	69	300	69	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	90	25	90			
50	Dohazari-Kalashah 100 MW Peaking	HFO (PDB)	6x17.0	102	102	48	51	51	51			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	59	25	60			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	7	9	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	25	2	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	74	54	74			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	88	25	90			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	44	33	33			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	68	17	68			
59	Mircharai 150 MW	HFO (BRPgen)	9x18.5	163	163	72	163	18	163			
	SS Power Unit-1	Coal (IPP)				315	290	290	290			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	0	0			
Chattogram Zone Total			2605	2545	1187	1734	1120	1759	265	330		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	33	38	40	40			
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	202	196	160	160			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	305	300	300			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	305	310	320			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	50	50	400		Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20x9.73+1x116	195	195	138	86	8	8	109		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	32	118	5	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	39	46	40	44			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	103	51	100			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	0	17	18			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	0	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	33	43	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	98	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	77	26	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	95	72	115			
**	Impoport (Tijpura)	India		160	160	148	140	129	152			
Cumilla Zone Total			2904	2896	1610	1771	1507	1869	509	163		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	95	32	100	107		Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	84	18	86			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	86			
84	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0			
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensing Zone Total			622	614	195	295	198	300	107	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.06.23 (Yesterday)		06.06.23 (Today)		05.06.23 Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)								
					Day	Evening	Day	Evening	Description/ Remarks						
87	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43	27	GT-1 & ST-1 Under maint.				
88	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	39	40	40	51	GT-4 Under maint.				
89	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	46	50	50	50						
90	Kushiara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5						
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	55	56	56						
93	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	73	75	76	76						
95	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	176	169	180	183						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	17	17						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16						
99	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	275	290	300	320						
100	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	367	404	400	400						
101	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	255	256	255	255						
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work				
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	45	47	48	48						
Sylhet Zone Total															
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCGP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	130	115	140	140	295	Gas Shortage				
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	17	26	22	30						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	17	70	60	70						
108	Khulina 225 MW CCGP	HSD/ Gas (NWP/CGCL)	1 x 150+1x75	230	230	175	225	120	200						
109	Rupsha 105 MW PP (Oron nupsha)	HFO (IPP)	6x18.445	105	105	17	36	17	34						
110	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	0	32	105						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	98	0	100	0						
112	Khulina 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	30	61	49	98						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	24	40						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	371	374	370	370						
**	Khulina 330 MW CCGP	Gas/HSD (PDB)		1000	1000	228	230	200	220						
**	Bheramara (HVDC)	India		1000	1000	908	815	930	930						
Khulina Zone Total															
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	64	48	64						
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	33	24	33						
117	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	166	170	170	170						
118	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	100	0	0	0	1244	Coal Shortage				
119	Potukhalhi 150MW PP (UPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150						
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	306	150	150						
121	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0	220	Under maint.				
Barishal Zone Total															
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage				
b) Baghabari 100 MW GTTP	Gas (PDB)		1 x 100	100	100	0	0	0	0	100	Under maint.				
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	28	28	28						
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	20	20	30	30						
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	35	90	0	90						
127	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	36	36						
128	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	25	34	43						
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	35	35						
130	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	160	155	160	160	55	Gas Shortage				
131	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/CGCL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage				
132	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	137	140	140	140	80	Gas Shortage				
133	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	228	262	280	280	152	Gas Shortage				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	14	20	22	22						
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	20	42						
137	Bazura 113 MW (Confidence) U-1	HFO (IPP)	6*18.65	113	113	35	55	35	55						
138	Bazura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.65	113	113	35	50	35	50						
139	Khmirra 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	21	28	21	28						
140	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	4	0	6	0						
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	759	748	750	750						
Rajshahi Zone Total															
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	5	72	72		Coal Shortage				
b) Barapukuria TPP Unit-2	Coal (PDB)		1 x 125	125	85	0	0	0	0	85	Under Overhauling				
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	240	240	240	240		Coal Shortage				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	16	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	56	35	55						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	9	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	114	115	115						
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0						
149	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	188	0	130	0						
Rangpur Zone Total															
Sub-total: Plants in operation															
(B) Plants under long term maintenance/ contract expired															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
152	Bosilia 108MW PP(LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
153	Aspugan 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired															
Gross Total															
(C) Actual data of 05.06.23 (Yesterday) Monday :															
01.	Max. Demand at eve. peak (Generation end)	:	15700	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):									
02.	Max. Demand at eve. peak (Sub-station end)	:	14826	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	:	13859	MW, at =	21:00 hrs	Dhaka	5389	5099	290	Mymensingh	1256	1140	116		
04.	Minimum Generation (Generation end)	:	11221	MW, at =	6:00 hrs	Chattogram	1372	1106	266	Sylhet	624	528	96		
05.	Day-peak Generation (Generation end)	:	12099	MW, at =	12:00 hrs	Khulina	1775	1430	345	Barishal	506	440	66		
06.	Evening-peak Generation (Generation end)	:	13859	MW, at =	21:00 hrs	Rajshahi	1546	1348	198	Rangpur	943	807	136		
07.	Evening Peak Load-shed (Sub-station end)	:	1758	MW, at =	21:00 hrs	Cumilla	1415	1170	245						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11293	MW, at =	5:00 hrs					Total	14826	13068	1758		
09.	Generation shortfall at evening peak due to :	:								(a) Gas =	17677765	Taka	(c) Coal =	68724244	Taka
a) Gas/LF limitation	:		3140	MW						(b) Oil =	847389486	Taka	Total =	1092891496	Taka
b) Coal supply Limitation	:		0	MW											
c) Low water level in Kaptai lake	:		205	MW											
d) Plants under shut down/ maintenance	:		1835	MW											
10.	Total Energy (Generation + India Import)	:	291.46	MKWh						14. Maximum Temperature in Dhaka was :	38.6° C				
	By Gas =	151.459	MKWh	By Oil =	63.104	MKWh				15. Export through East-West interconnections :					
	By Coal =	48.534	MKWh	By Hydro =	0.318	MKWh				At evening peak-hour	:	12099	MW, at	21:00 hrs	
	By Solar =	3.074	MKWh							Maximum	:	600	MW, at	20:00 hrs	
11.	Total Gas Supplied	:	1223.34	MMCFD						Energy	:	0	MKWh		
(D) Forecast of 06.06.23 (Today) Tuesday :															
01.	Maximum Demand	:	15800	MW	(Generation end)	04.	Maximum Load-shed	:	1335	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14389	MW	(Generation end)	05.	Total Generation	:	332.28	MKWh					
03.	Reserve / Shortage	:	-1411	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	37.6° C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation