

POWER GRID COMPANY OF BANGLADESH LTD.										Revised	
NATIONAL LOAD DESPATCH CENTER										QF-LDC-08	
DAILY REPORT										Page -1	
Till now the maximum generation is : -										12893 MW	
The Summary of Yesterday's										4-Nov-19	
Generation & Demand										21:00 Hrs on 29-May-19	
Today's Actual Min Gen. & Probable Gen. & Demand										Reporting Date : 5-Nov-19	
Day Peak Generation : 8494.5 MW										Min. Gen. at 5:00 6776 MW	
Evening Peak Generation : 10249.0 MW										Available Max Generation : 14440 MW	
E.P. Demand (at gen end) : 10249.0 MW										Max Demand (Evening) : 10500 MW	
Maximum Generation : 10249.0 MW										Reserve(Generation end) 3940 MW	
Total Gen. (MKWH) : 199.6										Load Shed : 0 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum -86 MW at 20:00 Energy MKWHR.											
Import from West grid to East grid :- Maximum - MW at - Energy - MKWHR.											
Water Level of Kaptai Lake at 6:00 A.M on 5-Nov-19											
Actual : 101.68 Ft.(MSL) , Rule curve : 108.60 Ft.(MSL)											
Gas Consumed : Total = 1141.71 MMCFD.										Oil Consumed (PDB) :	
										HSD : Liter	
										FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) :											
Gas : Tk136,546,092											
Coal : Tk38,897,229										Oil : Tk209,437,875	
										Total : Tk384,881,196	
Load Shedding & Other Information											
Area Yesterday Estimated Demand (S/S end) Today Estimated Shedding (S/S end) Rates of Shedding (On Estimated Demand)											
MW MW MW MW											
Dhaka 0 0:00 3727 0 0%											
Chittagong Area 0 0:00 1266 0 0%											
Khulna Area 0 0:00 1134 0 0%											
Rajshahi Area 0 0:00 1024 0 0%											
) 0 0:00 926 0 0%											
Mymensingh Area 0 0:00 747 0 0%											
Sylhet Area 0 0:00 420 0 0%											
Barisal Area 0 0:00 192 0 0%											
Rangpur Area 0 0:00 576 0 0%											
Total 0 10013 0											
Information of the Generating Units under shut down.											
Planned Shut- Down Forced Shut-Down											
1) Barapukuria ST: Unit-1.											
2) Sylhet-150 MW.											
3) Ghorasal Unit-1,3 & 5											
4) Sirajganj 225 MW Unit-2											
5) Raozan #2											
6) Ashuganj unit-4 & 5											
7) Chandpur CCPP ST											
8) Sylhet 150 MW											
9) Fenchuganj # 03 & 04											
Additional Information of Machines, lines, Interruption / Forced Load shed etc.											
Description Comments on Power Interruption											
a) Hathazari-Baroierhat 132 kV Ckt-1 was under shut down from 08:04 to 15:36 for A/M.											
b) Aminbazar-Hasnabad 230 kV Ckt-2 was under shut down from 09:24 to 16:46 for A/M.											
c) Mirpur-Uttara 132 kV Ckt-1 was under shut down from 09:22 to 17:48 for A/M.											
d) Halishahar-Khulshi 132 kV Ckt-1 was under shut down from 09:09 to 14:19 for A/M.											
e) Kishorganj-Mymensingh 132 kV Ckt-2 was under shut down from 09:13 to 16:09 for A/M.											
f) Jamalpur-UMPL 132 kV Ckt-1 was under shut down from 08:44 to 16:02 for A/M.											
g) Sherpur-UMPL 132 kV Ckt-1 was under shut down from 08:15 to 16:05 for A/M.											
h) Sremangal 132/33 kV T-2 transformer was under shut down from 09:15 to 12:08 for Delta test.											
i) Magura 132/33 kV T-1 transformer was under shut down from 08:07 to 15:51 for A/M.											
j) Khulna central 132/33 kV T-2 transformer was under shut down from 08:20 to 16:12 for A/M.											
k) Khulna (s) 230/132 kV T-1 transformer was under shut down from 09:02 to 13:36 for A/M.											
l) Barisal 230/132 kV T-2 transformer was under shut down from 08:42 to 16:36 for A/M.											
m) Bheramara HVDC shunt reactor 10CF at 400 kV side was under shut down from 10:03 to 16:10 for A/M.											
n) Siddhirganj 230/132 kV MTR-2 transformer was under shut down from 08:29 to 15:02 for A/M.											
o) Hasnabad 230/132 kV TR-2 transformer (132 kV side) was under shut down from 10:30 to 12:55 for C/M.											
p) Ruppur 132/11 kV T-2 transformer tripped at 08:05 showing S7N.											
q) Sikalbaha 225 MW CCPP was force shut down at 13:12 for CW pump problem.											
r) Haripur-Bhulta 230 kV Ckt-1 was under shut down from 08:45 to 17:30 for A/M.											
s) Dhamrai-Kaliakoir 132 kV Ckt-1 was shut down at 09:21 for A/M.											
t) Bibiyana-3 was synchronized at 20:23.											
u) Barishal(n) 132/33 kV T-5 transformer tripped at 17:28 showing PRD at 132 kV side.											
v) Cumilla(n)-Meghnaghat 230 kV Ckt-1 was shut down at 07:32 for A/M.											
Sub Divisional Engineer Executive Engineer Superintendent Engineer											
Network Operation Division Network Operation Division Load Despatch Circle											