

Date : 11-Nov-19							Page 2	
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks	
			Unit No. X Capacity	MW	MW	MW		
1	Ghorasal TPP (Unit-1&2)	PDB	2 ⁵⁵	85	35	840000	#1 Under maint.	
	Ghorasal Repowered CCPP Unit-3	PDB	1 ²¹⁰	170	0	0	Under maint.	
	Ghorasal Repowered CCPP Unit-4	PDB	1 ²¹⁰	180	0	1225000	under maint.	
	Ghorasal TPP Unit-5	PDB	1 ²¹⁰	190	0	0	Under maint.	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1 ^{243+1¹²²}	365	330	7178855		
3	Ghorashal 78.5 MW PP(MAX)	QRPP	2 ⁴⁰	78	0	0	Gas shortage.	
4	Ghorashal 108MW PP (Regent)	IPP	4 ^{34.35}	108	0	0	Gas shortage.	
5	Haripur GTPP	SBU, PDB	2 ³²	40	0	0	Under maint.	
6	Haripur 412 MW CCPP	EGCB	1 ^{273+1¹³⁹}	412	344	8311810	FGMO	
7	Haripur 360MW CCPP(HPL)	IPP	1 ^{235+1¹²⁵}	360	303	8657000		
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2 ^{150+1¹⁵⁰}	450	350	8222875	frequency control.	
9	Meghnaghat 100 MW (IEL)	QRPP	12 ^{8.9}	100	0	0	Reserve	
10	Meghnaghat CCPP(Summit)	IPP	2 ^{110+1¹¹⁰}	305	0	0	Reserve	
11	Madanganj 102 PP(Summit)	QRPP	6 ¹⁷	102	0	0	Reserve	
12	Madanganj-55 MW PP(Summit)	(IPP)	3 ^{17.08+1^{11.3}}	55	15	59177	Low demand.	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8 ^{13.45}	100	0	0	Reserve	
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8 ^{2.90}	22	22	249120		
15	210 MW Siddhirgonj TPP	PDB	1 ²¹⁰	115	0	0	Reserve	
16	Siddhirgonj 2 ¹²⁰ MW GTPP	EGCB	2 ¹⁰⁵	210	118	2024000	Gas shortage.	
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12 ^{8.9}	100	0	0	Reserve	
18	Siddhirgonj 335 MW CCPP	EGCB	1 ²¹⁷⁺¹¹⁸	335	0	610337	Gas shortage.	
19	Gagnagar 102 MW PP (Digital Power)	IPP	12 ^{8.924}	102	0	0	Reserve	
20	Katpotti 52 MW PP (Sinha)	IPP	7 ^{7.9}	51	48	217296		
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3 ¹⁸	54	17	44280	Low demand.	
22	Kodda 150MW PP	BPDB-RPCL	9 ^{17.06}	149	0	0	Reserve	
23	Manikganj 55 MW PP (Northern)	IPP	3 ^{19.3}	55	35	246474	Low demand.	
24	Nababganj 55 MW PP (Southern power	IPP	3 ^{19.3}	55	35	138427	Low demand.	
25	Bosila 108MW PP(CLC)	IPP	12 ^{8.775+1^{3.5}}	108	54	350400	Low demand.	
26	Summit Power,(Madhabdi+Ashulia)	SIPP,REB	3 ^{3.67+4^{8.73}}	80	53	1082400	Engine problem	
27	Maona 33 MW PP(Summit)	SIPP,REB	4 ^{8.73}	33	28	677700		
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4 ^{8.73}	33	33	802500		
29	Gazipur 52 MW PP	IPP	6 ^{8.9}	52	0	0	Reserve	
30	Tongi 80 MW GTPP	PDB	1 ¹⁰⁵	105	0	0	Reserve	
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18 ^{17.076}	300	200	740181	Low demand.	
32	Keraniganj 300 MW PP (APR)	IPP	256 ^{1.4}	300	0	0	Reserve	
33	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve	
34	Aurahati 100MW PP (Aggreko)	IPP	0.85 ^{23+0.95⁹¹}	100	0	0	Reserve	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	16	424800	Low demand.	
36	Gazipur 100 MW PP	RPCL	100 MW	105	90	1073076		
Dhaka area Total				5811	2126	43175708		
37	Chattogram TPP-1	PDB	1 ²¹⁰	180	110	2500000		
38	Chattogram TPP-2	PDB	1 ²¹⁰	180	0	0		
39	Raozan 25 MW PP	IPP	3 ^{8.9}	25	0	0	Reserve	
40	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	81540		
41	Patenga 50MW PP (Baraka)	IPP	8 ^{6.98}	50	22	84960	Low demand.	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2 ^{40+3⁵⁰}	230	78	1743400	Low water level	
43	Sikalbaha 225MW	PDB	1 ^{150+1¹⁷⁵}	225	0	0	Under maint.	
44	Sikalbaha Peaking GT	PDB	1 ¹⁵⁰	150	149	3272922	FGMO	
45	Sikalbaha 105 MW PP (Baraka Sikalba	IPP	105 MW	105	105	1646792		
46	Hathazari 100 MW peaking PP	PDB	11 ^{8.9}	98	0	0	Under S/D.	
47	Dohazari -Kalaish 100 MW Peaking	PDB	6 ¹⁷	102	51	143488	Low demand.	
48	Juldah 100 MW Unit-1 (Acom)	QRPP	8 ^{13.45}	100	100	1359720		
49	Juldah 100 MW PP Unit-3 (Acom)	IPP	0	100	50	272640	Low demand.	
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8 ^{2.90}	22	16	279312		
*	Malancha, Ctg. EPZ (United)		5 ^{8.73+3^{9.34}}	0	5	296160		
50	Chattogram 108 MW PP (ECPV)	IPP	16 ⁷	108	97	1065600		
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	16920		
52	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	Reserve	
53	Jodiak Power	IPP	3 ^{18.55+1^{3.6}}	54	17	36093	Low demand.	
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve	
Chattogram area Total				2166	800	12798547		
55	Ashuganj TPP Unit- 3	APSCL	1 ¹⁵⁰	135	80	1848682		
	Ashuganj TPP Unit- 4	APSCL	1 ¹⁵⁰	129	0	0		
	Ashuganj TPP Unit- 5	APSCL	1 ¹⁵⁰	134	0	0		
56	Ashuganj 225 MW CCPP	APSCL	1 ^{142+1¹⁷⁵}	221	180	4313000	FGMO	
57	Ashuganj 450 MW CCPP(North)	APSCL	1 ³⁶⁰	360	340	7017900	FGMO	
58	Ashuganj 450 MW CCPP(South)	APSCL	1 ³⁶⁰	360	270	6470000	FGMO	
59	Ashuganj 50 MW PP	APSCL	14 ^{3.968}	45	37	524592	Engine problem	
60	Ashuganj 55 MW PP (Precision)	RPP	15 ⁴	55	52	791520		
	Ashuganj 53MW PP (United)	QRPP	14 ⁴	53	0	0	Contract Expired	
62	Ashuganj 195MW PP (APSCL-United)	IPP	20 ^{9.73+1¹⁶}	195	8	217454	Low demand	
63	Ashuganj 51 MW PP (Midland)	IPP	6 ^{9.34}	51	35	525848	Engine problem	
64	Ashuganj 150MW PP (Midland)	IPP	23 ^{7.015}	150	70	145527	Low demand	
	B.Barai (Aggreko) 85MW	QRPP	86 ^{1.10}	85	0	0	Contract Expired	
66	Titas 50 MW Peaking PP	PDB	6 ^{8.92}	52	0	0	Reserve	
67	Chandpur 150 MW CCPP	PDB	1 ^{106+1⁵⁷}	163	81	1783520	Low demand	
68	Chandpur 200MW (Desh energy)	IPP	0	200	50	131520	Low demand	
69	Feni 22MW PP (Doreen)	SIPP, PDB	8 ^{2.90}	22	22	293364		
70	Feni 11 MW PP (Doreen)	SIPP, REB	4 ^{2.90}	11	11	112140		
**	Impoprt (Tripura)	Imported power	0	160	124	2160000		
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4 ^{8.73}	33	33	404600		
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6 ^{8.92}	52	0	0	Reserve	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3 ^{3.67+2^{6.97}}	25	18	258350		
74	Daudkandi 200 MW PP (B.Trac)	IPP	154 ^{1.4}	200	0	0	Reserve	
Cumilla Area Total				2891	1411	26998017		
75	RPCL 210MW CCPP	IPP	4 ^{35+1⁷⁰}	202	156	3645120		
76	Tangali 22 MW PP (Doreen)	SIPP, PDB	8 ^{2.90}	22	0	122760	Engine problem	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12 ^{8.924}	95	16	79680	Low demand	
78	Sarishabari 3 MW Solar Plant	IPP	1 ³	3	0	14200		
79	Mymensingh 200 MW PP (United)	IPP	200	200	160	1699200	Low demand	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	0	0	Reserve	
Mymensingh Area Total				637	332	5560960		
81	Fenchugonj CCPP Phase-1	PDB	2 ^{32+1³³}	70	58	1117000		
82	Fenchugonj CCPP Phase-2	PDB	2 ^{35+1³⁵}	90	0	0	Under maint.	
83	Kushiaira 163 MW CCPP (KP)	IPP	1 ^{109+1⁵⁴}	163	130	2907674	Low demand	
84	Shahbazar 330 MW CCPP	PDB	3 ¹¹⁰	330	238	4916800	frequency control.	
85	Fenchugonj 51 MW PP (Barakatullah)	RPP	18 ^{2.90}	51	53	574200		
86	Fenchugonj 44MW (Energyprima)	RPP	12 ^{3.3+5²}	44	49	73584		
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4 ^{2.90}	11	11	134096		
88	Shahjibazar GTTP Unit- 8 & 9	PDB	2 ³⁵	66	68	1280928	FGMO	
89	Shahjibazar 86MW PP (Shahjibazar)	RPP	32 ^{2.90}	86	76	899520	Engine problem	
90	Shahjibazar 50MW PP (EPL)	RPP	27 ^{2.0}	50	40	655200	Engine problem	
91	Sylhet 150 MW CCPP	PDB	1 ¹⁴²	142	0	0	Under shut down.	
92	Sylhet 20 MW GTTP	PDB	1 ²⁰	20	18	255000		
93	Sylhet 50MW PP (EPL)	RPP	27 ²	50	38	500760	Engine problem	
94	Shahjahanulla 25 MW PP	SIPP, REB	3 ^{9.34}	25	24	327504		
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1 ^{222+1¹¹⁹}	341	285	7310000	FGMO	
96	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	341	6166000		
97	Sylhet 10MW PP (Desh)	RPP	6 ^{1.95}	10	0	0	Reserve	
Sylhet Area Total				1949	1429	27117766		
98	Bheramara GTTP Unit-1,2 & 3	PDB	3 ²⁰	46	0	0	Reserve	
**	Bheramara (HVDC)	Imported power	2 ⁵⁰⁰	1000	778	12806545	Low demand	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7 ¹⁷	115	16	37440	Reserve	
100	Faridpur 50 MW Peaking PP	PDB	8 ^{6.89}	54	0	5280	Reserve	
101	Khulna 225 MW CCPP	NWPGCL	1 ^{150+1¹⁷⁵}	230	0	0	Reserve	
102	Gopalganj 100 MW Peaking PP	PDB	16 ^{6.98}	109	0	0	Reserve	
103	Bheramara 360 MW CCPP	NWPGCL	1 ^{278+1¹³²}	410	310	7354080	Low demand	
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5 ^{8.5}	40	40	174000		
105	Noapara 100 MW PP (Bangla Trac)	IPP	70 ^{1.4}	100	0	0	Reserve	
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6 ^{18.445}	105	17	131040	Low demand.	
107	Madhumati 100 MW PP	IPP	100 MW	105	48	120960	Low demand	
Khulna Area Total				2314	1209	20628345		
108	Barisal 110 MW PP (Summit)	IPP	7 ^{17.076}	110	0	137280	Reserve	
109	Barisal GT PP Unit-1& 2	PDB	2 ²⁰	30	0	0	Reserve	
110	Bhola 33 MW PP (Venture)	RPP	1 ^{34.50}	33	18	272300	Low demand	
111	Bhola 225 MW CCPP	PDB	2 ^{63+1⁶⁸}	194	81	676000	ST under maint.	
112	Bhola 95 MW PP (Aggreko)	QRPP	96 ^{1.10}	95	22	210880	Low demand	
Barisal Area Total				462	121	1296460		
113	Baghabari 71 MW GTTP	PDB	1 ⁷¹	71	60	1305000		
114	Baghabari 100 MW GTTP	PDB	1 ¹⁰⁰	100	0	0		
115	Baghabari 50 MW Peaking PP	PDB	6 ^{8.9}	52	0	0	Reserve	
116	Bera 70 MW Peaking PP	PDB	9 ^{8.29}	71	0	0	Reserve	
116	Amnura 50 MW PP(Sinha)	QRPP	7 ^{7.79}	50	50	642710		
117	Katakhal 50 MW PP (Northern)	QRPP	6 ^{8.9}	50	0	0	Reserve	
118	Katakhal>							