

Reporting Date : 26-Dec-19

Today's Actual Min Gen. & Probable Gen. & Demand

Min. Gen. at	4:00	4984 MW
--------------	------	---------

Min. Gen. at	4.00	4984 MW
Available Max Generation		14709 MW

Available Max Generation	14709 MW
Max Demand (Evening) :	8600 MW

Max Demand (Evening) :	8888 MW
Reserve(Generation end)	6109 MW

Reserve(Generation end)	6169 MW
Load Shed :	0 MW

Load Case		0 MW
3		

Time	Energy	MKWH
21:00		

21.00	Energy	MKWH
-	Energy	- MKWH

Energy	Micro
--------	-------

 $F_t(\text{MSL})$

	HSD	Liter
1	0.05	0.05
2	0.05	0.05
3	0.05	0.05
4	0.05	0.05
5	0.05	0.05
6	0.05	0.05
7	0.05	0.05
8	0.05	0.05
9	0.05	0.05
10	0.05	0.05
11	0.05	0.05
12	0.05	0.05
13	0.05	0.05
14	0.05	0.05
15	0.05	0.05
16	0.05	0.05
17	0.05	0.05
18	0.05	0.05
19	0.05	0.05
20	0.05	0.05
21	0.05	0.05
22	0.05	0.05
23	0.05	0.05
24	0.05	0.05
25	0.05	0.05
26	0.05	0.05
27	0.05	0.05
28	0.05	0.05
29	0.05	0.05
30	0.05	0.05
31	0.05	0.05
32	0.05	0.05
33	0.05	0.05
34	0.05	0.05
35	0.05	0.05
36	0.05	0.05
37	0.05	0.05
38	0.05	0.05
39	0.05	0.05
40	0.05	0.05
41	0.05	0.05
42	0.05	0.05
43	0.05	0.05
44	0.05	0.05
45	0.05	0.05
46	0.05	0.05
47	0.05	0.05
48	0.05	0.05
49	0.05	0.05
50	0.05	0.05
51	0.05	0.05
52	0.05	0.05
53	0.05	0.05
54	0.05	0.05
55	0.05	0.05
56	0.05	0.05
57	0.05	0.05
58	0.05	0.05
59	0.05	0.05
60	0.05	0.05
61	0.05	0.05
62	0.05	0.05
63	0.05	0.05
64	0.05	0.05
65	0.05	0.05
66	0.05	0.05
67	0.05	0.05
68	0.05	0.05
69	0.05	0.05
70	0.05	0.05
71	0.05	0.05
72	0.05	0.05
73	0.05	0.05
74	0.05	0.05
75	0.05	0.05
76	0.05	0.05
77	0.05	0.05
78	0.05	0.05
79	0.05	0.05
80	0.05	0.05
81	0.05	0.05
82	0.05	0.05
83	0.05	0.05
84	0.05	0.05
85	0.05	0.05
86	0.05	0.05
87	0.05	0.05
88	0.05	0.05
89	0.05	0.05
90	0.05	0.05
91	0.05	0.05
92	0.05	0.05
93	0.05	0.05
94	0.05	0.05
95	0.05	0.05
96	0.05	0.05
97	0.05	0.05
98	0.05	0.05
99	0.05	0.05
100	0.05	0.05

HSD	:	liter
EO	:	liter

FO	Filter
----	--------

Total : Tk199 985 374

Area	Yesterday		Today		
	MW	Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding (On Estimated Demand)	
Dhaka	0	0:00	3002	0	0%
Chittagong Area	0	0:00	1014	0	0%
Khulna Area	0	0:00	907	0	0%
Rajshahi Area	0	0:00	819	0	0%
)	0	0:00	741	0	0%
Mymensingh Area	0	0:00	598	0	0%
Sylhet Area	0	0:00	343	0	0%
Barisal Area	0	0:00	154	0	0%
Rangpur Area	0	0:00	461	0	0%
Total	0		8040	0	

Planned Shut- Down	Forced Shut- Down
	1) Barapukuria 10) Baghabari 100 MW
	2) Summit Meg 11) Sirajganj unit-2
	3) Ghorasal Unit-1,3,5
	4) Chandpur CCPP ST
	5) Sylhet 150 MW
	6) Bhola-225 MW GT-2 & ST
	7) Ashuganj Precision
	8) Ashuganj 225 MW CCPP
	9) Ashuganj unit-4,5

Description	Comments on Power Interruption
a) Kodda 132/33 kV T-2 transformer was under shut down from 09:23 to 16:37 for A/M.	
b) Hathazari-AKSML 230 kV Ckt was under shut down from 08:25 to 17:33 for A/M.	
c) Rampura 230/132 kV Tx-2 transformer was under shut down from 08:45 to 16:05 for A/M.	
d) Cantonment S/S 132/33 kV T-2 transformer was under shut down from 08:04 to 14:27 for D/W.	
e) Dhamrai-Kaliakoir 132 kV Ckt-1 was under shut down from 09:44 to 11:38 for Relay protection test.	
f) Dhamrai-Kaliakoir 132 kV Ckt-2 was under shut down from 11:40 to 14:07 for Relay protection test.	
g) Niamatpur 132/33 kV T-3 transformer was under shut down from 08:22 to 16:48 for A/M.	
h) Jaldhaka 132/33 kV T-2 transformer was under shut down from 10:48 to 14:25 for D/W.	About 10 MW power interruption occurred under Jaldhaka S/S from 10:48 to 14:25.
i) Faridpur-Gopalganj-Madaripur 132 kV both Ckts were under shut down from 10:03 to 17:13 for OPGW work.	
j) Tangail-RPCL(Mymensingh) 132 kV 132 kV Ckt was under shut down from 10:45 to 16:50 for A/M.	
k) Barapukuria 132/33 kV T-5 transformer was under shut down from 10:14 to 12:22 for R/H maintenance.	
l) Hathazari 230/132 kV MT-1 transformer was switched on at 11:13.	
m) Summit Bibiyana forced shut down at 14:14 and GT synchronized at 16:10 & STG synchronized at 18:34.	
n) Gallamari 132/33 kV T-1 & T-2 transformer were under shut down from 15:43 to 16:01 for 33 kV side tripped showing O/C relay.	About 20 MW power interruption occurred under Gallamari S/S from 15:43 to 16:01.
o) GPH-Hathazari 230 kV Ckt tripped at 20:57 from both ends showing Z-1 relay at B-phase from GPH end and general trip, distance relay at B-phase from Hathazari end and was switched on at 21:17.	
p) Hathazari-Raozan 230 kV Ckt-2 tripped at 20:57 from Hathazari end and was switched on at 21:22.	
q) Baghabari 71 MW was shut down at 15:10 due to Gas shortage.	
r) Shahjibazar 132/33 kV T-2 transformer was shut down at 07:09(26/12/2019) for A/M.	
s) Faridpur-Gopalganj 132 kV new Ckt-1 & 2 were shut down at 07:28(26/12/2019) for D/W.	
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle