



Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9584667, 9551095

Month February, 2020				Day : Saturday				Date : 15.02.20					
Probable Maximum Demand : 9200 MW				Probable Maximum Generation : 14541 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 92.20 ft				Today = 92.08 ft					
				Rule Curve = 95.04 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.02.20 (Yesterday)		15.02.20 (Today)		14.02.20 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	70	72	72	72				
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.	20/02/2020	
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	16/02/2020	
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.	30/03/2020	
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	300	300	300				
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	109	110	108	108				
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	76	78	60	78				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTPP	Gas (PDB)	2 x 32	64	40	0	0	0	0	40	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	333	350	360	360				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	330	400	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	350	344	412	412				
11	Siddhirganj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage		
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	26	100	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	120	150	150	150				
15	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	100	0	84	100	100				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	0	100	100				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
19	Gagnagar 102 MW PP Digital Pow	HFO (IPP)	12x8.924	102	102	0	102	100	102				
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	10	22	22				
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	33	49	57	57				
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	20	33	33				
23	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	25	33	33				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	100	100				
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	149	149				
27	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50				
28	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	53	53	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	200	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	16	100	149	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300				
32	Bramhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100				
33	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100				
34	Nababganj 55 MW PP (Southern pc)	HFO (IPP)	3x19.3	55	55	0	0	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	55	55				
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	71	71				
Dhaka Zone Total				6047	5811	1768	2382	3547	4167	690	655		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	120	120	120				
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4.25	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25				
41	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	17	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50				
43	Sikalbaha 105 MW PP (Baraka Sik)	HFO (IPP)	6x18.415	105	105	0	0	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	102	139	145	145				
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	215	229	225	225				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	140	230	300				
47	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	0	30	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	80	100				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	21	21				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			29	42	36	36				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	100	100				
53	Sikalbaha 54 MW Power Plant(Jodiari Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	50	110				
Chattogram Zone Total				2226	2166	456.25	851	1526	1651	340	0		
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	100	135	135	135				
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	39	39	43	43				
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1'75	221	221	168	168	120	120				
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	300	325	360	360				
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	345	325	360	360				
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5				
61	Ashuganj 195MW PP (APSCCL)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8				
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	25	100	150				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	8	0	50				
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	70	90	90				
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	0	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	50				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	20	21	21				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x1.4+40x1.515+15x1.05	200	200	0	0	0	200				
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	114				
74	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	0	0	113	113				
**	Impoort (Tripura)	India		160	160	60	102	92	110				
Cumilla Zone Total				3040	2980	1238	1339	1556	2238	264	0		
75	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	93	105	100	120				
76	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
77	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	48	95	95	95				
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	99	115	115	115				
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	105	50	100	200				
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	1.6	0	1.6	0				
Mymensingh Zone Total				645	637	368.6	387	433.6	552	0	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.02.20 (Yesterday)		15.02.20 (Today)		14.02.20 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
81	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	64	63	85	85				
82	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	50	50	66	66				
83	Fenchugonj 51 MW PP (Barakatull)	Gas (RPP)	19x2.90	51	51	51	51	51	51				
84	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	30	30	50	50				
85	Kushlari 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	100	100	130	130				
86	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	5	11	11	11				
87	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	67	66	66				
88	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+2x110	330	330	161	151	150	150				
89	Shahjibazar 86MW PP (Shahjibaza	Gas (RPP)	32x2.90	86	86	30	78	82	82				
90	Sylhet 150 MW CCGP	Gas (PDB)	1x142	142	142	0	47	100	120				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	17	17	17				
92	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0				
93	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
94	Shahjahanulla 25 MW PP	Gas (CIIP, REB)	3x9.34	25	25	24	24	24	24				
95	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	300	341	341				
96	Bibiyan-II 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	145	145	145	145				
Sylhet Zone Total				1944	1899	1029	1144	1328	1348	0	0		
97	Bheramara GTPP Unit-1,2 & 3	HSD (PDB)	3 x 20	60	46	0	0	0	40				
98	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	300	300				
99	Fardipur 30 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	36				
100	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	30	70				
101	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	225				
102	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	32	115	115	115				
103	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	100				
104	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	33	33				
105	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	50	105				
106	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	105				
**	Bheramara (HVDC)	India		1000	1000	175	424	529	775				
Khulna Zone Total				2328	2314	207	539	1107	1904	0	0		
107	Barisal GT PP Unit-1& 2	HSD (PDB)	2 x 20	40	30	0	0	0	30				
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	70	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	12	20	20	21				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	85	97	85	100				
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	92	95	95				
Payra 1320 MW						299	301	300	300				
Barishal Zone Total				472	462	396	510	570	656	0	0		
112	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
113	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	0	50				
114	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
115	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	45				
116	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	24	50	50	50				
117	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	26	80	102				
118	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40				
119	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	40	40				
120	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38				
121	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
122	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
123	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	225	225				
124	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	385	425	410	410				
125	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
126	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	2	10	5	5				
127	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	8	11	11	11				
128	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
129	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	109	109	113	113				
130	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	0	0	113				
Rajshahi Zone Total				2193	2183	548	677	1248	1516	601	0		
131	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	94	90	92	92				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Shutdown for Low Demand	
132	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	198	280	270	270				
133	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	17				
134	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	40	114	113	113				
135	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	17				
136	Majpara, Tatula 8 MW Solar PP (Sympa	Solar (IPP)	1 x 8	8	8	0	0	8	0				
Rangpur Zone Total				685	605	332	484	483	509	0	85		
Sub-total: Plants in operation				19580	19057	6342.9	8313	11799	14541	1895	740		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						5923	7470	11018	13579				
(B) Contract expired power plants													
137	Shahjibazar 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract expired	
Sub-Total: Plants under long term maintenance				50	50	0	0	0	0				
Gross Total				19630	19107	6342.9	8313	11799	14541	1895	740		
(C) Actual data of 14.02.20 (Yesterday) Friday :													
01.	Max. Demand (Generation end)	:	8313.00	MW,	at =	20:00 hrs P	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand (Sub-station end)	:	7470.00	MW,	at =	20:00 hrs P	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	8313.00	MW,	at =	20:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	5702.00	MW,	at =	5:00 hrs	Dhaka	2475	2475	0	Mymensingh	709	709
05.	Day-peak Generation (Generation end)	:	6342.85	MW,	at =	12:00 hrs	Chattogram	857	857	0	Sylhet	308	308
06.	Evening-peak Generation (Generation end)	:	8313.00	MW,	at =	20:00 hrs	Khulna	976	976	0	Barishal	227	227
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	20:00 hrs P	Rajshahi	976	976	0	Rangpur	227	227
08.	Actual Minimum Generation up to 8:00 hrs.	:	5440.00	MW,	at =	5:00 hrs am	Cumilla	715	715	0			
09.	Generation shortfall at evening peak due to :	:									Total	7470	7470
	a) Gas limitation	:	1735	MW			13.	Fuel cost :	(a) Gas = 104554137 Taka	(c) Coal = 37488410 Taka			
	d) Coal supply Limitation	:	0	MW				(b) Oil = 105608960 Taka	Total = 142042547 Taka				
	b) Low water level in Kaptai lake	:	160	MW									
	c) Plants under shut down/ maintenance	:	740	MW			14.	Maximum Temperature in Dhaka was :	27.0° C				
10.	Total Energy (Generation + India Import)	:	150.20	MKWh			15.	Export through East-West interconnections :					
	By Gas = 111.649 MKWH				By Oil = 15.041 MKWh			At evening peak-hour	: -711	MW,	at	20:00 hrs PM	
	By Coal = 14.988 MKWH				By Hydro = 1.573 MKWh			Maximum	: -773	MW,	at	18:30 hrs	
	By Solar= 0.149 MKWH							Energy	: 6.037	MKWh			
11.	Total Gas Supplied	:	975.08	MMCFD									
(D) Forecast of 15.02.20 (Today) Saturday :													
01.	Maximum Demand	:	9200	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14541	MW	(Generation end)		05.	Total Generation	:	166.23	MKWh		
03.	Maximum Shortage	:	-5341	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka ;	:	29.3° C			
* Captive Power ** Imported Power													
#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00													
(Fazul Islam Shaker) Deputy Secretary, Generation													