



Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9584667, 9551095

Month February, 2020				Day : Sunday				Date : 23.02.20			
Probable Maximum Demand : 9600 MW				Probable Maximum Generation : 14463 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 90.96 ft		Today = 90.75 ft		Rule Curve = 93.90 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.02.20 (Yesterday)		23.02.20 (Today)		22.02.20 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	37	37	37	37		
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	134	204	170	170		
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	304	281	325	325		
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0		
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	2 x 32	64	40	0	0	0	0	40	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	354	323	360	360		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	450	450	450		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	367	340	412	412		
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	32	40	40	178	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	65	91	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	150	150	150	150		
15	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	100	40	100	100	100		
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	15	100	100		
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55		
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
19	Gagnagar 102 MW PP Digital Pow	HFO (IPP)	12x8.924	102	102	50	102	100	102		
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22		
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	32	57	58	58		
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25		
23	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	33	25	25		
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52		
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	100	100		
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	149	149		
27	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50		
28	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	53	53	54	54		
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	200	300		
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	32	100	149	149		
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300		
32	Bramhangaoan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100		
33	Aurath 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100		
34	Nababganj 55 MW PP (Southern pc)	HFO (IPP)	3x19.3	55	55	0	0	55	55		
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	55	55		
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	71	71		
Dhaka Zone Total				6047	5811	2078	2447	3564	4166	658	485
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	69	69	70	70	161	Low Water Level
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	100	120		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4.5	0	5	0		
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25		
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18.5	0	20	0		
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	50	50	50		
43	Sikalbaha 105 MW PP (Baraka Sik)	HFO (IPP)	6x18.415	105	105	0	0	105	105		
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	140	149	145	145		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	207	204	225	225		
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	102	228	230	300		
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	50	100	100		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	80	100		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	21	21		
*	Malancha, Cig.EPZ (United)	Gas	5x8.73+3x9.34			3	26	10	30		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	30	100	100		
53	Sikalbaha 54 MW Power Plant(Jodiari Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	50	110		
Chattogram Zone Total				2226	2166	711	945	1490	1655	341	0
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	100	120	100	100		
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	46	46	45	45		
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	197	184	225	225		
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	325	310	360	360		
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	275	310	360	360		
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	20	20		
61	Ashuganj 195MW PP (APSCCL)	Gas (IPP)	20*9.73+1*116	195	195	26	26	46	46		
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43		
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	100	150		
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	91	90	90		
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	0	200		
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	24	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	50		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	21	21	21		
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x1.4+40x1.515+15x1.05	200	200	0	0	0	200		
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	114		
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	113	113		
**	Impoport (Tripura)	India		160	160	84	118	87	115		
Cumilla Zone Total				3040	2980	1273	1331	1676	2368	269	0
75	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	132	126	140	140		
76	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
77	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	50	95	95	95		
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
79	Mymensingh 200 MW PP (Limited)	HFO (IPP)	21x9.780	200	200	40	100	100	200		
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	2.1	0	1.6	0		
Mymensingh Zone Total				645	637	361.1	458	473.6	572	0	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.02.20 (Yesterday)		23.02.20 (Today)		22.02.20 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
81	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	85	88	88	88				
82	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	73	73	73	73				
83	Fenchugonj 51 MW PP (Barakatull)	Gas (RPP)	19x2.90	51	51	28	25	51	51				
84	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	51	50	50	50				
85	Kushlari 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
86	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
87	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	63	66	66				
88	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+2x110	330	330	155	145	150	150				
89	Shahjibazar 86MW PP (Shahjibaza	Gas (RPP)	32x2.90	86	86	78	80	80	80				
90	Sylhet 150 MW CCGP	Gas (PDB)	1x142	142	142	0	97	0	0				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	19	17	17				
92	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0				
93	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
94	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	15	24	24				
95	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	325	300	341	341				
96	Bibiyan-II 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	235	233	235	235				
Sylhet Zone Total				1944	1899	1258	1372	1359	1359	0	0		
97	Bheramara GTPP Unit-1,2 & 3	HSD (PDB)	3 x 20	60	46	0	0	0	40				
98	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	325	325	410	410				
99	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	36				
100	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	30	70				
101	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	225				
102	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	16	70	115	115				
103	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	100				
104	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	24	33	33				
105	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	50	105				
106	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	67	50	105				
**	Bheramara (HVDC)	India		1000	1000	565	816	590	838				
Khulna Zone Total				2328	2314	906	1302	1278	2077	0	0		
107	Barisal GT PP Unit-1&2	HSD (PDB)	2 x 20	40	30	0	0	0	30				
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	100	70	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	12	20	20	20				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0				
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	85	98	95	95				
Payra 1320 MW						0	0	0	0				
Barishal Zone Total				472	462	97	218	185	255	0	0		
112	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
113	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	0	50				
114	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
115	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	45				
116	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	40	40				
117	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	42	100	80	100				
118	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40				
119	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	40	40				
120	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38				
121	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	216	214	210	210				
122	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
123	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
124	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	420	422	410	410				
125	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	22	22				
126	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	11	11	10	10				
127	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
128	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
129	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	109	109	113	113				
130	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	0	0	113				
Rajshahi Zone Total				2193	2183	827	910	1228	1494	611	0		
131	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	91	89	90	90				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Shutdown for Low Demand	
132	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	260	280	280	280				
133	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	17				
134	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	70	113	113				
135	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	17				
136	Majpara, Tatalia 8 MW Solar PP (Sympa	Solar (IPP)	1 x 8	8	8	3.5	0	8	0				
Rangpur Zone Total				685	605	355	439	491	517	0	85		
Sub-total: Plants in operation				19580	19057	7865.6	9422	11745	14463	1879	570		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7405	8585	11057	13616				
(B) Contract expired power plants													
137	Shahjibazar 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract expired	
Sub-Total: Plants under long term maintenance				50	50	0	0	0	0				
Gross Total				19630	19107	7865.6	9422	11745	14463	1879	570		
(C) Actual data of 22.02.20 (Yesterday) Saturday :													
01.	Max. Demand (Generation end)	:	9422.00	MW,	at =	19:30 hrs P	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand (Sub-station end)	:	8585.00	MW,	at =	19:30 hrs P	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	9422.00	MW,	at =	19:30 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	5326.00	MW,	at =	5:00 hrs	Dhaka	3192	3192	0	Mymensingh	758	758
05.	Day-peak Generation (Generation end)	:	7865.60	MW,	at =	12:00 hrs	Chattogram	914	914	0	Sylhet	346	346
06.	Evening-peak Generation (Generation end)	:	9422.00	MW,	at =	19:30 hrs	Khulna	1072	1072	0	Barishal	234	234
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:30 hrs P	Rajshahi	1072	1072	0	Rangpur	234	234
08.	Actual Minimum Generation up to 8:00 hrs.	:	6054.00	MW,	at =	5:00 hrs am	Cumilla	763	763	0			
09.	Generation shortfall at evening peak due to :	:									Total	8585	8585
	a) Gas limitation	:	1718	MW			13.	Fuel cost :	(a) Gas = 123684999 Taka	(c) Coal = 39825338 Taka			
	d) Coal supply Limitation	:	0	MW				(b) Oil = 122091340 Taka	Total = 163510337 Taka				
	b) Low water level in Kaptai lake	:	161	MW									
	c) Plants under shut down/ maintenance	:	570	MW			14.	Maximum Temperature in Dhaka was :	31.7° C				
10.	Total Energy (Generation + India Import)	:	176.30	MKWh			15.	Export through East-West interconnections :					
	By Gas = 134.595 MKWH				By Oil = 17.174 MKWh			At evening peak-hour	: -238	MW,	at	19:30 hrs PM	
	By Coal = 8.546 MKWH				By Hydro = 1.597 MKWh			Maximum	: -418	MW,	at	5:00 hrs	
	By Solar= 0.184 MKWH							Energy	: 3.9	MKWh			
11.	Total Gas Supplied	:	1118.38	MMCFD									
(D) Forecast of 23.02.20 (Today) Sunday :													
01.	Maximum Demand	:	9600	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14463	MW	(Generation end)		05.	Total Generation	:	179.63	MKWh		
03.	Maximum Shortage	:	-4863	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka ;	:	31.3° C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation