

Date :		21-Apr-20		Page -2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	24	496000	Unit-1 Under maint.
	Ghorasal Repowered CCGP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	280	5246800	
2	Ghorashal 78.5 MW PP (MAX)	QRPP	2*40	78	0	0	Gas shortage.
3	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	52	411909	Low demand
4	Haripur GTPP	SBU, PDB	2*32	40	0	0	Under maint.
5	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	335	7919850	FGMO
6	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	280	6360000	frequency control.
7	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	380	7593250	frequency control.
8	Meghnaghat 100 MW (IEL)	QRPP	12*9	100	0	0	Reserve
9	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	130	2986822	Gas shortage.
10	Madanganj 102 PP(Summit)	QRPP	6*17	100	40	210304	Low demand
11	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	15	28225	Low demand
12	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	0	Reserve
13	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	63612	
14	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
15	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	32	1230000	Gas shortage.
16	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
17	Siddhirgonj 335 MW CCGP	EGCB	1*217+118	335	230	3444565	ST-under maint.
18	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	0	0	Reserve
19	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Reserve
20	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	0	0	Reserve
21	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	0	Reserve
22	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	0	0	Reserve
23	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	17	92027	Low demand
24	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel Shortage
25	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	34	801240	Engine problem
26	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	742200	Engine problem
27	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	16	505800	Engine problem
28	Gazipur 52 MW PP	IPP	6*8.9	52	0	0	Reserve
29	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Gas shortage.
30	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	0	0	Reserve
31	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve
32	Bramhanganj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
33	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
34	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	42	90720	Low demand
35	Gazipur 100 MW PP	RPCL	100 MW	105	0	0	Reserve
Dhaka area Total				5811	1951	38229324	
37	Chattogram TPP-1	PDB	1*210	180	0	1000000	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage.
38	Razzan 25 MW PP	IPP	3*8.9	25	0	0	Reserve
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	81810	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	18	48000	Low demand
41	Kapital Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	36	776760	Low water level
42	Sikalbaha 225MW	PDB	1*150+1*175	225	224	4880981	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	139	2103316	FGMO
44	Sikalbaha 105 MW PP (Baraka Sikab)	IPP	105 MW	105	0	0	Reserve
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	51	104203	Low demand
47	Juldah 100 MW Unit-1 (Accorn)	QRPP	8*13.45	100	0	0	Reserve
48	Juldah 100 MW PP Unit-3 (Accorn)	IPP	0	100	0	0	Reserve
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	450384	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	42	991200	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Reserve
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	15119	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	Reserve
53	Jodiac Power	IPP	3*18.55+1*3.6	54	0	0	Reserve
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
	Juldah unit-2	IPP	0	0	60	257200	Low demand
Chattogram area Total				2166	591	10708973	
55	Ashuganj TPP Unit- 3	APSCL	1*150	135	135	2184806	
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage.
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage.
56	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	180	4059000	FGMO
57	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	320	6944000	FGMO
58	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	270	6539000	FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	42	515232	
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	20	264480	Gas shortage.
62	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	217454	Gas shortage.
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	40	370568	Gas shortage.
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	0	Reserve
66	Titas 50 MW Peaking PP	PDB	6*8.92	50	0	0	Reserve
67	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	85	1541320	ST-under maint.
68	Chandpur 200MW (Desh energy)	IPP	0	200	0	0	Reserve
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	193140	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	2	16380	
**	Import (Tripura)	Imported power	0	160	122	2216640	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	155400	
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	0	0	Reserve
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	18	393190	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	80	156240	
Cumilla Area Total				2980	1376	25766850	
75	RPCL 210MW CCGP	IPP	4*35+1*70	202	212	4569040	
76	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	153720	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	0	0	Reserve
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	8100	
79	Mymensingh 200 MW PP (United)	IPP	200	200	120	400800	Engine problem
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	26	36000	Low demand
Mymensingh Area Total				637	375	5167660	
81	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	73	1861000	
82	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	0	0	under maint.
83	Kushia 163 MW CCGP (KP)	IPP	1*109+1*54	163	110	2722990	frequency control.
84	Shajibazar 330 MW CCGP	PDB	3*110	330	96	2372000	FGMO & GT-1 under maint.
85	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	50	290400	
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	51	381528	
87	Shajibazar 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	44000	
88	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	40	910944	FGMO
89	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	50	372480	frequency control.
90	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	0	0	Contact expired
91	Sylhet 150 MW CCGP	PDB	1*142	142	130	1421170	
92	Sylhet 20 MW GTTP	PDB	1*20	20	19	68000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	96600	
95	Bibiyan-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	280	6817750	FGMO
96	Bibiyan-III 400 MW CCGP	PDB	400 MW	400	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	36540	
Sylhet Area Total				1949	944	17395402	
98	Bheranara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheranara (HVC)	Imported power	2*500	1000	541	11092364	Low demand
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	49	73920	Low demand
100	Fairdipor 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve
101	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve
103	Bheranara 410 MW CCGP	NWPGCL	1*278+1*132	410	330	6666912	FGMO
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	0	0	Reserve
105	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Reserve
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	0	0	Reserve
107	Madhumati 100 MW PP	IPP	100 MW	105	0	0	Reserve
Khulna Area Total				2314	920	17833196	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	23	308000	
111	Bhola 225 MW CCGP	PDB	2*63+1*68	194	179	3802009	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	0	0	For Payra test
	Payra 1320 MW	NWPGCL	0	0	345	6879700	On test
Barisal Area Total				462	547	10989709	
113	Baghabari 71 MW GTTP	PDB	1*71	71	70	355000	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1*100	100	70	393000	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	Reserve
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve
116	Amnura 50 MW PP (Sinha)	QRPP	7*7.79	50	50	150120	
117	Katakali 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Reserve
118	Katakali 50 MW Peaking PP	PDB	6*8.7	50	0	0	Reserve
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	180	3815609	FGMO
120	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	Under S/D.
121	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	211	4018709	FGMO
122	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	376	7956327	FGMO
123	Santahar 50 MW Peaking PP	PDB	6*8.7	50	0	0	Reserve
124	Bogra 22 MW PP (GBB)	RPP	6*4	22	17	83280	Engine problem
125	Bogura 20 MW PP (Energyprima)	RPP	5*3.3+5*2	10			