

Date :		12-May-20		Page -2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	Unit-1 & 2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	100	4090000	Transformer O/L
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
2	Ghorasal 78.5 MW PP (MAX)	QRPP	2*40	78	40	1226176	Transformer O/L
3	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	15	1760545	Transformer O/L
4	Haripur GTPP	SBU, PDB	2*32	40	0	0	Under maint.
5	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	330	8186880	FGMO
6	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	351	7276000	Frequency Control.
7	Meghnaghat 450 MW CCPP (MPL)	IPP	2*150+1*150	450	420	8595500	Frequency Control.
8	Meghnaghat 100 MW (IEL)	QRPP	12*9	100	100	1503360	
9	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	275	6389818	
10	Madanganj 102 PP(Summit)	QRPP	6*17	100	92	2216808	
11	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	866678	
12	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	10	713166	Reserve
13	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	404172	
14	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
15	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	175	3205000	Gas shortage.
16	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	80	538560	Low demand
17	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	0	0	Under S/D.
18	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	0	62928	Reserve
19	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	47	265200	Reserve
20	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	1040400	
21	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	115	1030080	Low demand
22	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	902935	
23	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	17	555606	Low demand
24	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel Shortage
25	Summit Power (Madhabdi+Ashulia)	SIPP,REB	3*3.67+4*8.73	80	49	1121100	Engine problem
26	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	802900	
27	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	20	727400	Engine problem
28	Gazipur 52 MW PP	IPP	6*8.9	52	0	0	Reserve
29	Tongi 80 MW GTPP	PDB	1* 105	105	0	0	Gas shortage.
30	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	3811307	Low demand
31	Keraniganj 300 MW PP (APR)	IPP	25*1.4	300	0	0	Reserve
32	Bramhanganj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
33	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
34	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3064320	
35	Gazipur 100 MW PP	RPCL	100 MW	105	0	82652	Reserve
Dhaka area Total				5811	2900	80449491	
37	Chattogram TPP-1	PDB	1*210	180	95	2100000	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage.
38	Raczan 25 MW PP	IPP	3*8.9	25	8	110538	Low demand
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	108810	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	19	259680	Low demand
41	Kapital Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	35	815640	Low water level
42	Sikalbaha 225MW	PDB	1*150+1*175	225	217	5040526	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	139	3158820	FGMO
44	Sikalbaha 105 MW PP (Baraka Sikab	IPP	105 MW	105	0	0	Reserve
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	85	907290	
47	Juldah 100 MW Unit-1 (Accorn)	QRPP	8*13.45	100	0	105360	Reserve
48	Juldah 100 MW PP Unit-3 (Accorn)	IPP	0	100	90	2168640	
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	486624	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	42	643680	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	96	784320	Low demand
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	32040	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	199	4476218	Low demand
53	Jodiac Power	IPP	3*18.55+1*3.6	54	0	0	Reserve
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
	Juldah unit-2	IPP	0	0	100	2437440	
Chattogram area Total				2166	1146	23635626	
55	Ashuganj TPP Unit- 3	APSCL	1*150	135	120	3025116	
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage.
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage.
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	210	4812000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	310	4774500	ST under maint.
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	300	7450000	FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	42	883656	
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	44	1129440	
62	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	301090	Gas shortage.
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1185920	
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	10	659054	Transformer O/L
66	Titas 50 MW Peaking PP	PDB	6*8.92	50	0	0	Reserve
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Under maint.
68	Chandpur 200MW (Desh energy)	IPP	0	200	0	0	Reserve
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	494856	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	238680	
**	Import (Tripura)	Imported power	0	160	178	3593280	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	817800	
72	Jangalia 52 MW PP (Lakhdarawi)	IPP	6*8.92	52	0	48298	Reserve
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	491100	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	1179900	
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	113	2541000	
Cumilla Area Total				2980	1585	33625690	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	149	3503320	
76	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	456300	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	92	877440	Low demand
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	17000	
79	Mymensingh 200 MW PP (Unite)	IPP	200	200	151	3535200	
80	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	109	1890000	#REF!
Mymensingh Area Total				637	523	10279260	
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	89	2087000	
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	29	695401	
83	Kushia 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3313881	Frequency Control.
84	Shajibazar 330 MW CCPP	PDB	3*110	330	185	4392000	FGMO
85	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	53	1141200	
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	50	1146168	
87	Shajibazar 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	264000	
88	Shajibazar GTPP Unit- 8 & 9	PDB	2*35	66	60	1427328	FGMO
89	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	76	1573440	
90	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	0	0	Contact expired
91	Sylhet 150 MW CCPP	PDB	1*142	142	137	2790300	
92	Sylhet 20 MW GTPP	PDB	1*20	20	18	425000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	572462	
95	Bibiyan-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	285	7029500	FGMO
96	Bibiyan-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	240300	
Sylhet Area Total				1949	1190	27087710	
98	Bheranara GTPP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheranara (NWDC)	Imported power	2*500	1000	930	18458181	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	99	1831680	Engine problem
100	Fairdipur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve
103	Bheranara 410 MW CCPP	NWPGCL	1*278+1*132	410	335	8138592	FGMO
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	40	424875	
105	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	88	23712	
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	105	353760	Low demand
107	Madhumati 100 MW PP	IPP	100 MW	105	50	328320	Low demand
Khulna Area Total				2314	1647	29559120	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	713760	
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	33	606205	
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	60	1443000	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	96	2248230	
	Payra 1320 MW	NWPGCL	0	0	669	14908100	On test
Barisal Area Total				462	968	19	