

| Date :                |                                     | 15-May-20               |                     | Page -2          |                      |                  |                         |
|-----------------------|-------------------------------------|-------------------------|---------------------|------------------|----------------------|------------------|-------------------------|
| Sl. No.               | Name of the Power Stations          | Producer                | Installed Capacity  | Present Capacity | Peak Hour Generation | Energy Generated | Remarks                 |
|                       |                                     |                         | Unit No. X Capacity | MW               | MW                   | MW               |                         |
| 1                     | Ghorasal TPP (Unit-1&2)             | PDB                     | 2*55                | 85               | 0                    | 0                | Unit-1 & 2 Under maint. |
|                       | Ghorasal Repowered CCPP Unit-3      | PDB                     | 1*210               | 170              | 0                    | 0                | Under maint.            |
|                       | Ghorasal Repowered CCPP Unit-4      | PDB                     | 1*210               | 180              | 140                  | 3568000          |                         |
|                       | Ghorasal TPP Unit-5                 | PDB                     | 1*210               | 190              | 0                    | 0                | Under maint.            |
| 2                     | Ghorasal 365 MW CCPP Unit-7         | PDB                     | 1*243+1*122         | 365              | 0                    | 0                | Under maint.            |
| 3                     | Ghorashal 78.5 MW PP(MAX)           | QRPP                    | 2*40                | 78               | 40                   | 1114848          | Gas shortage.           |
| 4                     | Ghorashal 108MW PP (Regent)         | IPP                     | 34*3.35             | 108              | 74                   | 1750090          | Gas shortage.           |
| 5                     | Haripur GTPP                        | SBU, PDB                | 2*32                | 40               | 0                    | 0                | Under maint.            |
| 6                     | Haripur 412 MW CCPP                 | EGCB                    | 1*273+1*139         | 412              | 346                  | 8276990          | FGMO                    |
| 7                     | Haripur 360MW CCPP(MPL)             | IPP                     | 1*235+1*125         | 360              | 355                  | 7718000          |                         |
| 8                     | Meghnaghat 450 MW CCPP(MPL)         | IPP                     | 2*150+1*150         | 450              | 350                  | 8560250          | Frequency Control.      |
| 9                     | Meghnaghat 100 MW (IEL)             | QRPP                    | 1*2*9               | 100              | 16                   | 99840            | Low demand              |
| 10                    | Meghnaghat CCPP(Summit)             | IPP                     | 2*110+1*110         | 305              | 295                  | 6490851          | FGMO                    |
| 11                    | Madanganj 102 PP(Summit)            | QRPP                    | 6*17                | 100              | 94                   | 940680           |                         |
| 12                    | Madanganj-55 MW PP(Summit)          | (IPP)                   | 3*17.08+1*11.3      | 55               | 15                   | 69304            | Low demand              |
| 13                    | Keraniganj 100 MW PP (Powerpac)     | QRPP                    | 8*13.45             | 100              | 0                    | 0                | Reserve                 |
| 14                    | Narshingdi 22 MW PP (Doreen)        | SIPP, REB               | 8*2.90              | 22               | 19                   | 253260           | Engine problem          |
| 15                    | 210 MW Siddhirgonj TPP              | PDB                     | 1*210               | 115              | 0                    | 0                | Under maint.            |
| 16                    | Siddhirgonj 2*120 MW GTPP           | EGCB                    | 2*105               | 210              | 145                  | 2667000          | Gas shortage.           |
| 17                    | Siddhirgonj 100 PP(Dutch Bangla)    | QRPP                    | 12*8.9              | 100              | 0                    | 0                | Reserve                 |
| 18                    | Siddhirgonj 335 MW CCPP             | EGCB                    | 1*217+118           | 335              | 0                    | 0                | Under S/D.              |
| 19                    | Gagnagar 102 MW PP (Digital Power)  | IPP                     | 12*8.924            | 102              | 0                    | 0                | Reserve                 |
| 20                    | Katpotti 52 MW PP (Sinha)           | IPP                     | 7*7.9               | 51               | 0                    | 0                | Reserve                 |
| 21                    | Kamalaghat 54 MW PP(Banco Energy)   | IPP                     | 3*18                | 54               | 53                   | 746280           |                         |
| 22                    | Kodda 150MW PP                      | BPDB-RPCL               | 9*17.06             | 149              | 0                    | 0                | Reserve                 |
| 23                    | Manikganj 55 MW PP (Northern)       | IPP                     | 3*19.3              | 55               | 55                   | 284306           |                         |
| 24                    | Nababganj 55 MW PP (Southern power) | IPP                     | 3*19.3              | 55               | 17                   | 125078           | Low demand              |
| 25                    | Bosila 108MW PP(CLC)                | IPP                     | 12*8.775+1*3.5      | 108              | 0                    | 0                | Fuel Shortage           |
| 26                    | Summit Power(Madhabdi+Ashulia)      | SIPP,REB                | 3*3.67+4*8.73       | 80               | 36                   | 911040           | Engine problem          |
| 27                    | Maona 33 MW PP(Summit)              | SIPP,REB                | 4*8.73              | 33               | 28                   | 716000           |                         |
| 28                    | Rupganj 33 MW PP(Summit)            | SIPP,REB                | 4*8.73              | 33               | 16                   | 673000           | Engine problem          |
| 29                    | Gazipur 52 MW PP                    | IPP                     | 6*8.9               | 52               | 0                    | 0                | Reserve                 |
| 30                    | Tongi 80 MW GTPP                    | PDB                     | 1* 105              | 105              | 0                    | 0                | Gas shortage.           |
| 31                    | Kodda 300 MW PP Unit-2 (Summit)     | IPP                     | 18*17.076           | 300              | 148                  | 1558145          | Low demand              |
| 32                    | Keraniganj 300 MW PP (APR)          | IPP                     | 25*1.4              | 300              | 0                    | 0                | Reserve                 |
| 33                    | Bramhanganj 100 MW PP (Aggreko)     | IPP                     | 100                 | 100              | 0                    | 0                | Reserve                 |
| 34                    | Aurshahi 100MW PP (Aggreko)         | IPP                     | 0.85*23+0.95*91     | 100              | 0                    | 0                | Reserve                 |
| 35                    | Kodda 149 MW PP Unit-1 (Summit)     | IPP                     | 149                 | 149              | 100                  | 1658880          | Low demand              |
| 36                    | Gazipur 100 MW PP                   | RPCL                    | 100 MW              | 105              | 0                    | 0                | Reserve                 |
| Dhaka area Total      |                                     |                         |                     | 5811             | 2342                 | 48181842         |                         |
| 37                    | Chattogram TPP-1                    | PDB                     | 1*210               | 180              | 90                   | 2200000          | Gas shortage.           |
|                       | Chattogram TPP-2                    | PDB                     | 1*210               | 180              | 0                    | 0                | Gas shortage.           |
| 38                    | Razzan 25 MW PP                     | IPP                     | 3*8.9               | 25               | 7                    | 35856            | Low demand              |
| 39                    | Teknaf 20MW PP (Solartech)          | Teknaf Solartech Energy | 20                  | 20               | 0                    | 135000           |                         |
| 40                    | Patenga 50MW PP (Baraka)            | IPP                     | 8*6.98              | 50               | 0                    | 90240            | Reserve                 |
| 41                    | Kapital Hydro: Unit-1,2,3,4, 5      | PDB                     | 2*40+3*50           | 230              | 36                   | 809100           | Low water level         |
| 42                    | Sikalbaha 225MW                     | PDB                     | 1*150+1*175         | 225              | 218                  | 5138384          | FGMO                    |
| 43                    | Sikalbaha Peaking GT                | PDB                     | 1*150               | 150              | 139                  | 3375528          | FGMO                    |
| 44                    | Sikalbaha 105 MW PP (Baraka Sikab   | IPP                     | 105 MW              | 105              | 0                    | 0                | Reserve                 |
| 45                    | Hathazari 100 MW peaking PP         | PDB                     | 11*8.9              | 98               | 0                    | 0                | Under maint.            |
| 46                    | Dohazari -Kalaish 100 MW Peaking    | PDB                     | 6*17                | 102              | 68                   | 697872           | Low demand              |
| 47                    | Juldah 100 MW Unit-1 (Accorn)       | QRPP                    | 8*13.45             | 100              | 0                    | 0                | Reserve                 |
| 48                    | Juldah 100 MW PP Unit-3 (Accorn)    | IPP                     | 0                   | 100              | 100                  | 1497600          |                         |
| 49                    | Barabkunda 22 MW PP (Regent)        | SIPP, PDB               | 8*2.90              | 22               | 22                   | 517008           |                         |
| *                     | Malancha, Ctg. EPZ (Unitted)        |                         | 5*8.73+3*9.34       | 0                | 42                   | 935040           |                         |
| 50                    | Chattogram 108 MW PP (ECPV)         | IPP                     | 16*7                | 108              | 12                   | 72960            | Low demand              |
| 51                    | Kaptai 7 MW Solar PP                | PDB                     | 7.4 MW              | 7                | 0                    | 36840            |                         |
| 52                    | Anwara 300 MW PP (Unitted)          | IPP                     | 300 MW              | 300              | 107                  | 1656000          | Low demand              |
| 53                    | Jodiac Power                        | IPP                     | 3*18.55+1*3.6       | 54               | 0                    | 0                | Reserve                 |
| 54                    | Karnaphuli Power Ltd.               | IPP                     | 110                 | 110              | 0                    | 0                | Reserve                 |
|                       | Juldah unit-2                       | IPP                     | 0                   | 0                | 100                  | 2252160          |                         |
| Chattogram area Total |                                     |                         |                     | 2166             | 941                  | 19449588         |                         |
| 55                    | Ashuganj TPP Unit- 3                | APSCL                   | 1*150               | 135              | 135                  | 2708764          | Gas shortage.           |
|                       | Ashuganj TPP Unit- 4                | APSCL                   | 1*150               | 129              | 0                    | 0                | Gas shortage.           |
|                       | Ashuganj TPP Unit- 5                | APSCL                   | 1*150               | 134              | 0                    | 0                | Gas shortage.           |
| 56                    | Ashuganj 225 MW CCPP                | APSCL                   | 1*142+1*75          | 221              | 198                  | 4751000          | FGMO                    |
| 57                    | Ashuganj 450 MW CCPP(North)         | APSCL                   | 1*360               | 360              | 345                  | 7535000          | FGMO                    |
| 58                    | Ashuganj 450 MW CCPP(South)         | APSCL                   | 1*360               | 360              | 300                  | 6640000          | FGMO                    |
| 59                    | Ashuganj 50 MW PP                   | APSCL                   | 14*3.968            | 45               | 42                   | 960336           |                         |
| 60                    | Ashuganj 55 MW PP (Precision)       | RPP                     | 15*4                | 55               | 51                   | 967680           |                         |
| 62                    | Ashuganj 195MW PP (APSCL-Unitted    | IPP                     | 20*9.73+1*16        | 195              | 110                  | 1739636          | Gas shortage.           |
| 63                    | Ashuganj 51 MW PP (Midiland)        | IPP                     | 6*9.34              | 51               | 51                   | 912824           |                         |
| 64                    | Ashuganj 150MW PP (Midiland)        | IPP                     | 23*7.015            | 150              | 50                   | 292727           | Low demand              |
| 66                    | Titas 50 MW Peaking PP              | PDB                     | 6*8.92              | 62               | 0                    | 0                | Reserve                 |
| 67                    | Chandpur 150 MW CCPP                | PDB                     | 1*106+1*57          | 163              | 0                    | 0                | Under maint.            |
| 68                    | Chandpur 200MW (Desh energy)        | IPP                     | 0                   | 200              | 0                    | 0                | Reserve                 |
| 69                    | Feni 22MW PP (Doreen)               | SIPP, PDB               | 8*2.90              | 22               | 0                    | 384912           | Engine problem          |
| 70                    | Feni 11 MW PP (Doreen)              | SIPP, REB               | 4*2.90              | 11               | 10                   | 219600           | Engine problem          |
| **                    | Impoport (Tripura)                  | Imported power          | 0                   | 160              | 116                  | 2866560          |                         |
| 71                    | Jangalia 33MW PP (Summit)           | SIPP, PDB               | 4*8.73              | 33               | 33                   | 647600           |                         |
| 72                    | Jangalia 52 MW PP (Lakdanavi)       | IPP                     | 6*8.92              | 52               | 0                    | 0                | Reserve                 |
| 73                    | Cumilla 25 MW PP (Summit)           | SIPP, PDB               | 3*3.67+2*6.97       | 25               | 20                   | 427440           | Engine problem          |
| 74                    | Daudkandi 200 MW PP (B.Trac)        | IPP                     | 154*1.4             | 200              | 0                    | 0                | Reserve                 |
|                       | Feni Lanka Power                    | IPP                     | 7*18.415+1*9.78     | 114              | 0                    | 513000           | Reserve                 |
|                       | Chowmuhani 113 MW                   | IPP                     | 12*9.78+2*3.1       | 113              | 50                   | 1963920          | Low demand              |
| Cumilla Area Total    |                                     |                         |                     | 2980             | 1511                 | 33530999         |                         |
| 75                    | RPCL 210MW CCPP                     | IPP                     | 4*35+1*70           | 202              | 169                  | 4159610          | Gas shortage.           |
| 76                    | Tangal 22 MW PP (Doreen)            | SIPP, PDB               | 8*2.90              | 22               | 20                   | 396684           | Engine problem          |
| 77                    | Jamalpur 95 MW PP(Powerpac)         | IPP                     | 12*8.924            | 95               | 50                   | 238080           | Low demand              |
| 78                    | Sarishabari 3 MW Solar Plant        | IPP                     | 1*3                 | 3                | 0                    | 12800            |                         |
| 79                    | Mymensingh 200 MW PP (Unitted)      | IPP                     | 200                 | 200              | 175                  | 2289600          | Engine problem          |
| 80                    | Jamalpur 115 MW PP (Unitted)        | IPP                     | 115 MW              | 115              | 112                  | 582000           | #REF!                   |
| Mymensingh Area Total |                                     |                         |                     | 637              | 526                  | 7678774          |                         |
| 81                    | Fenchugonj CCPP Phase-1             | PDB                     | 2*32+1*33           | 70               | 86                   | 1680000          |                         |
| 82                    | Fenchugonj CCPP Phase-2             | PDB                     | 2*35+1*35           | 90               | 30                   | 213720           |                         |
| 83                    | Kushlaria 163 MW CCPP (KP)          | IPP                     | 1*109+1*54          | 163              | 163                  | 3511472          |                         |
| 84                    | Shajibazar 330 MW CCPP              | PDB                     | 3*110               | 330              | 193                  | 4355000          | FGMO & ST under S/D     |
| 85                    | Fenchugonj 51 MW PP (Barakatullah)  | RPP                     | 19*2.90             | 51               | 53                   | 772200           |                         |
| 86                    | Fenchugonj 44MW (Energyprima)       | RPP                     | 12*3.3+5*2          | 44               | 47                   | 799632           |                         |
| 87                    | Hobiganj 11MW PP Confidence-E       | SIPP, REB               | 4*2.90              | 11               | 11                   | 264000           |                         |
| 88                    | Shajilbazar GTPP Unit- 8 & 9        | PDB                     | 2*35                | 66               | 61                   | 1115520          | FGMO                    |
| 89                    | Shajilbazar 86MW PP (Shajilbazar)   | RPP                     | 32*2.90             | 86               | 50                   | 1015680          |                         |
| 90                    | Shajilbazar 50MW PP (EPL)           | RPP                     | 27*2.0              | 50               | 0                    | 0                | Contact expired         |
| 91                    | Sylhet 150 MW CCPP                  | PDB                     | 1*142               | 142              | 150                  | 3564920          |                         |
| 92                    | Sylhet 20 MW GTPP                   | PDB                     | 1*20                | 20               | 18                   | 430000           |                         |
| 93                    | Sylhet 50MW PP (EPL)                | RPP                     | 27*2                | 50               | 0                    | 0                | Contract Expired        |
| 94                    | Shahjahanulla 25 MW PP              | SIPP, REB               | 3*9.34              | 25               | 24                   | 441722           |                         |
| 95                    | Bibiyan-II 341 MW CCPP (Summit)     | IPP                     | 1*222+1*119         | 341              | 310                  | 7285000          | FGMO                    |
| 96                    | Bibiyan-III 400 MW CCPP             | PDB                     | 400 MW              | 400              | 0                    | 0                | Under maint.            |
| 97                    | Sylhet 10MW PP (Desh)               | RPP                     | 6*1.95              | 10               | 10                   | 241580           |                         |
| Sylhet Area Total     |                                     |                         |                     | 1949             | 1206                 | 25599426         |                         |
| 98                    | Bheranara GTPP Unit-1,2 & 3         | PDB                     | 3*20                | 46               | 0                    | 0                | Reserve                 |
| **                    | Bheranara (WDC)                     | Imported power          | 2*500               | 1000             | 944                  | 21780091         |                         |
| 99                    | Khulna 115 PP MW (KPCL-2)           | QRPP                    | 7*17                | 115              | 99                   | 980160           | Engine problem          |
| 100                   | Fairdipur 50 MW Peaking PP          | PDB                     | 8*6.89              | 54               | 0                    | 0                | Reserve                 |
| 101                   | Khulna 225 MW CCPP                  | NWPGCL                  | 1*150+1*75          | 230              | 0                    | 0                | Reserve                 |
| 102                   | Gopalganj 100 MW Peaking PP         | PDB                     | 16*6.98             | 109              | 0                    | 0                | Reserve                 |
| 103                   | Bheranara 410 MW CCPP               | NWPGCL                  | 1*278+1*132         | 410              | 370                  | 6171264          | FGMO                    |
| 104                   | Noapara 40 MW PP (Khanjahan Ali)    | QRPP                    | 5*8.5               | 40               | 40                   | 350625           |                         |
| 105                   | Noapara 100 MW PP (Bangla Trac)     | IPP                     | 70*1.4              | 100              | 90                   | 425280           | Engine problem          |
| 106                   | Rupsha 105 MW PP (Orlon rupsha)     | IPP                     | 6*18.445            | 105              | 53                   | 233760           | Engine problem          |
| 107                   | Madhumati 100 MW PP                 | IPP                     | 100 MW              | 105              | 0                    | 0                | Reserve                 |
| Khulna Area Total     |                                     |                         |                     | 2314             | 1596                 | 29505180         |                         |
| 108                   | Barisal 110 MW PP (Summit )         | IPP                     | 7*17.076            | 110              | 80                   | 620640           | Low demand              |
| 109                   | Barisal GT PP Unit-1& 2             | PDB                     | 2*20                | 30               | 0                    | 0                | Reserve                 |
| 110                   | Bhola 33 MW PP (Venture)            | RPP                     | 1*34.50             | 33               | 34                   | 625255           |                         |
| 111                   | Bhola 225 MW CCPP                   | PDB                     | 2*63+1*68           | 194              | 60                   | 1442000          |                         |
|                       |                                     |                         |                     |                  |                      |                  |                         |