

Date : 20-May-20		Page-2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2'55	85	0	0	Unit-1 & 2 Under maint.
	Ghorasal Repowered CAPP Unit-3	PDB	1'210	170	0	0	Under maint.
	Ghorasal Repowered CAPP Unit-4	PDB	1'210	180	140	3860000	Bad weather
	Ghorasal TPP Unit-5	PDB	1'210	190	0	0	Under maint.
2	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
3	Ghorasal 78.5 MW PPI(MAX)	QRPP	2'40	78	50	1329664	Gas shortage.
4	Ghorasal 108MW PP (Recent)	IPP	34'3.35	108	75	1888090	Bad weather
5	Haripur GTPP	SBU, PDB	2'32	40	0	0	Under maint.
6	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	328	8217600	FGMO
7	Haripur 360MW CAPP(HPL)	IPP	1'235+1'125	360	283	7678000	Bad weather
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2'150+1'150	450	300	9087000	Bad weather
9	Meghnaghat 100 MW (IEL)	QRPP	12'8.9	100	0	312000	Reserve
10	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	305	240	6256000	FGMO
11	Madanigan 102 PP(Summit)	QRPP	6'17	100	14	867166	Low demand
12	Madanigan-55 MW PP(Summit)	(IPP)	3'17.08+1'111.3	55	0	48923	Reserve
13	Keranigan 100 MW PP (Powerpac)	QRPP	8'13.45	100	0	0	Reserve
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	0	287352	
15	210 MW Siddhirgoni TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgoni 2'120 MW GTTP	EGCB	2'105	210	75	2927000	Bad weather
17	Siddhirgoni 100 PP(Dutch Bangla)	QRPP	12'8.9	100	0	0	Reserve
18	Siddhirgoni 335 MW CAPP	EGCB	1'217+1'118	335	0	0	Under S/D.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	0	0	Reserve
20	Katpotti 52 MW PP (Sinha)	IPP	7'7.9	51	0	3408	Reserve
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	0	355680	Reserve
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	0	0	Reserve
23	Manigan 55 MW PP (Northern)	IPP	3'19.3	55	17	246580	Low demand
24	Nababgan 55 MW PP (Southern pow)	IPP	3'19.3	55	0	0	Reserve
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	108	0	0	Fuel Shortage
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	25	1040280	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	20	642100	Engine problem
28	Ruanai 33 MW PP(Summit)	SIPP, REB	4'8.73	33	16	689300	Engine problem
29	Gazipur 52 MW PP	IPP	6'8.9	52	0	0	Reserve
30	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	15	983563	Low demand
32	Keranigan 300 MW PP (APR)	IPP	256'1.4	300	0	0	Reserve
33	Bramrangon 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Aurahi 100MW PP (Aggreko)	IPP	0.85'2349.95'91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	45	1406880	Low demand
36	Gazipur 100 MW PP	RPCL	100 MW	105	0	0	Reserve
Dhaka area Total				5811	1643	48132588	
37	Chattoagram TPP-1	PDB	1'210	180	90	2200000	Gas shortage.
	Chattoagram TPP-2	PDB	1'210	180	0	0	Gas shortage.
38	Raczar 25 MW PP	IPP	3'8.9	25	0	18326	Low demand
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	8100	
40	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	0	0	Reserve
41	Kapali Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	30	674880	Low water level
42	Sikalbaha 225MW	PDB	1'150+1'175	225	210	5009461	FGMO
43	Sikalbaha Peaking GT	PDB	1'150	150	100	3153784	FGMO
44	Sikalbaha 105 MW PP (Baraka Sikab)	IPP	105 MW	105	0	0	Reserve
45	Hathazari 100 MW Peaking PP	PDB	11'8.9	98	0	0	Under maint.
46	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	17	32640	Low demand
47	Juidah 100 MW Unit-1 (Accorn)	QRPP	8'13.45	100	0	0	Reserve
48	Juidah 100 MW Unit-3 (Accorn)	IPP	0	100	10	837120	Low demand
49	Barakunda 22 MW PP (Recent)	SIPP, PDB	8'2.90	22	21	464112	
*	Malancha, Ctg, EPZ (United)		5'8.73+3'9.34	0	40	665280	
50	Chattoagram 108 MW PP (ECPV)	IPP	16'7	108	0	0	Reserve
51	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	17640	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	49	1164218	Low demand
53	Jodiach Power	IPP	3'18.55+1'3.6	54	0	0	Reserve
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
	Juidah unit-2	IPP	0	0	100	1823040	
Chattoogram area Total				2166	667	16069601	
55	Ashugan TPP Unit- 3	APSCL	1'150	135	100	2471500	Gas shortage.
	Ashugan TPP Unit- 4	APSCL	1'150	129	0	0	Gas shortage.
	Ashugan TPP Unit- 5	APSCL	1'150	134	0	0	Gas shortage.
56	Ashugan 225 MW CAPP	APSCL	1'142+1'175	221	213	4794000	FGMO
57	Ashugan 450 MW CAPP(North)	IPP	1'360	360	265	7520100	FGMO
58	Ashugan 450 MW CAPP(South)	APSCL	1'360	360	275	6920000	FGMO
59	Ashugan 50 MW PP	APSCL	14'3.968	45	42	805896	Gas shortage.
60	Ashugan 50 MW PP (Precision)	RPP	15'4	55	15	348000	Bad weather
62	Ashugan 195MW PP (APSCL-United)	IPP	20'9.73+1'116	195	8	200727	Gas shortage.
63	Ashugan 51 MW PP (Midland)	IPP	6'9.34	51	22	1096688	
64	Ashugan 150MW PP (Midland)	IPP	23'7.015	150	48	518545	Low demand
66	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	0	Reserve
67	Chandpur 150 MW CAPP	PDB	1'106+1'57	163	0	0	Under maint.
68	Chandpur 200MW (Desh eneray)	IPP	0	200	0	0	Reserve
69	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	469908	
70	Feni 11 MW (Doreen)	SIPP, REB	4'2.90	11	8	179460	
**	Import (Tijura)	Imported power	0	160	130	248160	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	16	560500	
72	Jangalia 52 MW PP (Lakshani)	IPP	6'8.92	52	0	0	Reserve
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	15	310620	Engine problem
74	Daudkandi 200 MW PP (B. Trac)	IPP	154'1.4	200	0	0	Reserve
	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	0	Reserve
	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	0	337680	Reserve
Cumilla Area Total				2860	1200	28773884	
75	RPCL 210MW CAPP	IPP	4'35+1'70	202	155	4296360	Gas shortage.
76	Tangal 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	0	279180	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	0	276480	Reserve
78	Sarshaban 3 MW Solar Plant	IPP	1'3	3	0	4800	
79	Mymensingh 200 MW PP (United)	IPP	200	200	180	2692000	Low demand
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	16	500400	#REF!
Mymensingh Area Total				637	351	7450120	
81	Fenchugon CAPP Phase-1	PDB	2'32+1'33	70	89	2067000	
82	Fenchugon CAPP Phase-2	PDB	2'35+1'35	90	30	725400	
83	Kushiana 163 MW CAPP (KP)	IPP	1'109+1'54	163	100	3278127	Bad weather
84	Shahbazar 330 MW CAPP	PDB	3'110	330	187	4332000	FGMO & ST under S/D
85	Fenchugon 51 MW PP (Barakatalah)	RPP	19'2.90	51	53	798600	
86	Fenchugon 44MW (Energyprima)	RPP	12'3.3+5'2	44	47	797040	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	0	198000	
88	Shahbazar GTTP Unit- 8 & 9	PDB	2'35	66	29	1018272	FGMO
89	Shahbazar 86MW PP (Shahbazar)	RPP	32'2.90	86	55	1096320	Bad weather
90	Shahbazar 50MW PP (EPL)	RPP	2'72.0	50	0	0	Contact expired
91	Sylhet 150 MW CAPP	PDB	1'142	142	99	3022810	Bad weather
92	Sylhet 20 MW GTTP	PDB	1'20	20	17	408000	
93	Sylhet 50MW PP (EPL)	RPP	2'72	50	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	396754	Engine problem
95	Bibiana-II 341 MW CAPP (Summit)	IPP	1'222+1'119	341	310	7127700	FGMO
96	Bibiana-II 400 MW CAPP	PDB	0	400	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	228600	
Sylhet Area Total				1949	1042	25494623	
98	Bheramara GTTP Unit-1,2 & 3	PDB	3'20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2'500	1000	294	8296000	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7'17	115	0	50880	Bad weather
100	Fariapur 50 MW Peaking PP	PDB	8'6.98	54	0	0	Bad weather
101	Khulna 225 MW CAPP	NWPGCL	1'150+1'175	230	0	0	Bad weather
102	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Bad weather
103	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	210	7221312	FGMO
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5'8.5	40	0	0	Bad weather
105	Noapara 225 MW PP (Banjla Trac)	IPP	7'07.4	225	0	0	Bad weather
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	0	0	Bad weather
107	Mashumati 100 MW PP	IPP	100 MW	105	0	0	Bad weather
Khulna Area Total				2374	504	15566192	
108	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	0	0	Bad weather
109	Barisal GT PP Unit-1& 2	PDB	2'20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	3	189000	Bad weather
111	Bhola 225 MW CAPP	PDB	2'06+1'08	194	71	1191000	Bad weather
112	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	0	631948	Bad weather
	Pavra 1320 MW	NWPGCL	0	0	0	491300	On test
Barisal Area Total				462	74	2503248	
113	Bachabari 71 MW GTTP	PDB	1'71	71	0	0	Bad weather
	Bachabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage.
114	Bachabari 50 MW Peaking PP	PDB	6'8.9	52	0	0	Reserve
115	Bera 70 MW Peaking PP	PDB	9'3.29	71	0	0	Reserve
116	Amnara 50 MW PP(Sinha)	QRPP	7'7.79	50	0	154740	Reserve
117	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	0	0	Reserve
118	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	0	0	Reserve
119	Sirajgoni Unit-1 225MW	NWPGCL	1'150+1'175	210	0	0	Gas shortage.
120	Sirajgoni Unit-2 225MW	NWPGCL	1'150+1'175	220	162	4264309	FGMO
121	Sirajgoni Unit-3 225MW	NWPGCL	1'141	220	176	4667636	FGMO
122	Sirajgoni 400 MW CAPP Unit-4	SNWPGCL	1'282+1'132	414	324	9047360	FGMO
123	Santahar 50 MW Peaking PP	PDB	6'8.7	50	0	108811	Low demand
124	Bogra 22 MW PP (GBB)	RPP	6'4	22	19	366000	Engine problem
125	Bogra 20 MW PP (Energyprima)	R					