

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 9-Jun-20		Page -2					
No.	Name of the Power Stations	Producer	Installed Capacity	Capaci ty	Hour	Enerov Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	35	777000	Unit-2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	100	2670000	Gas shortage.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	220	4577627	Gas shortage.
3	Ghorashal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage.
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	99	2294772	
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	353	8274810	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	349	7759000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450	8884750	
9	Meghnaghat 100 MW(IEL)	QRPP	12*8.9	100	100	1917120	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	130	3108596	FGMO
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	88	2080032	Engine problem
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	30	919098	Low demand
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	50	477880	Low demand
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	392760	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage.
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	88	2028480	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	200	4372093	Machine problem
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	84	2003328	Engine problem
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	49	248496	
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	1164600	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	1027680	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	746464	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	908731	
25	Bosila 108MW PP(CLC)	SIPP, REB	12*8.775+1*3.5	108	0	0	Fuel Shortage
26	Summit Power.(Madhabadi+Ashulia)	SIPP,REB	3*3.67+4*8.73	80	53	1226400	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	737000	
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	697900	
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	730104	
30	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	265	4526398	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	25*61.4	300	0	86222	Reserve
33	Bramhangaan 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	50	100722	Low demand
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	132	3454560	Engine problem
36	Gazipur 100 MW PP	RPCL	100 MW	105	88	1857012	Engine problem
Dhaka area Total				5791	3448	70049635	
37	Chattogram TPP-1	PDB	1*210	180	90	2100000	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage.
38	Raozan 25 MW PP	IPP	3*8.9	25	25	120335	Low demand
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy Ltd	20	20	0	116910	
40	Patenga 50MW PP (Baraka)		IPP	8*6.98	50	25	311520
41	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	107	2597862	Low water level
42	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under S/D.
43	Sikalbaha Peaking GT	PDB	1*150	150	140	3234798	FGMO
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	17	194035	Low demand
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	102	234409	
47	Julidah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	0	31800	Reserve
48	Julidah 100 MW PP Unit-3 (Acom)	IPP	0	100	70	1813440	Low demand
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	471696	
*	Malancha, Ctg. EP2 (United)		5*8.73+3*9.34	0	37	460800	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	81	947520	Engine problem
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	40080	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	290	6679200	
53	Jodiad Power	IPP	3*18.55+1*3.6	54	0	10291	Reserve
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
	Julidah unit-2 (Acom)	IPP	8*13.6	100	100	2413440	
Chattogram area Total				2266	1104	22078136	
55	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas shortage.
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage.
	Ashuganj TPP Unit- 5	APSCL	1*150	134	80	2013618	Gas shortage.
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	154	4620000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	335	7762000	FGMO
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	280	6696000	FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	15	328248	Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	161440	Gas shortage.
62	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	234181	Gas shortage.
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	1010892	Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	132	3014254	Engine problem
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	90	2092190	
68	Chandpur 200MW (Desh energy)	IPP	0	200	17	82080	Low demand
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	13	363132	Engine problem
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	164340	Engine problem
**	Imported (Tripura)	Imported power	0	160	162	3497280	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	808700	
72	Jangalia 52 MW PP (Lakhdanavi)	IPP	6*8.92	52	52	325200	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	499350	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	106020	Low demand
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	102	1460760	Engine problem
Cumilla Area Total				2980	1586	35259685	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	113	2749480	Gas shortage.
76	Tangali 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	421200	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	1035840	
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	13400	
79	Myensingh 200 MW PP (United)	IPP	200	200	200	3782400	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2776800	#REF!
Myensingh Area Total				637	545	10779120	
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	57	1392000	
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	723120	
83	Kushiara 163 MW CCPP (KP)	IPP	1*106+1*54	163	163	3368455	
84	Shajibazar 330 MW CCPP	PDB	3*110	330	246	5662000	FGMO & ST under S/D
85	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	50	1105800	
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	49	1149120	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	258912	
88	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	29	1138312	FGMO
89	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	76	1720320	Engine problem
91	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	150	3160650	
92	Sylhet 20 MW GTTP	PDB	1*20	20	17	413000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	552960	
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	300	7335500	FGMO
96	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	239040	
	Bibiyana South 400 MW	PDB	400 MW	0	0	201000	On test
Sylhet Area Total				1988	1212	28320189	
98	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	930	21602182	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	1569920	
100	Fardpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	6	20992	Low demand
103	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	330	7676928	FGMO
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	40	547125	
105	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	73	502080	
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	53	318240	
107	Madhumati 100 MW PP	IPP	100 MW	105	15	89136	Low demand
Khulna Area Total				2284	1562	32726603	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	1368480	
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	30	634029	
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	89	2149615	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	74	1772882	Engine problem
	Payra 1320 MW	BCPCL	1*622	622	656	14578600	
Barisal Area Total				1054	959	20503606	
113	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	Reserve
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve
116	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	40	715110	Engine problem
117	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	16	71474	Low demand
118	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	14	69154	Low demand
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas