

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	35	772000	Unit-2 Under maint.
	Ghorasal Repowered CAPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CAPP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	280	7168764	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	69	1509984	
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	102	2148409	
5	Harijpur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Harijpur 412 MW CAPP	EGCB	1*273+1*139	412	0	0	Under maint.
7	Harijpur 383MW CAPP(MPL)	IPP	1*236+1*125	360	354	8078000	
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	420	9425000	frequency Control.
9	Meghnaghat 100 MW(IEI)	QRPP	12*8.9	100	91	1508160	Engine problem
10	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	260	6571811	FGMO
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	95	2175648	Engine problem
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	43	1027760	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	60	426143	Low demand
14	Narshingdi 22 MW PP (Doreen)	SI, P, REB	8*2.90	22	0	326736	
15	210 MW Siddhirganj TFP	PDB	8*2.10	115	0	0	Under maint.
16	Siddhirganj 2120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage.
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	91	1865280	
18	Siddhirganj 335 MW CAPP	EGCB	1*217+1*118	335	218	5005639	ST under maint.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	93	1912752	Engine problem
20	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	6	113232	Low demand
21	Kamalaghat 54 MW PP (Banco Energy)	IPP	3*18	54	53	1172520	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	115	661440	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	870023	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	17	695904	Low demand
25	Bosila 108MW PP(CICL)	IPP	12*8.775+1*3.5	108	0	0	Fuel Shortage
26	Summit Power, (Madhabdi+Ashulia)	SI, P, REB	3*3.67+4*8.73	80	55	1148280	Engine problem
27	Maona 33 MW PP(Summit)	SI, P, REB	4*8.73	33	33	809400	
28	Rupganj 33 MW PP(Summit)	SI, P, REB	4*8.73	33	33	816300	
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	51984	Low demand
30	Tongi 80 MW GTPP	PDB	1* 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	286	3424907	
32	Keraniganj 300 MW PP (APR)	IPP	236*1.4	300	0	0	Reserve
33	Bramhangonj 100 MW PP (Aggreko)	IPP	0 100	100	0	0	Reserve
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	113	2597760	Low demand
36	Gazipur 100 MW PP	RPCL	100 MW	105	34	892020	Engine problem
Dhaka area Total			5791	3011	63175856		
37	Chattogram TPP-1	PDB	1*210	180	90	2100000	Gas shortage.
38	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage.
39	Raozan 25 MW PP	IPP	3*8.9	25	0	29576	
40	Teknaf 208MW PP (Solartech)	Teknaf Solartech Ene	20	20	0	36180	
41	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	36	251040	
42	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	100	1564360	Low water level
43	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under S/D.
44	Sikalbaha Peaking GT	PDB	1*150	150	140	3221122	
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	17	154727	Low demand
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
47	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	93	626030	
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	0	18120	Reserve
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1647360	
50	Barabkunda 22 MW PP (Regent)	SI, P, PDB	8*2.90	22	21	480768	
51	* Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	38	563040	
52	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	97	1234560	Engine problem
53	Kapta 7 MW Solar PP	PDB	7.4 MW	7	0	29399	
54	Anwara 300 MW PP (United)	IPP	300 MW	300	306	6965236	
55	Jodiac Power	IPP	3*18.55+1*3.6	54	0	0	Reserve
56	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
57	Juldah unit-2 (Acorn)	IPP	8*13.6	100	100	2405760	
Chattogram area Total			2266	1138	21327278		
58	Ashuganj TPP Unit-3	APSCl	1*150	129	80	1670734	Gas shortage.
59	Ashuganj TPP Unit-4	APSCl	1*150	129	0	0	Gas shortage.
60	Ashuganj TPP Unit-5	APSCl	1*150	134	0	0	Gas shortage.
61	Ashuganj 225 MW CAPP	APSCl	1*142+1*175	221	181	4608000	FGMO
62	Ashuganj 450 MW CAPP(North)	APSCl	1*360	360	260	4841000	FGMO
63	Ashuganj 450 MW CAPP(South)	APSCl	1*360	360	250	6851000	FGMO
64	Ashuganj 50 MW PP	APSCl	14*3.968	45	37	811584	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	135940	Gas shortage.
66	Ashuganj 195MW PP (APSCl-United)	IPP	20*8.9+1*16	195	5	769454	Gas shortage.
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	946320	Engine problem
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	128	956800	Low demand
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	32500	Reserve
70	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	81	2064140	
71	Chandpur 200MW (Desh energy)	IPP	0	200	0	22560	Reserve
72	Feni 22MW PP (Doreen)	SI, P, PDB	8*2.90	22	21	483408	
73	Feni 11 MW PP (Doreen)	SI, P, REB	4*2.90	11	8	134280	
74	Imporgri (Tripura)	Imported power	0	160	166	3393600	
75	Jangalia 33MW PP (Summit)	SI, P, PDB	4*8.73	33	32	788400	
76	Jangalia 52 MW PP (Lakdanaw)	IPP	6*8.92	52	52	294571	
77	Cumilla 25 MW PP (Summit)	SI, P, PDB	3*3.67+2*6.97	25	21	424940	
78	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
79	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	69540	Reserve
80	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	96	1579200	Low demand
Cumilla Area Total			2980	1534	30878771		
81	RPCL 210MW CAPP	IPP	4*35+1*70	202	141	3234320	Gas shortage.
82	Tangail 22 MW PP (Doreen)	SI, P, PDB	8*2.90	22	22	417960	
83	Jamulpur 95 MW PP (Powerpac)	IPP	12*8.924	95	71	749760	Low demand
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12450	
85	Mymensingh 200 MW PP (United)	IPP	200	200	190	3424800	
86	Jamulpur 115 MW PP (United)	IPP	115 MW	115	115	2796000	#REF!
Mymensingh Area Total			637	539	10635290		
87	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	58	1774000	
88	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	30	721680	
89	Kushlira 163 MW CAPP (KP)	IPP	1*109+1*54	163	163	3596154	
90	Shahjibazar 330 MW CAPP	PDB	3*110	330	241	5459000	FGMO & ST under S/D
91	Fenchugonj 51 MW PP (Barakattullah)	RPP	1*9.90	50	50	1204200	
92	Fenchugonj 44MW (Energyprima)	RPP	12*3.35+2	44	46	1145592	
93	Hobiganj 11MW PP Colidence-E	SI, P, REB	4*2.90	11	11	222960	
94	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	61	1403808	FGMO
95	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	79	1817280	Engine problem
96	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	150	3327400	frequency Control.
97	Sylhet 20 MW GTPP	PDB	1*20	20	18	413000	
98	Sylhet 50MW PP (EPL)	RPP	2*2	50	0	0	Contract Expired
99	Shahjibazar 25 MW PP	SI, P, REB	3*9.34	25	25	439752	
100	Bibiyan-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	270	7430000	FGMO
101	Bibiyan-III 400 MW CAPP	PDB	400 MW	400	0	0	Under maint.
102	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	238140	
103	Bibiyan South 400 MW	PDB	400 MW	0	0	0	On test
Sylhet Area Total			1988	1211	29192966		
104	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve
105	Bheramara (HVDC)	Imported power	2*500	1000	938	22593454	
106	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	1872960	
107	Frankpur 50 MW Peaking PP	PDB	8*6.99	54	0	0	Reserve
108	Khulna 225 MW CAPP	NWPGCL	1*150+1*175	230	0	0	Reserve
109	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	21504	Reserve
110	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	340	8370144	FGMO
111	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	40	316500	
112	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	86	515520	Low demand
113	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	70	333600	Low demand
114	Madhumati 100 MW PP	IPP	100 MW	105	0	0	Reserve
Khulna Area Total			2284	1589	34023682		
115	Bansal 110 MW PP (Summit)	IPP	7*17.076	110	110	1406440	
116	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	24	518908	
117	Bhola 225 MW CAPP	PDB	2*63+1*68	194	64	1639000	GT-2 & ST Under maint.
118	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	78	1884888	Engine problem
119	Payra 1320 MW	BCPCL	1*622	622	607	13812700	
Barisal Area Total			1054	883	19261836		
120	Baghbari 71 MW GTPP	PDB	1*71	71	0	185000	Gas shortage.
121	Baghbari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage.
122	Baghbari 50 MW Peaking PP	PDB	6*8.9	52	25	76448	
123	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	39268	Reserve
124	Amnura 50 MW PP(Sinha)	QRPP	7*7.9	50	40	861130	Engine problem
125	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	57362	Reserve
126	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	37	113237	
127	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage.
128	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	184	4433818	FGMO
129	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	183	4500882	FGMO
130	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1*282+1*132	414	392	9392781	FGMO
1							