

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS							
Date : 25-Jun-20				Page -2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Enerov Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	35	721000	Unit-2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	300	7113964	
3	Ghorashal 78.5 MW PP(MAX)	QRPP	2*40	78	63	1428448	Engine problem
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	95	2216363	Engine problem
5	Hanpur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Hanpur 412 MW CCPP	EGCB	1*273+1*139	412	0	93180	Under maint.
7	Hanpur 360MW CCPP(HPL)	IPP	1*235+1*125	360	233	6738000	Line shut down
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	420	9360750	Frequency control
9	Meghnaghat 100 MW(IEI)	QRPP	12*8.9	100	97	2251200	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	260	6255331	FGMO
11	Madanganj 102 PB(Summit)	QRPP	6*17	100	80	2068584	Engine problem
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	41	993887	Engine problem
13	Keranganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	144439	Reserve
14	Narshingdi 22 MW PP (Doreen)	SIIPP, REB	8*2.90	22	22	462852	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	96	1532000	Gas shortage.
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	97	2236800	
18	Siddhirgonj 335 MW CCPP	EGCB	12*17+1*118	335	325	4902766	ST under maint.
19	Gagragar 102 MW PP (Digital Power)	IPP	12*8.924	102	102	2251008	
20	Katpottli 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Reserve
21	Kamalahat 54 MW PP(Banco Energy)	IPP	3*18	54	35	1182600	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	1049760	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1170211	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	971717	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel Shortage
26	Summit Power (Madhabadi+Ashulia)	SIIPP, REB	3*3.67+4*8.73	80	55	1262000	Engine problem
27	Maona 33 MW PP(Summit)	SIIPP,REB	4*8.73	33	0	755800	Engine problem
28	Rugganj 33 MW PP(Summit)	SIIPP,REB	4*8.73	33	33	794700	
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	157404	Reserve
30	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	272	5364434	Low demand
32	Keranigonj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
33	Bramhangaoan 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	25564	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	0	128	2844000	Engine problem
36	Gazipur 100 MW PP	RPCL	100 MW	105	107	869652	
	Sonargoon 104 MW (Orion)	IPP	18.5*6	0	108	977280	
Dhaka area Total				5791	3247	68196024	
37	Chattogram TPP-1	PDB	1*210	180	90	2100000	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage.
38	Razzan 25 MW PP	IPP	3*8.9	25	25	119156	
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Ener	20	20	0	61020	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	479520	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	95	2272342	Low water level
42	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under S/D.
43	Sikalbaha Peaking GT	PDB	1*150	150	139	3182251	FGMO
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	51	513527	Low demand
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Reserve
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	102	1111376	
47	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	0	45120	Reserve
48	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2417280	
49	Barakunda 22 MW PP (Regent)	SIIPP, PDB	8*2.90	22	20	458408	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	37	488640	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	45	771840	Low demand
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	32040	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	161	6184909	Low demand
53	Jodioc Power	IPP	3*18.55+1*3.6	54	0	424314	Reserve
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
	Juldah unit-2 (Acorn)	IPP	8*13.6	100	100	2419200	
Chattogram area Total				2266	1015	23081943	
55	Ashuganj TPP Unit- 3	APSCL	1*150	135	80	2254008	Gas shortage.
	Ashuganj TPP Unit- 4	APSCL	1*150	129	100	2384695	Gas shortage.
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage.
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	187	4501000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	315	7651500	FGMO
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	0	0	Under maint.
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	41	841032	
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	47	1091040	Engine problem
62	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	26	702545	Gas shortage.
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	1030611	Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	138	220306	
66	Tilas 50 MW Peaking PP	PDB	6*8.92	52	0	52440	Reserve
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	88	2070780	
68	Chandpur 200MW (Desh energy)	IPP	0	200	0	233280	Reserve
69	Feni 22MW PP (Doreen)	SIIPP, PDB	8*2.90	22	21	477792	
70	Feni 11 MW PP (Doreen)	SIIPP, REB	4*2.90	11	8	179640	Engine problem
**	Impoport (Tripura)	Imported power	0	160	172	3563520	
71	Jangalia 33MW PP (Summit)	SIIPP, PDB	4*8.73	33	25	597700	Engine problem
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	2775714	
73	Cumilla 25 MW PP (Summit)	SIIPP, PDB	3*3.67+2*6.97	25	21	486320	Engine problem
74	Daudikandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	367080	Reserve
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	105	1879080	
Cumilla Area Total				2980	1469	32675673	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	139	3478040	Gas shortage.
76	Tangail 22 MW PP (Doreen)	SIIPP, PDB	8*2.90	22	20	402012	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	37	624000	Engine problem
78	Sarsishabari 3 MW Solar Plant	IPP	1*3	0	0	9750	
79	Mymensingh 200 MW PP (United)	IPP	200	200	150	3312000	Low demand
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	70	2457600	#REF!
Mymensingh Area Total				637	416	10283402	
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	59	1385000	
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	721680	
83	Kushlari 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3400445	Frequency control
84	Shajibazar 330 MW CCPP	PDB	3*110	330	255	6181000	FGMO & ST under S/D
85	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	47	1153200	
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	45	908712	
87	Hobiganj 11MW PP Confidence-E	SIIPP, REB	4*2.90	11	11	219168	
88	Shajibazar GTTP Unit. 8 & 9	PDB	2*35	66	59	1395168	FGMO
89	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	76	1724160	Engine problem
91	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	140	2914470	
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	420000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIIPP, REB	3*9.34	25	24	507984	
95	Bidiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	280	6356270	FGMO
96	Bidiana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	246600	
	Bibiya South 400 MW	PDB	400 MW	0	0	0	On test
Sylhet Area Total				1988	1184	27523857	
98	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	930	22391273	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	2001600	
100	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	0	78720	Reserve
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*8.98	109	0	16512	Reserve
103	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	360	8891264	
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	40	561000	
105	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100	1112640	
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	105	583200	
107	Madhumati 100 MW PP	IPP	100 MW	105	15	274032	Low demand
Khulna Area Total				2284	1665	35710241	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	1320960	
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	37	735650	
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	87	2113725	GT-2 & ST Under maint.
112	Bhola 95 MW PP (Aggreko)	QRPP	98*1.10	95	79	1860899	Engine problem
	Payra 1320 MW	BCPCL	1*622	622	569	13429100	
Barisal Area Total				1054	882	19460244	
113	Baghabari 71 MW GTTP	PDB	1*71	71	70	1515000	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	156160	
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	65993	
116	Ammura 50 MW PP (Sinha)	QRPP	7*7.79	50	0	0	Reserve
117	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	112429	Reserve
118	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	43	179613	
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage.
120	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	140	4175164	FGMO
121	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	142	4315127	FGMO
122	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	419	9542490	FGMO
123	Santahar 50 MW Peaking PP	PDB	6*8.7	50	34	117020	
124	Bogra						