

**POWER GRID COMPANY OF BANGLADESH LTD.
NATIONAL LOAD DESPATCH CENTER
DAILY REPORT**

QF-LDC-08
Page -1

Reporting Date : 7-Jul-20

Till now the maximum generation is :-

12893 MW

21:00 Hrs on 29-May-19

The Summary of Yesterday's		6-Jul-20		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :		9498.3	MW	12:00		Min. Gen. at	7:00 8559 MW
Evening Peak Generation :		11470.0	MW	21:00		Available Max Generation	15272 MW
E.P. Demand (at gen end) :		11470.0	MW	21:00		Max Demand (Evening) :	11500 MW
Maximum Generation :		11470.0	MW	21:00		Reserve(Generation end)	3772 MW
Total Gen. (MKWH) :		238.7		System Load Factor	: 86.72%	Load Shed	: 0 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum		-246	MW	at	20:00	Energy	MKWHR.
Import from West grid to East grid :- Maximum		-	MW	at	-	Energy	- MKWHR.
Water Level of Kaptai Lake at 6:00 A M on	7-Jul-20						
Actual :	83.34	Ft.(MSL) ,		Rule curve :	84.96	Ft.(MSL)	

Gas Consumed :	Total =	1148.09	MMCFD.	Oil Consumed (PDB) :		HSD :	Liter
						FO :	Liter

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk165,041,643		Oil :	Tk391,479,794	Total :	Tk638,920,965
	Coal :	Tk82,399,528					

Load Shedding & Other Information

Area	Yesterday		Estimated Demand (S/S end)		Today		Rates of Shedding (On Estimated Demand)
	MW	0:00	MW	MW	Estimated Shedding (S/S end)	MW	
Dhaka	0	0:00	4098		0	0	0%
Chittagong Area	0	0:00	1395		0	0	0%
Khulna Area	0	0:00	1250		0	0	0%
Rajshahi Area	0	0:00	1129		0	0	0%
Cumilla Area	0	0:00	1020		0	0	0%
Mymensingh Area	0	0:00	823		0	0	0%
Sylhet Area	0	0:00	459		0	0	0%
Barisal Area	0	0:00	212		0	0	0%
Rangpur Area	0	0:00	635		0	0	0%
Total	0		11021		0		

Information of the Generating Units under shut down.

Planned Shut- Down

Forced Shut- Down

- 1) Barapukuria ST: Unit-1,2
- 2) Bibiyana #3
- 3) Ghorasal Unit-2,3,4,5.
- 4) Ashuganj unit-3,5
- 5) Bholo-225 MW GT-2
- 6) Kaptai-2,4,5
- 7) Raozan # 2
- 8) Sirajganj #1

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Comments on Power Interruption
a) Dohazari-Cox's Bazar 132 kV Ckt-2 was under shut down from 08:05 to 17:50 for D/W.	
b) Aminbazar-Mirpur 132 kV Ckt-2 was under shut down from 08:14 to 16:16 for D/W.	
c) Meghna-Shympur 230 kV Ckt-2 was under shut down from 09:12 to 16:50 for D/W.	
d) B.Baria 132/33 kV T-2 transformer was under shut down from 10:10 to 17:06 for C/M.	
e) Baghabari 132 kV Bus-1 was shut down at 10:35 for D/W.	
f) Sikalbaha-Dohazari 132 kV Ckt-1 tripped at 13:23 from both ends showing Dist. Z1,R at Sikalbaha end and Dist. Z2,R at Dohazari end and was switched on at 13:43.	
g) Ghorashal-Ashuganj 132 kV Ckt-1 tripped at 14:30 showing Dist. B,C at Ghorashal end and Dist. B,C at Ashuganj end and was switched on at 14:44.	
h) Comilla(N)-Chandraghona 132 kV Ckt-1 tripped at 16:36 showing Dist. A, auto recloser at Comilla(N) end and auto recloser at Chandraghona end and was switched on at 16:45.	
i) Maniknagar-Bangabhaban 132 kV Ckt-1 tripped at 17:31 showing pilot wire protection,main protection trip, trip Ckt supervision at Maniknagar end and was switched on at 18:36.	
j) Ashuganj-Ghorashal 132 kV Ckt-1 tripped at 21:55 from both ends showing Dist. B,C at Ashuganj end and Dist. B,C, remote protection at Ghorashal end and was switched on at 22:47.	
k) Ashuganj-Sirajganj 230 kV Ckt-2 tripped at 21:14 from both ends showing Dist. Z1,3-phase,122 Km,SOTF,AR block at Sirajganj end and Dist. Z1,3-phase,AR block at Ashuganj end.	
l) Kabirpur 132/33 kV T-2 transformer was under shut down from 05:42(07/7/2020) to 07:38 for C/M.	
m) Sylhet 132/33 kV T-1 transformer was shut down at 05:44(07/7/2020) for C/M.	About 25 MW power interruption occurred under Sylhet S/S area from 05:44(07/7/2020) to 06:48.
n) Kaptai unit-5 was shut down at 05:01(07/7/2020) for rotor support crack maintenance work.	
o) Meghnaghat 230 kV Bus-1 was shut down at 07:45(07/7/2020) for C/M.	

Sub Divisional Engineer
Network Operation Division

Executive Engineer
Network Operation Division

Superintendent Engineer
Load Despatch Circle