

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date : 2-Aug-20              |                                        |                       |                     |                  |                      |                  | Page -2             |
|------------------------------|----------------------------------------|-----------------------|---------------------|------------------|----------------------|------------------|---------------------|
| Sl. No.                      | Name of the Power Stations             | Producer              | Installed Capacity  | Present Capacity | Peak Hour Generation | Enerov Generated | Remarks             |
|                              |                                        |                       | Unit No. X Capacity | MW               | MW                   | MW               |                     |
| 1                            | Ghorasal TPP (Unit-1&2)                | PDB                   | 2*55                | 85               | 33                   | 650000           | Unit-2 Under maint. |
|                              | Ghorasal Repowered CCPP Unit-3         | PDB                   | 1*210               | 170              | 0                    | 0                | Under maint.        |
|                              | Ghorasal Repowered CCPP Unit-4         | PDB                   | 1*210               | 180              | 100                  | 3684000          | Gas shortage        |
|                              | Ghorasal TPP Unit-5                    | PDB                   | 1*210               | 190              | 0                    | 0                | Under maint.        |
| 2                            | Ghorasal 365 MW CCPP Unit-7            | PDB                   | 1*243+1*122         | 365              | 200                  | 6029055          | Gas shortage        |
| 3                            | Ghorashal 78.5 MW PP(MA)               | QRPP                  | 2*40                | 78               | 0                    | 0                | Gas shortage        |
| 4                            | Ghorashal 108MW PP (Regent)            | IPP                   | 34*3.35             | 108              | 0                    | 0                | Gas shortage        |
| 5                            | Haripur GTTP                           | SBU, PDB              | 2*32                | 20               | 0                    | 0                | Under maint.        |
| 6                            | Haripur 412 MW CCPP                    | EGCB                  | 1*273+1*139         | 412              | 0                    | 0                | Under maint.        |
| 7                            | Haripur 360MW CCPP(HPL)                | IPP                   | 1*235+1*125         | 360              | 322                  | 7978000          | Gas shoetage        |
| 8                            | Meghnaghat 450 MW CCPP(MPL)            | IPP                   | 2*150+1*150         | 450              | 450                  | 9566000          |                     |
| 9                            | Meghnaghat 100 MW(IEI)                 | QRPP                  | 12*8.9              | 100              | 100                  | 1598400          |                     |
| 10                           | Meghnaghat CCPP(Summit)                | IPP                   | 2*110+1*110         | 305              | 130                  | 3324713          |                     |
| 11                           | Madanganj 102 PP(Summit)               | QRPP                  | 6*17                | 100              | 80                   | 1571232          | Engine problem      |
| 12                           | Madanganj-55 MW PP (Summit)            | (IPP)                 | 3*17.08+1*11.3      | 55               | 15                   | 107306           | Low demand          |
| 13                           | Keraniganj 100 MW PP (Powerpac)        | QRPP                  | 8*13.45             | 100              | 0                    | 19428            | Reserve             |
| 14                           | Narshingdi 22 MW PP (Doreen)           | SIIPP, REB            | 8*2.90              | 22               | 16                   | 294660           | Engine problem      |
| 15                           | 210 MW Siddhirgonj TPP                 | PDB                   | 1*210               | 115              | 0                    | 0                | Under maint.        |
| 16                           | Siddhirgonj 2*120 MW GTTP              | EGCB                  | 2*105               | 210              | 160                  | 3652000          | Gas shortage        |
| 17                           | Siddhirgonj 100 PP(Dutch Bangla)       | QRPP                  | 12*8.9              | 100              | 91                   | 1088640          | Engine problem      |
| 18                           | Siddhirgonj 335 MW CCPP                | EGCB                  | 1*217+1*118         | 335              | 320                  | 7448076          |                     |
| 19                           | Gaznagar 102 MW PP (Summit)            | IPP                   | 12*9.924            | 102              | 102                  | 1000512          |                     |
| 20                           | Katpotti 52 MW PP (Sinha)              | IPP                   | 7*7.9               | 51               | 0                    | 0                | Fuel Shortage       |
| 21                           | Kamalaghat 54 MW PP(Banco Energy)      | IPP                   | 3*18                | 54               | 35                   | 318240           | Low demand          |
| 22                           | Kodda 150MW PP                         | BPDB-RPCL             | 9*17.06             | 149              | 133                  | 712800           | Low demand          |
| 23                           | Manikganj 55 MW PP (Northern)          | IPP                   | 3*19.3              | 55               | 55                   | 274756           |                     |
| 24                           | Nababganj 55 MW PP (Southern power )   | IPP                   | 3*19.3              | 55               | 17                   | 202204           | Low demand          |
| 25                           | Bosila 108MW PP(CLC)                   | IPP                   | 12*8.775+1*3.5      | 108              | 0                    | 0                | Fuel Shortage       |
| 26                           | Summit Power (Madhabadi+Ashulia)       | SIIPP, REB            | 3*3.67+4*8.73       | 80               | 47                   | 914100           | Engine problem      |
| 27                           | Masana 33 MW PP(Summit)                | SIIPP, REB            | 4*8.73              | 33               | 33                   | 690700           |                     |
| 28                           | Rupganj 33 MW PP(Summit)               | SIIPP, REB            | 4*8.73              | 33               | 23                   | 548600           | Engine problem      |
| 29                           | Gazipur 52 MW PP                       | IPP                   | 6*8.9               | 52               | 51                   | 237540           |                     |
| 30                           | Tongi 80 MW GTTP                       | PDB                   | 1* 105              | 105              | 0                    | 0                | Under maint.        |
| 31                           | Kodda 300 MW PP Unit-2 (Summit)        | IPP                   | 18*17.076           | 300              | 260                  | 1967127          | Low demand          |
| 32                           | Keraniganj 300 MW PP (APR)             | IPP                   | 256*1.4             | 300              | 229                  | 642322           | Low demand          |
| 33                           | Bramhangaoan 100 MW PP (Aggreko)       | IPP                   | 100                 | 100              | 0                    | 0                | Reserve             |
| 34                           | Aurashah 100MW PP (Aggreko)            | IPP                   | 0.85*23+0.95*91     | 100              | 0                    | 0                | Reserve             |
| 35                           | Kodda 149 MW PP Unit-1 (Summit)        | IPP                   | 149                 | 149              | 149                  | 2806560          |                     |
| 36                           | Gazipur 100 MW PP                      | RPCL                  | 100 MW              | 105              | 88                   | 427884           | Low demand          |
|                              | Meghnaghat 104 MW PP (OPCL)            | IPP                   | 18*5*6              | 104              | 104                  | 1937280          |                     |
| <b>Dhaka area Total</b>      |                                        |                       |                     | <b>5895</b>      | <b>3343</b>          | <b>59683135</b>  |                     |
| 37                           | Chattogram TPP-1                       | PDB                   | 1*210               | 180              | 90                   | 2100000          | Gas shortage.       |
|                              | Chattogram TPP-2                       | PDB                   | 1*210               | 180              | 0                    | 0                | Gas shortage.       |
| 38                           | Raozan 25 MW PP                        | IPP                   | 3*8.9               | 25               | 8                    | 100951           | Low demand          |
| 39                           | Teknaf 20MW PP (Solartech)             | Teknaf Solaratech Ene | 20                  | 20               | 0                    | 97065            |                     |
| 40                           | Patenga 50MW PP (Baraka)               | IPP                   | 8*6.98              | 50               | 13                   | 115680           | Low demand          |
| 41                           | Kaptai Hydro. Unit-1,2,3,4, 5          | PDB                   | 2*40+3*50           | 230              | 143                  | 3369436          | Low water level     |
| 42                           | Sikalbaha 225MW                        | PDB                   | 1*150+1*175         | 225              | 0                    | 0                | Under S/D.          |
| 43                           | Sikalbaha Peaking GT                   | PDB                   | 1*150               | 150              | 139                  | 3032490          |                     |
| 44                           | Sikalbaha 105 MW PP (Baraka Sikalbaha) | IPP                   | 105 MW              | 105              | 0                    | 21745            | Reserve             |
| 45                           | Hathazari 100 MW peaking PP            | PDB                   | 11*8.9              | 98               | 0                    | 0                | Under maint.        |
| 46                           | Dohazari -Kalaish 100 MW Peaking       | PDB                   | 6*17                | 102              | 85                   | 506971           |                     |
| 47                           | Juldah 100 MW Unit-1 (Acom)            | QRPP                  | 8*13.45             | 100              | 0                    | 0                | Reserve             |
| 48                           | Juldah 100 MW PP Unit-3 (Acom)         | IPP                   | 0                   | 100              | 100                  | 2378880          |                     |
| 49                           | Barabkundia 22 MW PP (Regent)          | SIIPP, PDB            | 8*2.90              | 22               | 21                   | 448896           |                     |
| *                            | Malancha, Ctg. EPZ (United)            |                       | 5*8.73+9*3.4        | 0                | 0                    | 407870           |                     |
| 50                           | Chattogram 108 MW PP (ECPPV)           | IPP                   | 16*7                | 108              | 84                   | 440184           | Engine problem      |
| 51                           | Kaptai 7 MW Solar PP                   | PDB                   | 7.4 MW              | 7                | 0                    | 36960            |                     |
| 52                           | Anwara 300 MW PP (United)              | IPP                   | 300 MW              | 300              | 307                  | 5788473          |                     |
| 53                           | Jodiac Power                           | IPP                   | 3*18.55+1*3.6       | 54               | 17                   | 116819           | Low demand          |
| 54                           | Karnaphuli Power Ltd.                  | IPP                   | 110                 | 110              | 0                    | 0                | Reserve             |
|                              | Juldah unit-2 (Acom)                   | IPP                   | 8*13.6              | 100              | 100                  | 2302080          |                     |
| <b>Chattogram area Total</b> |                                        |                       |                     | <b>2266</b>      | <b>1107</b>          | <b>21264500</b>  |                     |
| 55                           | Ashuganj TPP Unit-3                    | APSCL                 | 1*150               | 129              | 0                    | 0                | Gas shortage.       |
|                              | Ashuganj TPP Unit-4                    | APSCL                 | 1*150               | 129              | 80                   | 1986895          | Gas shortage        |
|                              | Ashuganj TPP Unit- 5                   | APSCL                 | 1*150               | 134              | 0                    | 0                | Gas shortage.       |
| 56                           | Ashuganj 225 MW CCPP                   | APSCL                 | 1*142+1*75          | 221              | 176                  | 4195000          | FGMO                |
| 57                           | Ashuganj 450 MW CCPP(North)            | APSCL                 | 1*360               | 360              | 250                  | 7130000          | FGMO                |
| 58                           | Ashuganj 450 MW CCPP(South)            | APSCL                 | 1*360               | 360              | 240                  | 6671000          | FGMO                |
| 59                           | Ashuganj 50 MW PP                      | APSCL                 | 14*3.968            | 45               | 10                   | 524880           | Engine problem      |
| 60                           | Ashuganj 55 MW PP (Precision)          | RPP                   | 15*4                | 55               | 5                    | 514080           | Gas shortage        |
| 62                           | Ashuganj 195MW PP (APSCL-United)       | IPP                   | 20*9.73+1*16        | 195              | 8                    | 200727           | Gas shortage.       |
| 63                           | Ashuganj 51 MW PP (Midland)            | IPP                   | 8*9.34              | 51               | 51                   | 1259174          |                     |
| 64                           | Ashuganj 150MW PP (Midland)            | IPP                   | 23*10.15            | 150              | 127                  | 612218           | Low demand          |
| 66                           | Titas 50 MW Peaking PP                 | PDB                   | 8*9.92              | 52               | 0                    | 0                | Reserve             |
| 67                           | Chandpur 150 MW CCPP                   | PDB                   | 1*106+1*57          | 163              | 90                   | 2088970          | ST under maint.     |
| 68                           | Chandpur 200MW (Desh energy)           | IPP                   | 0                   | 200              | 181                  | 876000           | Low demand          |
| 69                           | Feni 22MW PP (Doreen)                  | SIIPP, PDB            | 8*2.90              | 22               | 21                   | 489564           |                     |
| 70                           | Feni 11 MW PP (Doreen)                 | SIIPP, REB            | 4*2.90              | 11               | 11                   | 234900           |                     |
| **                           | Imporprt (Tripura)                     | Imported power        | 0                   | 160              | 128                  | 2834880          |                     |
| 71                           | Jangalia 33MW PP (Summit)              | SIIPP, PDB            | 4*8.73              | 33               | 33                   | 805600           |                     |
| 72                           | Jangalia 52 MW PP (Lakdanavi)          | IPP                   | 8*8.92              | 52               | 52                   | 1156166          |                     |
| 73                           | Cumilla 25 MW PP (Summit)              | SIIPP, PDB            | 3*3.67+2*6.97       | 25               | 22                   | 423990           |                     |
| 74                           | Daudkandi 200 MW PP (B.Trac)           | IPP                   | 154*1.4             | 200              | 0                    | 0                | Reserve             |
|                              | Feni Lanka Power                       | IPP                   | 7*18.415+1*9.78     | 114              | 114                  | 899460           |                     |
|                              | Chowmuhani 113 MW                      | IPP                   | 12*9.78+2*3.1       | 113              | 0                    | 1630440          | Reserve             |
| <b>Cumilla Area Total</b>    |                                        |                       |                     | <b>2980</b>      | <b>1599</b>          | <b>34535944</b>  |                     |
| 75                           | RPCL 210MW CCPP                        | IPP                   | 4*35+1*70           | 202              | 88                   | 3148120          | Gas shortage.       |
| 76                           | Tangal 22 MW PP (Doreen)               | SIIPP, PDB            | 8*2.90              | 22               | 17                   | 369792           | Engine problem      |
| 77                           | Jamalpur 95 MW PP(Powerpac)            | IPP                   | 12*8.924            | 95               | 95                   | 1610880          |                     |
| 78                           | Sarishabari 3 MW Solar Plant           | IPP                   | 1*3                 | 3                | 0                    | 16850            |                     |
| 79                           | Mymensingh 200 MW PP (United)          | IPP                   | 200                 | 200              | 200                  | 4711200          |                     |
| 80                           | Jamalpur 115 MW PP (United)            | IPP                   | 115 MW              | 115              | 115                  | 1140000          | #REF!               |
| <b>Mymensingh Area Total</b> |                                        |                       |                     | <b>637</b>       | <b>515</b>           | <b>10996842</b>  |                     |
| 81                           | Fenchugonj CCPP Phase-1                | PDB                   | 2*32+1*33           | 70               | 61                   | 1447000          |                     |
| 82                           | Fenchugonj CCPP Phase-2                | PDB                   | 2*35+1*35           | 90               | 30                   | 719760           | # 4 under maint.    |
| 83                           | Kushiaira 163 MW CCPP (KP)             | IPP                   | 1*109+1*54          | 163              | 130                  | 3328936          |                     |
| 84                           | Shajibazar 330 MW CCPP                 | PDB                   | 3*110               | 330              | 152                  | 4516000          |                     |
| 85                           | Fenchugonj 51 MW PP (Barakatullah)     | RPP                   | 19*2.90             | 51               | 53                   | 1237800          |                     |
| 86                           | Fenchugonj 44MW (Energyprima)          | RPP                   | 12*3.3+5*2          | 44               | 47                   | 1127088          |                     |
| 87                           | Hobiganj 11MW PP Confidence-E          | SIIPP, REB            | 4*2.90              | 11               | 11                   | 264000           |                     |
| 88                           | Shajibazar GTTP Unit. 8 & 9            | PDB                   | 2*35                | 68               | 61                   | 1421472          | FGMO                |
| 89                           | Shajibazar 86MW PP (Shajibazar)        | RPP                   | 32*2.90             | 86               | 50                   | 1715520          |                     |
| 91                           | Sylhet 225 MW CCPP                     | PDB                   | 1*142+1*89          | 231              | 0                    | 0                | Under maint.        |
| 92                           | Sylhet 20 MW GTTP                      | PDB                   | 1*20                | 20               | 18                   | 410000           |                     |
| 93                           | Sylhet 50MW PP (EPL)                   | RPP                   | 27*2                | 50               | 0                    | 0                | Contract Expired    |
| 94                           | Shahjahanulla 25 MW PP                 | SIIPP, REB            | 3*9.34              | 25               | 20                   | 458445           |                     |
| 95                           | Biliana-II 341 MW CCPP (Summit)        | IPP                   | 1*222+1*119         | 341              | 0                    | 0                | FGMO                |
| 96                           | Bilayana-II 400 MW CCPP                | REB                   | 400 MW              | 400              | 0                    | 0                | Under maint.        |
| 97                           | Sylhet 10MW PP (Desh)                  | RPP                   | 6*1.95              | 10               | 9                    | 232920           |                     |
|                              | Bilayana South 400 MW                  | PDB                   | 400 MW              | 0                | 0                    | 0                | On test             |
| <b>Sylhet Area Total</b>     |                                        |                       |                     | <b>1988</b>      | <b>642</b>           | <b>16878941</b>  |                     |
| 98                           | Bheramara GTTP Unit-3                  | PDB                   | 1*20                | 16               | 0                    | 0                | Reserve             |
| **                           | Bheramara (HVDC)                       | Imported power        | 2*500               | 1000             | 937                  | 22533091         |                     |
| 99                           | Khulna 115 PP MW (KPCL-2)              | QRPP                  | 7*17                | 115              | 115                  | 2584320          |                     |
| 100                          | Faridpur 50 MW Peaking PP              | PDB                   | 8*6.89              | 54               | 0                    | 0                | Reserve             |
| 101                          | Khulna 225 MW CCPP                     | NWPGCL                | 1*150+1*75          | 230              | 0                    | 0                | Reserve             |
| 102                          | Gopalganj 100 MW Peaking PP            | PDB                   | 1*98                | 109              | 0                    | 0                | Reserve             |
| 103                          | Bheramara 410 MW CCPP                  | NWPGCL                | 1*278+1*132         | 410              | 265                  | 8079840          | FGMO                |
| 104                          | Noapara 40 MW PP (Khanjahan Ali)       | QRPP                  | 5*8.5               | 40               | 40                   | 611625           |                     |
| 105                          | Noapara 100 MW PP (Bangla Trac)        | IPP                   | 70*1.4              | 100              | 100                  | 683520           |                     |
| 106                          | Rupsha 105 MW PP (Orion rupsha)        | IPP                   | 6*18.445            | 105              | 105                  | 705600           | Engine problem      |
| 107                          | Madhumati 100 MW PP                    | IPP                   | 100 MW              | 105              | 0                    | 13680            | Reserve             |
| <b>Khulna Area Total</b>     |                                        |                       |                     | <b>2284</b>      | <b>1562</b>          | <b>35211676</b>  |                     |
| 108                          | Barisal 110 MW PP (Summit )            | IPP                   | 7*17.076            | 110              | 110                  | 1519680          |                     |
| 110                          | Bhola 33 MW PP (Venture)               | RPP                   | 1*34.50             | 33               | 41                   | 830082           |                     |
| 111                          | Bhola 225 MW CCPP                      | PDB                   | 2*63+1*68           | 194              | 65                   | 1553000          | GT-2 Under maint.   |
| 112                          | Bhola 95 MW PP (Aggreko)               | QRPP                  | 95*1.10             | 95               | 78                   | 1860842          | Engine problem      |
|                              | Payra 1320 MW                          | BCPCL                 | 1*622               | 622              | 577                  | 12153900         |                     |
| <b>Barisal Area Total</b>    |                                        |                       |                     | <b>1054</b>      | <b>871</b>           | <b>17917504</b>  |                     |
| 113                          | Baghabari 71 MW GTTP                   | PDB                   | 1*71                | 71               | 0                    | 0                | Gas shortage.       |
|                              | Baghabari 100 MW GTTP                  | PDB                   | 1*100               | 100              | 0                    | 0                | Gas shortage.       |
| 114                          | Baghabari 50 MW Peaking PP             | PDB                   | 6*8.9               | 52               | 50                   | 261888           |                     |
| 115                          | Bera 70 MW Peaking PP                  | PDB                   | 9*8.29              | 71               | 0                    | 0                | Reserve             |
| 116                          | Ammura 50 MW PP(Sinha)                 | QRPP                  | 7*7.79              | 50               | 0                    | 0                | Fuel shortage       |
| 117                          | Katakhali 50 MW PP (Northern)          | QRPP                  | 6*8.9               | 50               | 16                   | 74940            | Low demand          |
| 118                          | Katakhali 50 MW Peaking PP             | PDB                   | 3*7.7               | 50               | 37                   | 233370           |                     |
| 119                          | Sirajgonj Unit-1 225MW                 | NWPGCL                | 1*150+1*75          | 210              | 0                    | 0                | Gas shortage.       |
| 120                          | Sirajgonj Unit-2 225MW                 | NWPGCL                | 1*150+1*75          | 220              | 0                    | 2978391          | Gas shortage        |
| 121                          | Sirajgonj Unit-3 225MW                 | NWPGCL                | 1*141               | 220              | 187                  | 4640955          | FGMO                |
| 122                          | Sirajgonj 400 MW CCPP Unit-4           | SNWPGCL               | 1*282+1*132         |                  |                      |                  |                     |