DAILY REPORT DAILY REPORT The opting Date : 9-Aug-20 Till now the maximum generation is :- 12893 MW 21:00 Hrs on 29-May-19 The Summary of Yesterday's 8-Aug-20 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation Security Securit	Page -1
The Summary of Yesterday's 8-Aug-20 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation : 9665.7 MW 12:00 Min. Gen. at 8:00 9079 MW Evening Peak Generation : 12023.0 MW 21:00 Available Max Generation 14702 MW E.P. Demand (at gen end) : 12023.0 MW 21:00 Max Demand (Evening) : 12400 MW Maximum Generation : 12023.0 MW 21:00 Reserve(Generation end) 2302 MW Total Gen. (MKWH) : 246.8 System Load Factor 85.52% Load Shed : 0 MW Export from East grid to West grid :- Maximum -39 MW at 1:00 Energy MKWHR.	
Day Peak Generation 9665.7 MW 12:00 Min. Gen. at 8:00 9079 MW Evening Peak Generation 12023.0 MW 21:00 Available Max Generation 14702 MW E.P. Demand (at gen end) 12023.0 MW 21:00 Max Demand (Evening) 12420 MW Maximum Generation 1 12023.0 MW 21:00 Mexerve(Generation end) 12202 MW Total Gen. (MKWH) 246.8 System Load Factor 85.52% Load Shed 0 MW Export from East grid to West grid :- Maximum -39 MW at 1:00 Energy MKWHR.	
E.P. Demand (at gen end): 12023.0 MW 21:00 Max Demand (Evening): 12400 MW Maximum Generation: 12023.0 MW 21:00 Reserve(Generation end) 2302 MW Total Gen. (MKWH): 246.8 System Load Factor 185.52% Load Shed 0 MW Export from East grid to West grid:- Maximum EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR -39 MW at 1:00 Energy MKWHR.	
Maximum Generation 12023.0 MW 21:00 Reserve(Generation end) 2302 MW Total Gen. (MKWH) 246.8 System Load Factor 85.52% Load Shed 0 MW Export from East grid to West grid :- Maximum -39 MW at 1:00 Energy MKWHR.	
Total Gen. (MKWH) 246.8 System Load Factor : 85.52% Load Shed : 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR -39 MW at 1:00 Energy MKWHR.	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -39 MW at 1:00 Energy MKWHR.	
Import non west grid to East grid - Maximum - Mix which are - Energy - Mix which	
Water Level of Kaptai Lake at 6:00 A M on 9-Aug-20	
Actual : 94.64 Ft.(MSL), Rule curve : 91.56 Ft.(MSL)	
Gas Consumed : Total = 1145.11 MMCFD. Oil Consumed (PDB) :	
HSD : Liter	
FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) : Gas : Tk161,657,008	
: Coal : Tk75,339,846 Oil : Tk508,192,487 Total : Tk745,189,342	
Load Shedding & Other Information	
Area Yesterday Today	
Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding	
MW MW (On Estimated Demand)	
Dhaka 0 0:00 4406 0 0% Chittagong Area 0 0:00 1502 0 0%	
Chittagong Area 0 0:00 1502 0 0% Khulna Area 0 0:00 1346 0 0%	
Rajshahi Area 0 0:00 1217 0 0 0%	
Cumilla Area 0 0:00 1099 0 0%	
Mymensingh Area 0 0:00 887 0 0% Sylhet Area 0 0:00 492 0 0%	
Barisal Area 0 0.00 228 0 0 0%	
Rangpur Area 0 0:00 684 0 0%	
Total 0 11861 0	
Information of the Generating Units under shut down.	
Planned Shut- Down Forced Shut- Down 10) Haripur-412 MW.	
1) Barapukuria ST: 11) Baghabari-1,2	
2) Bibiyana #3	
3) Ghorasal Unit-2,3,	
4) Ashuganj unit-3	
5) Bhola-225 MW GT-2 & ST	
6) Kaptai-2	
7) Raozan #1,2	
8) Sirajganj #1	
9) Sylhet-225 MW.	
Additional Information of Machines, lines, Interruption / Forced Load shed etc.	
Description Comments on Power Interruption	
a) Madunaghat 132/33 kV T1 transformer was shut down from 11:06 to 12:58 for C/M.	
b) Ranganj 132/33 kV T2 transformer was shut down from 09:16 to 11:05 for C/M. About 12 MW power interruption occurred under Ranganj	S/S area
from 09:16 to 11:05.	
c) Faridpur 132/33 kV T2 transformer was under shut down from 11:25 to 12:26 due to oil leakage maintenance About 35 MW power interruption occurred under Faridpur 1	S/S area
of B-phase CT. from 11:25 to 12:26.	
d) Madunaghat-Chandraghona 132 kV Ckt-2 tripped at 12:05 from both end showing dist Z1 from both end	
and was switched on at 12:17.	
e) After maintenance Ghorasal #04 was synchronized at 10:19.	
f) Khulna(S)-Khulna© 132 kV Ckt-1 was shut down from 12:45 to 15:57 for protection test at Khulna(S) end.	
g) Jhenaidah 132/33 kV T1 transformer was shut down from 14:28 to 17:04 due to red hot maintenance at About 36 MW power interruption occurred under Jhenaidal	s/S area
33 kV incoming isolator. from 14:28 to 17:04.	
h) Ruppur 132/33 kV T1 transformer was shut down from 12:19 to 14:50 for measurement of earth resistance.	
i) Ruppur 132/33 kV T2 transformer was shut down from 14:56 to 15:18 for measurement of earth resistance.	
j) Ashuganj Modular tripped at 20:13 showing E/F relay at the same time Ashuganj Midland 150 MW,	
Ashuganj Midland 51 MW are got tripped .	
k) Netrokona 132/33 kV T1 transformer is under shut down since 07:02 for C/M. About 05 MW power interruption occurred under Netrokona	s/S area
since 07:02 to till now.	
I) Natore 132/33 kV T2 transformer under 33 kV CB was shut down from 07:13 to 08:47 for red hot maintenance	
at 33 kV bushing.	
m) After maintenance Meghnaghat Summit GT-1 was synchronized at 07:29.	
Sub Divisional Engineer Executive Engineer Superintendent Engineer	
Network Operation Division Load Despatch Circle	