



Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551995

Month August, 2020				Day : Monday				Date : 17.08.20				
Probable Maximum Demand : 11900 MW				Probable Maximum Generation : 14887 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 94.17 ft				Today = 94.05 ft				
				Rule Curve = 94.12 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.08.20 (Yesterday)		17.08.20 (Today)		16.08.20 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	28	28	28	28		57	Unit 2 under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under maint.
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80		Gas Shortage
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	99	98	98	9		Gas Shortage
4	Ghorasal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	78	68	69	78	78	9		Gas Shortage
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	347	353	360	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	420	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under maint.
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	295	265	330	330			
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	90	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	305	260	305	305			
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	7	7	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	80	80	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	39	55	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	50	100	100			
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	85	93	85	93			
20	Narsingdi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	22	22	22	22			
21	Summit Power, (Madhadi-Ashulia)	Gas (SIIPP, REB)	6x3.67+1x8.73	80	80	53	55	55	55			
22	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	33	33	33	33			
23	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	33	33	33	33			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	35	50			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	34	100	100			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	32	149	149	149			
27	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	47	49	50			
28	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	53	53	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	224	272	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	123	131	131	131			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x1.4	300	300	0	0	100	300			
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	80	100			
34	Nababganj 55 MW PP (Southern p	HFO (IPP)	3x19.3	55	55	0	55	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
36	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	90	104	104			
Dhaka Zone Total				6119	5895	2629	3018	3704	3998	433	1299	
38	Karnaphuli Hydro PP Unit-1,2,3,4,	Hydro (PDB)	2x40, 3x50	230	230	156	155	154	154	75		Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2.9	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25			
42	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	0	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	4	50	50	50			
44	Sikalbaha 105 MW PP (Baraka Sil)	HFO (IPP)	6x18.415	105	105	0	0	100	100			
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	0	100			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	164	164	165	165			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	225	178	300	300			
48	Juidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100			
49	Juidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
50	Dohazari -Kalaish 100 MW Peakin	HFO (PDB)	6x17.0	102	102	0	85	100	100			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	18	18	18	18			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	15	10	25			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	91	97	97			
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	50	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	50	110			
56	Juidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
Chattogram Zone Total				2326	2266	971.9	1174	1554	1708	75	180	
57	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	80	80	129	129	49		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	36	38	38			
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	193	199	220	220			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	285	280	360	360			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	290	360	360			
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	5	20	20			
63	Ashuganj 195MW PP (APSCL)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8			
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	8	100	150	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	42			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	96	86	90	96			
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	15	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	21	21	22	22			
70	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	8	8	11	11			
71	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	0	25	25	25			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	41	43	43			
73	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	15	20	20	20			
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x1.4+40x1.515+15x1.05	200	200	0	0	0	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	50	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	21	57	60	60			
**	Impoport (Tripura)	India		160	160	112	136	163	173			
Cumilla Zone Total				3040	2980	1286	1508	2084	2342	318	0	
77	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	153	126	157	157			
78	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	20	20	20	20			
79	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	32	73	72	72			
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	88	115	115			
81	Myemensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	185	200	200	200			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	0	0	1.6	0			
Myemensingh Zone Total				645	637	390.8	507	565.6	564	0	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.08.20 (Yesterday)		17.08.20 (Today)		16.08.20 (Yesterday)		Status of Machines under shut-down/ Maintenance							
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :									
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date						
83	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	86	87	88	88										
84	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30	60		GT-4 Under maint.							
85	Fenchugonj 51 MW PP (Barakatalui	Gas (RPP)	19x2.90	51	51	50	53	51	51										
86	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	48	48	48	48										
87	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163										
88	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	5	11	11	11										
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	61	61	66										
90	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	201	194	210	210										
91	Shahjibazar 86MW PP (Shahjibaz)	Gas (RPP)	32x2.90	86	86	85	85	86	86										
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	80	0	80	80										
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18										
94	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0										
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	0	10	10										
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	0	25	25										
97	Bibiana-II 341 MW CCPP (Summit	Gas (IPP)	1x222+1x119	341	341	310	270	341	341										
98	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Under maint.							
	Bibiyan South 400 MW	Gas (PDB)				0	0	0	0										
Sylhet Zone Total				2033	1988	1173	1020	1222	1227	0	460								
99	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16										
100	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	345	345	410	410										
101	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30										
102	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60										
103	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	120	200	180	225										
104	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	99	103	115	115										
105	Noapara 100 MW PP (Bangla Trac	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	60	100										
106	Noapara 40 MW PP (Khanjahan Al	HFO (QRPP)	5x8.5	40	40	0	40	40	40										
107	Rupsha 105 MW PP (Orion rupsha	HFO (IPP)	6x18.445	105	105	0	53	90	90										
108	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100										
**	Bheramara (HVDC)	India		1000	1000	914	913	924	924										
Khulna Zone Total				2288	2284	1478	1704	1919	2110	0	105								
109	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	80	110	110										
110	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	22	33	33										
111	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	90	89	89	89	105		GT-2 Under maint.							
112	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	79	77	76	76										
113	Payra 1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	304	592	600	600										
Barishal Zone Total				1054	1054	519	860	908	908	0	105								
114	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage							
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	65	0	70	70	100		Gas Shortage							
115	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	43										
116	Baghabari 200 MW PP (Paramoun	HSD (IPP)	135x1.6	200	200	0	0	200	200										
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	35	0	40										
118	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0										
119	Chapainawabganj 100 MW Peakin	HFO (PDB)	12x8.924	104	104	0	98	100	100										
120	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	47	0	45										
121	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	50	50										
122	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	35										
123	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage							
124	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150 + 1x75	220	220	193	178	220	220										
125	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	180	214	220	220										
126	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	408	414	414	414										
127	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	17	22	22										
128	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	11	11	10	10										
129	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	0	11	10	10										
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	39	52	52										
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	50	109	113	113										
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	43	113	113										
Rajshahi Zone Total				2193	2183	924	1300	1594	1757	381	0								
133	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage							
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage							
134	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	149	150	150										
135	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0										
136	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	106	113	113										
137	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10										
138	Majpara, Tatalia 8 MW Solar PP (Sympa I	Solar (IPP)	1 x 8	8	8	6	0	8	0										
Rangpur Zone Total				685	605	156	255	271	273	170	0								
Sub-total: Plants in operation				20383	19892	9527.7	11346	13822	14887	1377	2044								
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9258	11025	13431	14466										
(B) Contract expired power plants																			
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0										
Gross Total				20383	19892	9528	11346	13822	14887	1377	2044								
(C) Actual data of 16.08.20 (Yesterday) Sunday :																			
01.	Max. Demand (Generation end)	:	11346.00	MW, at = 20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :													
02.	Max. Demand (Sub-station end)	:	11025.00	MW, at = 20:00 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed						
03.	Highest Generation (Generation end)	:	11450.00	MW, at = 22:00 hrs		MW	MW	MW	MW	MW	MW	MW	MW						
04.	Minimum Generation (Generation end)	:	7835.20	MW, at = 7:00 hrs		Dhaka	3772	3772	0	Mymensingh	946	946	0						
05.	Day-peak Generation (Generation end)	:	9527.70	MW, at = 12:00 hrs		Chattogram	1039	1039	0	Sylhet	499	499	0						
06.	Evening-peak Generation (Generation end)	:	11346.00	MW, at = 20:00 hrs		Khulna	1444	1444	0	Barishal	307	307	0						
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 20:00 hrs		Rajshahi	1241	1241	0	Rangpur	763	763	0						
08.	Actual Minimum Generation up to 8:00 hrs.	:	8409.87	MW, at = 7:00 hrs and		Cumilla	1014	1014	0										
09.	Generation shortfall at evening peak due to :	:				Total		11025	11025	0									
	a) Gas limitation	:	1132	MW	13.	Fuel cost :		(a) Gas = 156466386 Taka	(c) Coal = 71265171 Taka										
	d) Coal supply Limitation	:	170	MW		(b) Oil = 420595621 Taka		Total = 648327178 Taka											
	b) Low water level in Kaptai lake	:	75	MW	14.	Maximum Temperature in Dhaka was : 31° C													
	c) Plants under shut down/ maintenance	:	2044	MW	15.	Export through East-West interconnections :													
10.	Total Energy (Generation + India Import)	:	233.96	MKWh		At evening peak-hour		215	MW, at 20:00 hrs										
	By Gas = 133.810 MKWh			56.117 MKWh		Maximum		41	MW, at 19:00 hrs										
	By Coal = 15.371 MKWh			3.677 MKWh		Energy		0.013	MKWh										
	By Solar= 0.097 MKWh																		
11.	Total Gas Supplied	:	1127.71	MMCFD															
(D) Forecast of 17.08.20 (Today) Monday :																			
01.	Maximum Demand	:	11900	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)													
02.	Maximum Generation	:	14887	MW (Generation end)	05.	Total Generation : 243.15 MKWh													
03.	Maximum Shortage	:	-2987	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 31.4° C													
* Captive Power ** Imported Power																			
#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00																			
(Fazoul Islam Shaker) Deputy Secretary, Generation																			