

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS								
Date :		24-Aug-20		Page -2				
Sl No.	Name of the Power Stations	Producer	Installed Capacity	Capacity	Present	Peak Hour	Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB		85	28		549000	Unit-1 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0		0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0		0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	110		2709000	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0		0	Under maint.
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	64		1513120	Engine problem
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	94		2244154	Engine problem
5	Haripur GTPP	SBU, PDB	2*32	20	0		0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	341		8594430	Engine maint.
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	325		7643000	FGMO
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450		9062450	Frequency control.
9	Meghnaghat 100 MW(IEI)	QRPP	12*8.9	100	100		2215680	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	130		3461876	GT-1 Under S/D.
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	0		1805664	tripped at 18:07
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55		1093403	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	100		805050	
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19		201828	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0		0	Under maint.
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0		0	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	95		2088960	
18	Siddhirganj 335 MW CCPP	EGCB	1*217+118	335	0		0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	66		1993104	Engine problem
20	Katpali 52 MW PP (Sinha)	IPP	7*7.9	51	0		549984	tripped at 18:20
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53		1189800	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	149		2855040	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55		1180445	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55		904577	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0		0	Fuel Shortage
26	Summit Power,(Madhabadi+Ashulia)	SIPP,REB	3*3.67+4*8.73	80	49		1261320	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33		814200	
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33		711800	
29	Gazipur 52 MW PP	IPP	6*8.9	52	52		329496	
30	Tongi 80 MW GTTP	PDB	1* 105	105	0		0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	289		6265198	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	306		1293316	
33	Bramhangaoan 100 MW PP (Aggreko)	IPP	100	100	80		195224	Low demand
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	82		448512	Low demand
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	0		1942560	Engine problem
36	Gazipur 100 MW PP	RPCL	100 MW	105	105		1497828	
	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	17		432960	Fuel Shortage
Dhaka area Total				5895	3335		67851359	
37	Chattogram TPP-1	PDB	1*210	180	0		0	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0		0	Gas shortage.
38	Raczan 25 MW PP	IPP	3*8.9	25	25		383662	
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Ene	20	20	0		98010	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50		854400	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	75		1738040	Low water level
42	Sikalbaha 225MW	PDB	1*150+1*175	225	111		3093664	Machine problem
43	Sikalbaha Peaking GT	PDB	1*150	150	104		2835576	Gas shortage.
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0		0	Reserve
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0		0	Under maint.
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	102		801028	
47	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	60		481440	Low demand
48	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100		2377920	
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20		445968	
*	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	23		540480	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	97		1669440	Engine problem
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0		29761	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	307		6194945	
53	Jodiac Power	IPP	3*18.55+1*3.6	54	0		5315	Transformer O/L
54	Karnaphuli Power Ltd.	IPP	110	110	0		0	Transformer O/L
	Juldah unit-2 (Acorn)	IPP	8*13.6	100	100		2344320	
Chattogram area Total				2266	1174		23893969	
55	Ashuganj TPP Unit- 3	APSCL	1*150	135	0		0	Gas shortage.
	Ashuganj TPP Unit-4	APSCL	1*150	129	70		1682150	Gas shortage.
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0		0	Gas shortage.
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	145		3447000	Gas shortage
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	280		6751100	Gas shortage
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	180		4874000	Gas shortage
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	5		140976	Gas shortage.
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	0		0	Gas shortage.
62	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8		217454	Gas shortage.
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51		1259303	
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	50		650690	L/O.
65	Titas 50 MW Peaking PP	PDB	6*9.92	52	42		434696	
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	96		2273510	ST under maint.
68	Chandpur 200MW (Desh energy)	IPP	0	200	200		1548000	
69	Ferit 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	0		392328	tripped at 18:38
70	Ferit 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	0		169560	tripped at 18:38
**	Impoport (Tripura)	Imported power	0	160	148		3257280	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33		669000	Engine problem
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	43		717278	Engine problem
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*9.7	25	20		472890	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	150		401664	Low demand
	Ferit Lanka Power	IPP	7*18.415+1*9.78	114	114		1494540	
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	56		1250760	Fuel shortage
Cumilla Area Total				2980	1691		32104169	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	123		2993240	Engine problem
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17		354168	Engine problem
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	72		1728960	
78	Sanshabari 3 MW Solar Plant	IPP	1*3	3	0		13900	
79	Mymensingh 200 MW PP (United)	IPP	200	200	180		4288900	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115		1375200	#REF!
Mymensingh Area Total				637	807		10754268	
81	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	60		1423000	
82	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	28		722400	# 4 under maint.
83	Kushiaira 163 MW CCPP (KP)	IPP	1*109+1*54	163	110		3274363	Frequency control.
84	Shahibazar 330 MW CCPP	PDB	3*110	330	142		4176000	ST under maint.
85	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	50		1179000	
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.345*2	44	43		1030032	
87	Hobiganj 118MW PP Confidence-E	SIPP, REB	4*2.90	11	8		127000	Engine problem
88	Shahibazir GTTP Unit- 8 & 9	PDB	2*35	66	64		1421472	FGMO
89	Shahibazar 86MW PP (Shahibazar)	RPP	32*2.90	86	85		1981440	
91	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	80		1929240	Machine problem
92	Sylhet 20 MW GTTP	PDB	1*20	20	18		414000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	0		0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16		435542	
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	270		7301000	FGMO
96	Bibiyana-III 405 MW CCPP	PDB	400 MW	400	0		0	Under maint.
97	Sylhet 108MW PP (Desh)	RPP	6*19.95	10	9		234460	
	Bibiyana South 400 MW	PDB	400 MW	0	0		0	On test
Sylhet Area Total				1988	983		25638949	
98	Bheramara GTTP Unit-3	PDB	1*20	16	0		0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	932		22212364	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115		2722560	
100	Fairdip 50 MW Peaking PP	PDB	8*6.89	54	23		103200	Reserve
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	140		3421440	Frequency control.
102	Gopalganj 100 MW Peaking PP	PDB	6*6.98	109	0		9984	Reserve
103	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	340		8079640	FGMO
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	40		628875	
105	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100		522240	
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	105		1185600	
107	Madhumati 100 MW PP	IPP	100 MW	105	15		55584	Low demand
Khulna Area Total				2284	1810		38941687	
108	Barsal 110 MW PP (Summit)	IPP	7*17.076	110	48		413472	Low demand
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	13		463179	Engine problem
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	89		2165959	GT-2 Under maint.
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	77		1567191	Engine problem
	Paira 1320 MW	BCPCL	1*622	622	622		13023000	
Barisal Area Total				1054	849		17632981	
113	Baghabari 71 MW GTTP	PDB	1*71	71	0		0	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1*100	100	0		0	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50		605280	Under maint.
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	35		203876	
116	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50</				