POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER
DAILY REPORT QF-LDC-08 Reporting Date : 26-Aug-20 12893 MW
 Hrs
 on
 29-May-19

 Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at
 8:00
 8421 MW

 Available Max Generation
 14264 MW
 Fill now the maximum generation is: 25-Aug-20 **Gen** 10076.8 MW 11563.0 MW The Summary of Yesterday's
Day Peak Generation : Generation & Demand 12:00 Evening Peak Generation 19:30 E.P. Demand (at gen end) Max Demand (Evening) 11563.0 MW 19:30 12000 MW Maximum Generation 11563.0 MW 19:30 Reserve(Generation end) Total Gen. (MKWH) 248.7 ystem Load Factor : 89.60%

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Load Shed 0 MW Export from East grid to West grid :- Maximum 80 MW 2:00 Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on MKWHR MW Energy 26-Aug-20 Ft.(MSL) 97.20 Ft.(MSL) Rule curve Actual : 93.29 1040.35 MMCFD Oil Consumed (PDB): HSD Liter FΩ Liter Cost of the Consumed Fuel (PDB+Pvt) Tk142.319.363 Gas Tk72,966,924 : Tk702,605,066 Total: Tk917,891,353 **Load Shedding & Other Information** Yesterday Area Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW 4221 1437 Dhaka 0:00 0% 0% 0% 0% 0% 0% Chittagong Area Khulna Area 0 0:00 0:00 1288 Rajshahi Area 0 0:00 1164 0 Cumilla Area 0:00 1052 0 849 Mymensingh Area Sylhet Area 0 0:00 472 0% 0% Barisal Area 219 Rangpur Area 0:00

Information of the Generating Units under shut down.

Planned Shut- Down

Total

Forced Shut-Down

- 1) Barapukuria ST: Unit-1,2
 - 2) Bibiyana #3
 - 3) Ghorasal Unit-2,3,4,7
 - 4) Ashuganj unit-3,5
 - 5) Bhola-225 MW GT-2 & ST
 - 6) Kaptai-2,4,5
 - 7) Raozan #1.2
 - 8) Sirajganj #1
 - 9) Baghabari-71 & 100 MW

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description

Comments on Power Interruption

- a) Sherpur 132/33 kV T-3 transformer was switched on at 23:30 after replacing of CT.
- b) Aminbazar 230/132 kV T-3 transformer was under shut down from 08:54 to 18:28 for D/W.

c) Comilla(N) 132/33 kV T-4 transformer along with 33 kV Bus section of T-3 transformer was under shut of from 11:21 to 12:57 for C/M. d) Mongla 132/33 kV T-1 transformer was under shut down from 09:03 to 10:42 for R/H maintenance

About 10 MW power interruption occurred under Comilla(N) S/S area from 11:21 to 12:57. About 16 MW power interruption occurred under Mongla S/S area

from 09:03 to 10:42.

- e) Pabna-Shahjadpur 132 Ckt was under shut down from 10:03 to 10:42 for C/M.
- f) Ashugani-Ghorashal 132 kV Ckt-1 was under shut down from 09:47 to 12:28 for C/M.
- g) Barishal(N)-Barishal(S) 132 kV Ckt was under shut down from 10:32 to 11:11 for tree trimming.
- h)Kulaura 132/33 kV T-2 transformer was under shut down from 10:18 to 11:36 for C/M.
- i) Kulaura 132/33 kV T-1 transformer was under shut down from 10:20 to 11:37 for make it clear.
- j) Patuakhali 132/33 kV T-1 transformer was under shut down from 12:05 to 14:26 for C/M.
- k) Ruppur 132/33 kV T-2 transformer was shut down at 10:03 for C/M.
- I) Rajshahi S/S-Katakhali Peaking Plant 132 kV Ckt was under shut down from 09:45 to 12:27 for C/M.
- m) Chandraghona 132/33 kV T-2 transformer was under shut down from 10:21 to 11:00 for C/M.
- n) Barapukuria 132/33 kV T-5 transformer under shut down from 08:40 to 10:40 for R/H maint at 132 kV isolator.
- o) Barapukuria 132 kV Bus-2 was under shut down from 08:40 to 10:50 for R/H maint at 132 kV isolator.

knagar 132/33 kV T-1 and T-2 transformers tripped at 09:20 from both sides due to 33/11 kV auxiliary interruption occurred under Joydebpur S/S area transformer flashing for LA problem at R,B-phase and T-1 & T-2 were switched on at from 09:20 to 11:38.

- q) Ashuganj-Ghorashal 230 kV Ckt-1 was charged from Ashuganj end for protection test from 12:08 to
- 12:40. r) Summit Kodda 300 MW to Tongi and Kaliakoir 230 kV Ckt was under shut down from 12:50 to 20:13 for

switch yard work. 32/33 kV T-3 transformer was under shut down from 14:20 to 15:30 for replace heat sink at 33 kV

About 12 MW power interruption occurred under Joydebpur S/S area from 14:20 to 15:30.

side t) Summit Kodda 300 MW was synchronized at 20:52.

- u) Chandpur 150 MW STG was synchronized at 17:27 and was shut down at 19:38 for Damper problem.
- v) Ashuganj-Sirajganj 230 kV Ckt-1 was shut down at 16:00 for R/H maintenance at Y-phase(Riser loop joint) of Ashuganj end.
- w) Kabirpur 132/33 kV T-2 transformer was under shut down from 06:11(26/8/2020) to 07:11 for C/M.
- x) Sylhet-Chatak 132 kV Ckt-2 was under shut down from 06:29(26/8/2020) to 08:11 for C/M.
- y) Joydevpur 132/33 kV T-3 transformer was under shut down from 06:40(26/8/2020) to 07:31 for switching on auxiliary 33/0.4 kV transformer after maint. Work.
- z) Hasnabad-Aminbazar 230 kV Ckt-2 was shut down at 07:13(26/8/2020) for C/M...
- aa) C.Nawabganj 132/33 kV transformer tripped at 23:40 from both sides showing O/C relay due to Godagari feeder fault and was switched on at 23:52.
- ab) Ishwardi-Ghorashal 230 kV Ckt-2 tripped at 07:55(26/8/2020) from Ishwardi end showing Dist.T,PD-3 relay

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle