

| EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS |                                        |                      |                     |                  |           |                  |                           |
|--------------------------------------------------------------------|----------------------------------------|----------------------|---------------------|------------------|-----------|------------------|---------------------------|
| Date :                                                             |                                        | 2-Sep-20             |                     | Page -2          |           |                  |                           |
| Sl No.                                                             | Name of the Power Stations             | Producer             | Installed Capacity  | Present Capacity | Peak Hour | Enernv Generated | Remarks                   |
|                                                                    |                                        |                      | Unit No. X Capacity | MW               | MW        | MW               |                           |
| 1                                                                  | Ghorasal TPP (Unit-1&2)                | PDB                  | 2*55                | 85               | 28        | 542000           | Unit-1 Under maint.       |
|                                                                    | Ghorasal Repowered CCGP Unit-3         | PDB                  | 1*210               | 170              | 0         | 0                | Under maint.              |
|                                                                    | Ghorasal Repowered CCGP Unit-4         | PDB                  | 1*210               | 180              | 100       | 2392000          | Gas shortage              |
|                                                                    | Ghorasal TPP Unit-5                    | PDB                  | 1*210               | 190              | 110       | 2709000          | Gas shortage              |
| 2                                                                  | Ghorasal 365 MW CCGP Unit-7            | PDB                  | 1*243+1*122         | 365              | 0         | 0                | Under maint.              |
| 3                                                                  | Ghorasal 78.5 MW PP(MAX)               | QRPP                 | 2*40                | 78               | 0         | 0                | Gas shortage              |
| 4                                                                  | Ghorasal 108MW PP (Regent)             | IPP                  | 34*3.35             | 108              | 72        | 1716636          | Gas shortage              |
| 5                                                                  | Haripur GTPP                           | SBU, PDB             | 2*32                | 20               | 0         | 0                | Under maint.              |
| 6                                                                  | Haripur 412 MW CCGP                    | EGCB                 | 1*273+1*139         | 412              | 356       | 9057280          | FGMO                      |
| 7                                                                  | Haripur 360MW CCGP(HPL)                | IPP                  | 1*235+1*125         | 360              | 349       | 8043000          |                           |
| 8                                                                  | Meghnaghat 450 MW CCGP(MPL)            | IPP                  | 2*150+1*150         | 450              | 450       | 8946500          |                           |
| 9                                                                  | Meghnaghat 100 MW PP (Summit)          | QRPP                 | 12*8.9              | 100              | 100       | 2285760          |                           |
| 10                                                                 | Meghnaghat CCGP(Summit)                | IPP                  | 2*110+1*110         | 305              | 150       | 3328058          | GT-1 Under S/D due to gas |
| 11                                                                 | Madanganj 102 PP(Summit)               | QRPP                 | 6*17                | 100              | 97        | 1725480          |                           |
| 12                                                                 | Madanganj 55 MW PP(Summit)             | (IPP)                | 3*17.08+1*11.3      | 55               | 55        | 1110965          |                           |
| 13                                                                 | Keraniganj 100 MW PP (Powerpac)        | QRPP                 | 8*13.45             | 100              | 88        | 466643           | Engine problem            |
| 14                                                                 | Narshingdi 22 MW PP (Doreen)           | SIPP, REB            | 8*2.90              | 22               | 12        | 420048           | Engine problem            |
| 15                                                                 | 210 MW Siddhirgonj TPP                 | PDB                  | 1*210               | 115              | 0         | 0                | Under maint.              |
| 16                                                                 | Siddhirgonj 2*120 MW GTPP              | EGCB                 | 2*105               | 210              | 0         | 0                | Gas shortage              |
| 17                                                                 | Siddhirgonj 100 PP(Dutch Bangla)       | QRPP                 | 12*8.9              | 100              | 99        | 2152320          |                           |
| 18                                                                 | Siddhirgonj 335 MW CCGP                | EGCB                 | 1*217+118           | 335              | 9         | 679128           | ST sync process.          |
| 19                                                                 | Gagnagar 102 MW PP (Digital Power)     | IPP                  | 12*8.924            | 102              | 93        | 2064528          | Engine problem            |
| 20                                                                 | Kalpoti 52 MW PP (Sinha)               | IPP                  | 7*7.9               | 51               | 0         | 0                | Engine problem            |
| 21                                                                 | Kamalaghat 54 MW PP(Banco Energy)      | IPP                  | 3*18                | 54               | 53        | 946440           |                           |
| 22                                                                 | Kodda 150MW PP                         | BPDB-RPCL            | 9*17.06             | 149              | 149       | 2116800          |                           |
| 23                                                                 | Manikganj 55 MW PP (Northern)          | IPP                  | 3*19.3              | 55               | 55        | 859208           |                           |
| 24                                                                 | Nababganj 55 MW PP (Southern power )   | IPP                  | 3*19.3              | 55               | 55        | 878261           |                           |
| 25                                                                 | Bosila 108MW PP(CLC)                   | IPP                  | 12*8.775+1*3.5      | 108              | 0         | 0                | Fuel Shortage             |
| 26                                                                 | Summit Power (Madhabdi+Ashulia)        | SIPP, REB            | 3*3.67+4*8.73       | 80               | 55        | 1233420          | Engine problem            |
| 27                                                                 | Maona 33 MW PP(Summit)                 | SIPP, REB            | 4*8.73              | 33               | 33        | 604100           |                           |
| 28                                                                 | Rupganj 33 MW PP(Summit)               | SIPP, REB            | 4*8.73              | 33               | 33        | 773800           |                           |
| 29                                                                 | Gazipur 52 MW PP                       | IPP                  | 6*8.9               | 52               | 51        | 713364           |                           |
| 30                                                                 | Tongi 80 MW GTPP                       | PDB                  | 1* 105              | 105              | 0         | 0                | Under maint.              |
| 31                                                                 | Kodda 300 MW PP Unit-2 (Summit)        | IPP                  | 18*17.076           | 300              | 268       | 5394543          | Low demand                |
| 32                                                                 | Keraniganj 300 MW PP (APR)             | IPP                  | 256*1.4             | 300              | 0         | 59415            | Reserve                   |
| 33                                                                 | Bramhangaan 100 MW PP (Aggreko)        | IPP                  | 100                 | 100              | 50        | 235411           | Low demand                |
| 34                                                                 | Auraha 100MW PP (Aggreko)              | IPP                  | 0.85*23+0.95*91     | 100              | 52        | 264594           | Low demand                |
| 35                                                                 | Kodda 149 MW PP Unit-1 (Summit)        | IPP                  | 149                 | 149              | 112       | 2653920          | Engine problem            |
| 36                                                                 | Gazipur 100 MW PP                      | RPCL                 | 100 MW              | 105              | 104       | 1701120          |                           |
|                                                                    | Meghnaghat 104 MW PP (OPCL)            | IPP                  | 18.5*6              | 104              | 104       | 2477760          |                           |
| Dhaka area Total                                                   |                                        |                      |                     | 5895             | 3342      | 68551502         |                           |
| 37                                                                 | Chattogram TPP-1                       | PDB                  | 1*210               | 180              | 0         | 0                | Gas shortage.             |
|                                                                    | Chattogram TPP-2                       | PDB                  | 1*210               | 180              | 0         | 0                | Gas shortage.             |
| 38                                                                 | Raozan 25 MW PP                        | IPP                  | 3*8.9               | 25               | 25        | 419736           |                           |
| 39                                                                 | Teknaf 20MW PP (Solartech)             | Teknaf Solartech Ene | 20                  | 20               | 0         | 152415           |                           |
| 40                                                                 | Patenga 50MW PP (Baraka)               | IPP                  | 8*6.98              | 50               | 50        | 745920           |                           |
| 41                                                                 | Kapila Hydro: Unit-1,2,3,4, 5          | PDB                  | 2*40+3*50           | 230              | 78        | 1889338          | Low water level           |
| 42                                                                 | Sikalbaha 225MW                        | PDB                  | 1*150+1*175         | 225              | 0         | 37510            | Machine problem           |
| 43                                                                 | Sikalbaha Peaking GT                   | PDB                  | 1*150               | 150              | 145       | 2849449          |                           |
| 44                                                                 | Sikalbaha 105 MW PP (Baraka Sikalbaha) | IPP                  | 105 MW              | 105              | 17        | 274326           | Low demand                |
| 45                                                                 | Hathazari 100 MW peaking PP            | PDB                  | 11*8.9              | 98               | 0         | 0                | Under maint.              |
| 46                                                                 | Dohazari -Kalatsh 100 MW Peaking       | PDB                  | 6*17                | 102              | 102       | 998784           |                           |
| 47                                                                 | Juldah 100 MW Unit-1 (Acom)            | QRPP                 | 8*13.45             | 100              | 30        | 360640           | Low demand                |
| 48                                                                 | Juldah 100 MW PP Unit-3 (Acom)         | IPP                  | 0                   | 100              | 100       | 2287680          |                           |
| 49                                                                 | Barabikunda 22 MW PP (Regent)          | SIPP, PDB            | 8*2.90              | 22               | 18        | 423360           |                           |
| *                                                                  | Malancha, Ctg. EP2 (United)            | IPP                  | 5*8.73+3*9.34       | 0                | 25        | 327480           |                           |
| 50                                                                 | Chattogram 108 MW PP (ECPV)            | IPP                  | 16*7                | 108              | 86        | 1939200          | Engine problem            |
| 51                                                                 | Kapta 7 MW Solar PP                    | PDB                  | 7*4.44              | 7                | 0         | 33479            |                           |
| 52                                                                 | Anwara 300 MW PP (United)              | IPP                  | 300 MW              | 300              | 307       | 7238727          |                           |
| 53                                                                 | Jodiach Power                          | IPP                  | 3*18.55+1*3.6       | 54               | 54        | 1107316          |                           |
| 54                                                                 | Karnaphuli Power Ltd.                  | IPP                  | 110                 | 110              | 1         | 82799            | Low demand                |
|                                                                    | Juldah unit-2 (Acom)                   | IPP                  | 8*13.6              | 100              | 100       | 2366400          |                           |
| Chattogram area Total                                              |                                        |                      |                     | 2266             | 1138      | 23534759         |                           |
| 55                                                                 | Ashuganj TPP Unit- 3                   | APSCL                | 1*150               | 135              | 0         | 0                | Gas shortage.             |
|                                                                    | Ashuganj TPP Unit- 4                   | APSCL                | 1*150               | 129              | 0         | 0                | Gas shortage.             |
|                                                                    | Ashuganj TPP Unit- 5                   | APSCL                | 1*150               | 134              | 0         | 0                | Gas shortage.             |
| 56                                                                 | Ashuganj 225 MW CCGP                   | APSCL                | 1*142+1*75          | 221              | 0         | 3670000          | Machine problem           |
| 57                                                                 | Ashuganj 450 MW CCGP(North)            | APSCL                | 1*360               | 360              | 325       | 7165800          | FGMO                      |
| 58                                                                 | Ashuganj 450 MW CCGP(South)            | APSCL                | 1*360               | 360              | 295       | 6632000          | FGMO                      |
| 59                                                                 | Ashuganj 50 MW PP                      | APSCL                | 14*3.968            | 45               | 35        | 798768           | Gas shortage.             |
| 60                                                                 | Ashuganj 55 MW PP (Precision)          | RPP                  | 15*4                | 55               | 25        | 354720           | Gas shortage.             |
| 62                                                                 | Ashuganj 195MW PP (APSCL-United)       | IPP                  | 20*9.73+1*16        | 195              | 8         | 217454           | Gas shortage.             |
| 63                                                                 | Ashuganj 51 MW PP (Midland)            | IPP                  | 6*9.34              | 51               | 43        | 1018085          | Engine problem            |
| 64                                                                 | Ashuganj 150MW PP (Midland)            | IPP                  | 23*7.015            | 150              | 70        | 1324800          | Low demand                |
| 66                                                                 | Titas 50 MW Peaking PP                 | PDB                  | 8*6.92              | 52               | 44        | 401744           | Engine problem            |
| 67                                                                 | Chandpur 150 MW CCGP                   | PDB                  | 1*106+1*57          | 163              | 95        | 1775700          |                           |
| 68                                                                 | Chandpur 200MW (Desh energy)           | IPP                  | 0                   | 200              | 175       | 1054080          | Low demand                |
| 69                                                                 | Feni 22MW PP (Doreen)                  | SIPP, PDB            | 8*2.90              | 22               | 19        | 450144           |                           |
| 70                                                                 | Feni 11 MW PP (Doreen)                 | SIPP, REB            | 4*2.90              | 11               | 11        | 203940           |                           |
| **                                                                 | Impoport (Tripura)                     | Imported power       | 0                   | 160              | 144       | 3439680          |                           |
| 71                                                                 | Jangalia 33MW PP (Summit)              | SIPP, PDB            | 4*8.73              | 33               | 33        | 806000           |                           |
| 72                                                                 | Jangalia 52 MW PP (Lakdanavi)          | IPP                  | 6*8.92              | 52               | 43        | 782002           | Engine problem            |
| 73                                                                 | Cumilla 25 MW PP (Summit)              | SIPP, PDB            | 3*3.67+2*6.97       | 25               | 21        | 469850           |                           |
| 74                                                                 | Daudkandi 200 MW PP (B.Trac)           | IPP                  | 16*14.4             | 200              | 0         | 0                | Reserve                   |
|                                                                    | Feni Lanka Power                       | IPP                  | 7*18.415+1*9.78     | 114              | 114       | 1472880          |                           |
|                                                                    | Chowmuhani 113 MW                      | IPP                  | 12*9.78+2*3.1       | 113              | 113       | 2598120          |                           |
| Cumilla Area Total                                                 |                                        |                      |                     | 2980             | 1613      | 34635767         |                           |
| 75                                                                 | RPCL 210MW CCGP                        | IPP                  | 4*35+1*70           | 202              | 122       | 3245480          | Engine problem            |
| 76                                                                 | Tangail 22 MW PP (Doreen)              | SIPP, PDB            | 8*2.90              | 22               | 22        | 485280           |                           |
| 77                                                                 | Jamulpur 95 MW PP(Powerpac)            | IPP                  | 12*8.924            | 95               | 71        | 1263360          | Engine problem            |
| 78                                                                 | Sarishabari 3 MW Solar Plant           | IPP                  | 1*3                 | 3                | 0         | 12850            |                           |
| 79                                                                 | Mymensingh 200 MW PP (United)          | IPP                  | 200                 | 200              | 200       | 4603200          |                           |
| 80                                                                 | Jamulpur 115 MW PP (United)            | IPP                  | 115 MW              | 115              | 115       | 1118000          | #REF!                     |
| Mymensingh Area Total                                              |                                        |                      |                     | 637              | 530       | 10726170         |                           |
| 81                                                                 | Fenchugonj CCGP Phase-1                | PDB                  | 2*32+1*33           | 70               | 91        | 2124000          |                           |
| 82                                                                 | Fenchugonj CCGP Phase-2                | PDB                  | 2*35+1*35           | 90               | 30        | 721800           | # 4 under maint.          |
| 83                                                                 | Kushara 163 MW CCGP (KP)               | IPP                  | 1*109+1*54          | 163              | 163       | 3646963          |                           |
| 84                                                                 | Shajibazar 330 MW CCGP                 | PDB                  | 3*110               | 330              | 201       | 5436000          | ST under maint.           |
| 85                                                                 | Fenchugonj 51 MW PP (Barakatullah)     | RPP                  | 19*2.90             | 51               | 50        | 1117200          |                           |
| 86                                                                 | Fenchuganj 44MW (Energyprima)          | RPP                  | 12*3.3+5*2          | 44               | 48        | 1110888          |                           |
| 87                                                                 | Hobiganj 11MW PP Confidence-E          | SIPP, REB            | 4*2.90              | 11               | 8         | 180480           |                           |
| 88                                                                 | Shajibazar GTPP Unit- 8 & 9            | PDB                  | 2*36                | 61               | 0         | 1324512          | FGMO                      |
| 89                                                                 | Shajibazar 86MW PP (Shajibazar)        | RPP                  | 32*2.90             | 86               | 85        | 2026560          |                           |
| 91                                                                 | Sylhet 225 MW CCGP                     | PDB                  | 1*142+1*89          | 231              | 120       | 2603730          | Machine problem           |
| 92                                                                 | Sylhet 20 MW GTPP                      | PDB                  | 1*20                | 20               | 18        | 417000           |                           |
| 93                                                                 | Sylhet 50MW PP (EPL)                   | RPP                  | 27*2                | 50               | 0         | 0                | Contract Expired          |
| 94                                                                 | Shahjahanula 25 MW PP                  | SIPP, REB            | 3*9.34              | 25               | 24        | 569904           |                           |
| 95                                                                 | Bibiana 341 MW CCGP (Summit)           | IPP                  | 1*222+1*119         | 341              | 310       | 7119800          | FGMO                      |
| 96                                                                 | Bibiyana-III 400 MW CCGP               | PDB                  | 400 MW              | 400              | 0         | 0                | Under maint.              |
| 97                                                                 | Sylhet 10MW PP (Desh)                  | RPP                  | 6*1.95              | 10               | 10        | 245340           |                           |
|                                                                    | Bibiyana South 400 MW                  | PDB                  | 400 MW              | 0                | 0         | 0                | On test                   |
| Sylhet Area Total                                                  |                                        |                      |                     | 1988             | 1219      | 28644177         |                           |
| 98                                                                 | Bheramara GTPP Unit-3                  | PDB                  | 1*20                | 16               | 0         | 0                | Reserve                   |
| **                                                                 | Bheramara (HVDC )                      | Imported power       | 2*500               | 1000             | 905       | 21995636         |                           |
| 99                                                                 | Khulna 115 PP MW (KPCL-2)              | QRPP                 | 7*17                | 115              | 106       | 1950720          | Engine problem            |
| 100                                                                | Faridpur 50 MW Peaking PP              | PDB                  | 8*6.89              | 54               | 0         | 0                | Reserve                   |
| 101                                                                | Khulna 225 MW CCGP                     | NWPGCL               | 1*150+1*75          | 230              | 160       | 3253440          | Low demand                |
| 102                                                                | Gopalganj 100 MW Peaking PP            | PDB                  | 16*6.98             | 109              | 0         | 9216             | Reserve                   |
| 103                                                                | Bheramara 410 MW CCGP                  | NWPGCL               | 1*278+1*132         | 410              | 370       | 7162560          | FGMO                      |
| 104                                                                | Noapara 40 MW PP (Khanjahan Ali)       | QRPP                 | 16*4.4              | 40               | 40        | 471750           |                           |
| 105                                                                | Noapara 100 MW PP (Bangla Trac)        | IPP                  | 70*1.4              | 100              | 100       | 518400           |                           |
| 106                                                                | Rupsha 105 MW PP (Orion rupsha)        | IPP                  | 6*18.445            | 105              | 105       | 608640           |                           |
| 107                                                                | Madhumati 100 MW PP                    | IPP                  | 100 MW              | 105              | 0         | 0                | Reserve                   |
| Khulna Area Total                                                  |                                        |                      |                     | 2284             | 1786      | 35970362         |                           |
| 108                                                                | Barisal 110 MW PP (Summit )            | IPP                  | 7*17.076            | 110              | 64        | 911040           | Low demand                |
| 110                                                                | Bhola 33 MW PP (Venture)               | RPP                  | 1*34.50             | 33               | 32        | 591556           |                           |
| 111                                                                | Bhola 225 MW CCGP                      | PDB                  | 2*63+1*68           | 194              | 65        | 1557000          | GT-2 Under maint.         |
| 112                                                                | Bhola 95 MW PP (Aggreko)               | QRPP                 | 96*1.10             | 95               | 78        | 1447478          | Engine problem            |
|                                                                    | Payra 1320 MW                          | BCPCL                | 1*622               | 622              | 520       | 11934500         |                           |
| Barisal Area Total                                                 |                                        |                      |                     | 1054             | 759       | 16441574         |                           |
| 113                                                                | Baghabari 71 MW GTPP                   | PDB                  | 1*71                | 71               | 0         | 0                | Gas shortage.             |
|                                                                    | Baghabari 100 MW GTPP                  | PDB                  | 1*100               | 100              | 0         | 0                | Gas shortage.             |
| 114                                                                | Baghabari 50 MW Peaking PP             | PDB                  | 6*8.9               | 52               | 50        | 580424           |                           |
| 115                                                                | Bera 70 MW Peaking PP                  | PDB                  | 9*8.29              | 71               | 35        | 162262           |                           |
| 116                                                                | Amnura 50 MW PP(Sinha)                 | QRPP                 | 7*7.79              | 50               | 0         | 0                | Fuel shortage             |
| 117                                                                | Katakhali 50 MW PP (Northern)          | QRPP                 | 6*8.9               | 50               | 0         | 0                | Reserve                   |
| 118                                                                | Katakhali 50 MW Peaking PP             | PDB                  | 6*8.7               | 50               | 43        | 270200           | Engine problem            |
| 119                                                                | Sirajgonj Unit-1 225MW                 | NWPGCL               | 1*150+1*75          | 210              | 0         | 401744           | Gas shortage.             |
| 120                                                                | Sirajgonj Unit-2 225MW                 | NWPGCL               | 1*150+1*75          | 220              | 202       | 4397000          | FGMO                      |
| 121                                                                | Sirajgonj Unit-3 225MW                 | NWPGCL               | 1*141               | 220              | 210       | 4707918          | FGMO                      |
| 122                                                                | Sirajgonj 400 MW CCGP Unit-4           | SNWPGCL              | 1*282+1*132         | 414              | 412       | 9327127          | FGMO                      |
| 123                                                                | Santahar 50 MW Peaking PP              | PDB                  | 6*8.7               | 5                |           |                  |                           |