

Reporting Date : 9-Sep-20

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Actual :	93.11	Ft.(MSL)	Rule curve :	100.84	Ft.(MSL)
----------	-------	----------	--------------	--------	----------

Liter  
Liter

Total : Tk736,853,815

### Load Shedding & Other Information

Area	Yesterday		Estimated Demand (S/S end)	Today		Rates of Shedding (On Estimated Demand)
	MW			Estimated Shedding (S/S end)	MW	
Dhaka	0	0:00	4687	0	0%	
Chittagong Area	0	0:00	1599	0	0%	
Khulna Area	0	0:00	1434	0	0%	
Rajshahi Area	0	0:00	1296	0	0%	
Cumilla Area	0	0:00	1171	0	0%	
Mymensingh Area	0	0:00	945	0	0%	
Sylhet Area	0	0:00	521	0	0%	
Barisal Area	0	0:00	243	0	0%	
Rangpur Area	0	0:00	729	0	0%	
Total	0		12625	0		

Information of the Generating Units under shut down.

### Forced Shut-Down

- 1) Barapukuria-9) Bhola 225 MW GT-2 & ST
- 2) Bibiyana #3 10) Payra Unit-1
- 3) Ghorasal Unit-1,2,3,7
- 4) Ashuganj unit-3,4
- 5) Kaptai-1,2,5
- 6) Raozan #1,2
- 7) Sirajganj #2
- 8) Baghabari-71 MW

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

### Comments on Power Interruption

- a) Cumilla(N) 132/33 kV transformer was under shut down from 10:08 to 10:33 for C/M.  
b) Cumilla(N) 132/33 kV-T4 transformer was under shut down from 10:37 to 11:23 for C/M.  
c) Ashuganj-320 kV Bus-1 was under shut down from 09:50 to 18:32 for C/M.  
d) Ashuganj-Ashuganj(S) 230 kV Ckt-2 was under shut down from 09:28 to 18:39 for Bus-1 isolator problem.  
e) Ashuganj-Sirajganj 230 kV Ckt-2 was under shut down from 08:08 to 18:32 for Bus-1 isolator problem.  
f) Aminbazar-Bosila-108 MW 132 kV Ckt was under shut down from 09:25 to 21:15 for D/W.  
g) Myensing 132/33 kV-T2 transformer on fire & T-1, T-3 also tripped at 13:15.  
At the same time Myensing RPCL, Myensing-200 MW, Jamalpur-115 MW & Jamalpur-95 MW also tripped and were synchronized at 13:38, 17:07, 16:45 & 17:13 respectively. T-3 transformer was switched on at 16:34.  
h) Myensing 132 kV Bus-1 & 2 were switched on at 15:58.  
i) Myensing-Kishorganj 132 kV Ckt-1 & 2 were switched on at 15:58 & 17:45 respectively.  
j) Myensing-Netrokona 132 kV Ckt-1 & 2 were switched on at 16:03 & 17:47 respectively.  
k) Myensing-RPCL 132 kV Ckt-1 & 2 were switched on at 16:04 & 17:47 respectively.  
l) Myensing-Kishorganj 132 kV Ckt-1 & 2 were switched on at 22:33 & 15:59 respectively.  
m) Feni-Chodagadam 132 kV Ckt-1 tripped at 11:43 showing O/C & E/F relays and was switched on at 14:36.  
n) Sirajganj #1 was synchronized at 22:33.  
o) Sirajganj #2 was shut down at 23:56 for MI.  
p) Kishore-KPCL-2 132 kV Ckt is under shut down since 07:25/9/9/2020 for C/M.

About 420 MW power interruption occurred under Mymensingh zone area from 13:15 to 16:34.

**Superintendent Engineer  
Load Despatch Circle**