POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Hrs on 29-May-19 Today's Actual Min Gen. & Probable Gen. & Demand Min Gen. at 8:00 802 2000 Available May Company 12893 MW Till now the maximum generation is: The Summary of Yesterday's Day Peak Generation : Generation & Demand 10180.0 MW 12317.0 MW 8982 MW 14573 MW 12:00 Available Max Generation Evening Peak Generation 19:00 E.P. Demand (at gen end) Max Demand (Evening) : Reserve(Generation end) 12317.0 MW 19:00 12700 MW 12317.0 MW 19:00 Total Gen. (MKWH) 258.5 System Load Factor : 87.45% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Load Shed 0 MW Export from East grid to West grid :- Maximum -230 MW Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on MKWHR MW Energy 5-Oct-20 Ft.(MSL) 106.36 Ft.(MSL Rule curve Actual: 99.99 1171.58 MMCFD. Oil Consumed (PDB): HSD Liter FΩ Liter Cost of the Consumed Fuel (PDB+Pvt) Tk158.762.687 Gas Tk644,095,389 Total : Tk883,937,962 **Load Shedding & Other Information** Area Today Estimated Demand (S/S end) Rates of Shedding Estimated Shedding (S/S end) (On Estimated Demand) Dhaka 0:00 4533 1546 Chittagong Area Khulna Area ō 0:00 0% 0% 0% Rajshahi Area 0 0:00 1252 0 Cumilla Area 0:00 1132 0% Mymensingh Area 913 Sylhet Area 0 0:00 505 0 0% Rangpur Area 0:00 704 **12207** Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-1.2 2) Baghabari-71 MW,100 MW 3) Ghorasal Unit-1,2,3, 4) Ashuganj unit-3,4 5) Kaptai-2,4,5 6) Raozan #1,2 7) Siddirganj-335 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description a) Baghabari 230/132 kV T-2 transformer was under shut down from 08:05 to 13:32 for C/m. b) Rangpur 132/33 kV T-1 transformer was under shut down from 08:04 to 17:10 for A/M. c) Ashuganj 450 MW south GT was synchronized at 08:33 after maintenance work. About 07 MW power interruption occurred under Bakulia S/S area side and O/C relay at 33 kV side and was switched on at 11:50. from 09:52 to 11:50. e) Mirpur-Uttara(3rd) 132 kV Ckt was shut down at 07:48 for A/M and still under maintenance. f) Kallyanpur 132/33 kV GT-2 transformer was shut down at 09:32 for C/M. About 22 MW power interruption occurred under Polashbari S/S area work at 33 kV PBS feeder. from 09:10 to 10:30. er tripped at 09:45 due to 33 kV feeder fault and was switched on from 09:45 to 12:00 i) Barishal(N)-Bhola 230 kV Ckt-1 tripped at 12:43 showing Dist. L3,Z1,15.07 Km at Barishal(N) end and Dist. 65.5 Km at Bhola end and was switched on at 13:29. At the same time Bhola Agreeko 95 MW also tripped and was synchronized at 14:59.) Siddhirganj-Haripur 230 kV Ckt-2 was under shut down from 14:52 to 16:47 for R/H maintenance at Siddhirganj end. k) Siddhirganj GT-1 was shut down at 14:10 for checking of vibration sensor and was synchronized at 17:43. I) HVDC Bheramara Aux. transformer tripped at 17:16 showing PRD and was switched on at 19:07. rs tripped at 16:27 due to 33 kV fe tion occurred under GK. Project S/S area & T-2 were switched on at 17:54 and 17:53 respectively. from 16:27 to 17:54. n) Raozan unit-1 was shut down at 00:28(05/10/20200 due to problem with feed water pump. o) Barapukuria 132/33 kV T-3 transformer tripped at 01:32(05/10/20200 from both sides showing O/C,E/F relay at 3 kV side and L/O at 132 kV side and was switched on at 01:42. p) Fenchuganj S/S-Sylhet 132 kV Ckt tripped at 03:05(05/10/2020) from Fenchuganj S/S end showing Dist. 3-phase, Gen. trip and was switched on at 03:34. At the same time Sylhet 20 MW,10 MW and Fenchuganj Energy Prima also tripped. q) Bhola Agreeko 95 MW tripped at 03:35(05/10/2020) due to gas shortage and was synchronized at 04:28.

Executive Engineer

Network Operation Division

Load Despatch Circle

Sub Divisional Engineer Network Operation Division