				NY OF BANGL DESPATCH							QF-LDC-0
		101110		REPORT	JE111 E11						Page -1
Till now the maximum generation	on is : -		12893 MW		21	:00	Hrs on 2	eporting D 19-May-19	ate: 1	5-Oct-20	
The Summary of Yesterday's		14-Oct-20	Generation	& Demand			Today's Actual N	/lin Gen. 8	R Probab		
Day Peak Generation : Evening Peak Generation :		10646.0 12528.0			12:00 19:30		Min. Gen. at Available Max Ger	7:00 neration		9071 14569	
E.P. Demand (at gen end) :		12528.0 12528.0			19:30 19:30		Max Demand (Eve Reserve(Generati	ening) :		13000 1569	
Maximum Generation : Total Gen. (MKWH) :		264.9	System Loa	ad Factor	: 88.11%		Load Shed	on end)			MW
Export from East grid to West grid :-		PORT / IMPORT	THROUGH		INTERCONNECTO MW at		3:00	En	orav		MKWHR.
Import from West grid to East grid :-	Maximum			-210	MW at		-		ergy ergy	-	MKWHR.
Water Level of Kaptai La Actual		Ft.(MSL),	15-Oct-20	Rule curve	: 107.30		Ft.(MSL)				
				rtaio ourvo			r c (moz)				
Gas Consumed :	Total =	1157.36	MMCFD.		Oil Consumed (PD)B):	F	HSD :			Liter
								0 :			Liter
Cost of the Consumed Fuel (PDB+P	vt):	Gas :	Tk16	2,448,514							
:		Coal :	Tk76	3,189,074	Oil	:	Tk683,120,694	Tot	al : Tk9	21,758,282	
Load Shedding & Other Information											
Area	Yesterday						Today				
7400	•			Demand (S/S e	nd)		Estimated Sheddi			ites of Shedo	
Dhaka	MW 0	0:00		MW 4603			N	/WV	(On	Estimated D 0%	emand)
Chittagong Area	Ö	0:00		1570				Ö		0%	
Khulna Area	0	0:00		1408				0		0%	
Rajshahi Area Cumilla Area	0	0:00 0:00		1272 1149				0		0%	
Mymensingh Area	Ö	0:00		928				0		0%	
Sylhet Area	0	0:00		513				0		0%	
Barisal Area Rangpur Area	0	0:00 0:00		239 715				0		0% 0%	
Total	0		1	12396				0			
	Information o	f the Generating I	Jnits under s	shut down							
	anomaton o	the contraining t	orino dilator c	mat down.							
	Planned Shut- Dov	vn			Forced Shut- Dov	vn					
					1) Barapukuri	ia S	ST: Unit-1,2				
					2) Baghabari-	-71	MW,100 MV	V			
					Ghorasal L	Jnit	-1,2,3				
					4) Ashuganj u	ınit	-3,4				
					5) Kaptai-2,4						
					6) Raozan #2	,					
					7) Siddirganj-		= NA\A/				
					() Siddinganij-	330	J IVIVV				
	Additional Inform	ation of Machine	s, lines, inte	erruption / For	ced Load shed etc.						
	1	escription					Comments on Po	ower Inte	rruption		
a) Kaptai-Chandraghona	a 132 kV Ckt-1	was under	shut do	wn from 0	8:35 to 16:05	for	A/M.				
b) Bheramara HVDC sta								r A/M.			
c) Lalmonirhat 132/33 k											
l '											
d) Sirajganj 132/33 kV T											
e) Ishwardi-Bheramara 1						r C	/M.				
f) Tongi-Kaliakoir 230 k\	/ Ckt was und	er shut dow	n from C	08:45 to 16	:16 for A/M.						
g) Barishal(N)-Barishal(S) 132 kV Ckt	-2 was unde	er shut d	own from	11:49 to 13:16	of fo	r protection	work			
at Barishal(S) end.											
h) Comilla(N) 132/33 kV T-4 transformer was under shut down from 12:15 to 14:12 for							or R/H main	tenanc	e		
work at 33 kV Bus.											
i) Sylhet-Chatak 132 kV	Ckt-2 was un	der shut dov	vn from	09:08 to 1	0:44 for DC fa	il p	roblem at C	B of S	ylhet e	end.	
i) Natore 132/33 kV T-3	transformer w	as under sh	ut down	from 10:1	9 to 13:22 for	bu	shing proble	em of	•		
j) Natore 132/33 kV T-3 transformer was under shut down from 10:19 to 13:22 for bushing problem of Y-phase, 33 kV side.											
k) Agargaon 230/132 kV	T-2 transform	ner tripped a	at 12:45	showina E	us bar Diff. at	23	80 kV side a	nd was	6		
switched on at 13:05.						Ī					
I) Rangamati-Khagrachari	132 kV Ckt-2 v	vas under sl	nut down	from 08:57	to 15:17 for A	/м					
m) Saidpur 132/33 kV T-							A/M				
n) Sylhet CCPP ST tripp					3.00 10 11.101		, 01vi.				
o) Sylhet CCPP GT tripp					or						
p) Sirajganj unit-4 trippe						mo	bronized at	20.22	and		
ST was synchronized a		to problem	i wiiii ga	is supply a	iliu O i was sy		ilioilized at i	20.22	anu		
		rt tripped at	15:10 40	o to I A bur	at at P phase	_ _ D	rimo and				
q) Sylhet-Sylhet Energy P											
r) Norail-Magura 132 kV		ider snut do	own iron	1 14:40 10	21:30 for abno	ווווכ	iai sound wa	as gene	eraung		
from B-phase,LA at No						. 1					
s) Fenchuganj S/S-Sylhe				m Fenchu	ganj S/S end s	ho	wing Dist. Z	1 at			
Fenchuganj S/S end ar											
t) Barishal(N)-Madaripur	132 kV Ckt-1	was under	shut dov	wn from 14	1:03 to 17:31 f	or	protection w	ork at			
Barishal(N) end.											
u) Madanganj-Munshiga	nj 132 kV Ckt	-1 was unde	er shut d	own from	08:24 to 14:12	2 fo	r A/M.				
v) Natore 132/33 kV T-2 transformer was	under shut down from	16:17 to 18:34 for r	nodification w	ork of			About 20 MW power			l under Natore	S/S area
33 kV Bus.							from 16:17 t				
w) Natore 132/33 kV T-3	transformer	was shut do	wn at 17	:44 for hig	temperature	e at	t Y-phase,bu	ushing	of		
33 kV side.	**************************************	dament of the first	1.0 :				Ab 45 1551			Lucada a et a	- 010 -
x) Fenchuganj-Kulaura 132 kV Ckt-1 & 2 on at 22:07.	uipped at ∠1:55 from K	ulaura end showing	L/U and were	switched			About 45 MW power from 21:55 to			under Kulaur	a 5/5 area
	N/ Old 4 ···-		F	00.00/45/	0/0000\ +- 00			U 22.U	٠.		
y) Kaliakoir-Bibiyana 400								0/14			
z) Kabirpur 132/33 kV T-								C/M.			
aa) Dohazari-Cox's baza ab) Naogaon 132/33 kV T-3 transformer t	ar 132 kV Ckt-	∠ was shut	down at	U6:24(15/	10/2020) for D)/V\	About 32 MW power	s inter		Lundor M	en 6/6
at LT side and was swi			rus at m ISIDE	and E/F			from 05:54(un a/a area
ac) Hathazari-Baroihat 1			-20/45/4	IU/3U3U/ -	howing E/F				.020) ((. 00.00.	
ao, i iauiazaii-Daiviilal I	UZ NV UNI-I I	ipped at 00	.20(10/1	012020) 8	nowing E/F le	.ay	ut i ialiiaZdi	ii eilu.			

Sub Divisional Engineer Network Operation Division Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle