			1	POWER GRID COMPANY OF BANGLADESH NATIONAL LOAD DESPATCH CENTE								QF-LDC
				DAILY REPORT								Page
Till now the maximum g	eneration is :		12893 MV	v			21:0	00 Hrs on		porting Date :	4-Dec-20	
The Summary of Yesterd		3-Dec-20	Generation	on & Demand				Today's Actua		& Probable Ge	n. & Demand	
Day Peak Generation :		7491.0		Hour:		12:00		Min. Gen. at		4:00		5707 MW
Evening Peak Generation :		8928.0		Hour:		19:00		Available Max G		:		3397 MW
E.P. Demand (at gen end):		8928.0		Hour :		19:00 19:00		Max Demand (E				7800 MW 5597 MW
Maximum Generation : Total Gen. (MKWH) :		8928.0 171.9	IVIVV	Hour : System Load	Eactor :	80.24%		Reserve(General Load Shed	ation end)			0 MW
Total Octi. (WIKWIT) .		171.3		/IMPORT THROUGH EAST-WEST INTER	CONNECTOR			Load Orica	•			O MW
Export from East grid to Wes						MW	at	8:00		Energy		MKWHR
mport from West grid to East	st grid :- Maxi	mum		-		MW	at	-		Energy		- MKWHR
ter Level of Kaptai Lake at 6 Actual :		Ft.(MSL),	4-Dec-20		Rule curve :	40	05.73	Ft.(MSL)				
Actual :	99.90	FL(IVIOL),			Rule curve :	- 10	05.73	FL(MOL)				
Gas Consumed :	Total =	874.33	MMCFD.			Oil Cons	sumed (PDB):				
									HSD			Liter
									FO :			Liter
2	(DDD - D - I)			71.400.407.740								
Cost of the Consumed Fuel	(PDB+PVt):	Gas : Coal :		Tk120,437,749 Tk59,790,101			Oil	: Tk288,444,947		Total · T	k468,672,796	
							Oil	. 1K200,444,547		TOTAL . I	K400,072,790	
		oad Shedding &	Other Info	ormation								
Area	Yesterda	у		5 th 1 1 5 th 1 6 th 1 6 th 1				Today	10/0	- D		P
	MW			Estimated Demand (S/S end)				Estimated Shed	lding (S/S e MW	end)	Rates of Shed On Estimated [
Dhaka	0	0:00		2780					IVIVV	0	On Estimated t	zonanu)
Chittagong Area	0	0:00		937						0	0%	
Khulna Area	Ö	0:00		838						0	0%	
Rajshahi Area	0	0:00		756						0	0%	
Cumilla Area	0	0:00		684						0	0%	
Mymensingh Area	0	0:00		552						0	0%	
Sylhet Area	0	0:00		319						0	0%	
Barisal Area	0	0:00 0:00		142 426						0	0% 0%	
Rangpur Area Total	0	0:00		7434						0	0%	
						4) Ashu 5) Kapta 6) Raoz 7) Siddi	zan #2 irganj-33	-3 S				
							ndpur-16: nani #1 (3 MW CCPP STG				
Add		Description		Interruption / Forced Load shed etc.				Comments on	Power Inte	erruption		
b) Baroaulial-Hathazari 132 k o) Aminbazar 220/132kV TO d) Saver-Manikganj P/P 132 e) Jamalpur-UMPL 132 kV Ck g) Sherpur-UMPL 132 kV Ck g) Tongj(old)-Tongj(Nev) 13. i) Cumilla(N) 230/132 kV T-2 j) Wymensing RPCL-Mymen k) Bhandaria-Bagerhat 132 k) j) Naogaon-Bogura 132 kV m) Saidpur-Barapukuria 132 n) Maguara 132 kV T-2 m) Saidpur-Barapukuria 132 n) Maguara 132/33 kV T-2 tm)	to Ckt-1 was us a transformer kV Ckt-2 was Ckt-2 was under 1 transformer 2 kV Ckt-2 was transformer was transformer was under transformer was under transformer was under transformer was v Ckt-2 was under transformer was v Ckt-2 tripped Ckt-2 was under transformer was v Ckt-2 tripped Ckt-2 was under transformer was v Ckt-2 tripped Ckt-2 was sync	under shut down fi was under shut down der shut down for shut down from to was under shut dow sunder shut dow was under shut dow kV Ckt-2 was und der shut down from sunder shut down from under shut down from the shut down d at 10:04 showing thronized at 13:21	rom 08:16 lown from 0 from 08:5 m 08:11 to 09:01 to 16 own from 0 own from 0 ler shut do own 07:58 to n 09:12 to n from 08:4 from 08:2 g Dist. Rela	to 15.26 for A/M. 8i.16 to 17.11 for A/M. 5 to 15:53 for A/M. 16.42 for A/M. 49 for A/M. 7:51 to 18:06 for A/M. 8:24 to 16:54 for A/M. 8:24 to 16:54 for A/M. 16:41 for A/M. 16:41 for A/M.								
Sub Divisional Engineer Network Operation Division				ive Engineer Operation Division						uperintendent E		