

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 7-Dec-20

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	Generation	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*95	185	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CCPP Unit-	PDB	1*210	170	93	2415500	Gas shortage
	Ghorasal Repowered CCPP Unit-	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	115	278750	Gas shortage
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	200	4798136	Machine problem.
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	71	1705136	Gas shortage
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	341	8560640	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	328	7658000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	400	9067050	Frequency control
9	Meghnaghat 100 MW(EL)	QRPP	1*28.9	100	78	1439040	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	58	222024	Low demand
12	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	45	399800	Low demand
13	Karaniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	100	1555051	
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	298656	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*9.8	100	100	446400	
18	Siddhirgonj 335 MW CCPP	EGCB	1*21+1*18	335	0	0	Under maint.
19	Gagnagar 102 MW PP (Digital Po)	IPP	12*8.924	102	7	72288	Low demand
20	Kapoti 52 MW PP (Sinha)	IPP	7*7.9	51	10	22512	Low demand
21	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	1064160	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	64	176640	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	769207	
24	Nabiganj 55 MW PP (Southern)	IPP	3*19.3	55	17	153440	Low demand
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Under maint.
26	Summit Power,(Madhabadi-Ashuli)	SIPP,REB	3*3.67+4*8.73	80	57	1291020	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	25	564900	Engine problem
28	Ruggan 33 MW PP(Summit)	SIPP,REB	4*8.73	33	25	646600	Engine problem
29	Gazipur 52 MW PP	IPP	6*8.9	52	16	189660	Low demand
30	Tongi 50 MW GTTP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summ)	IPP	18*17.076	300	200	1332327	Low demand
32	Karaniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.
33	Bramhangon 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summ)	IPP	149	149	100	1064880	Low demand
36	Gazipur 100 MW PP	RPCL	100 MW	105	0	0	Reserve.
37	Meghnaghat 149 MW PP (QPCL)	IPP	18*8.58	149	90	1579200	Engine problem
38	Manikganj 182MW PP(MPGL)	IPP	9*18	182	17	37440	On test
<b>Dhaka area Total</b>				<b>6057</b>	<b>2685</b>	<b>50427357</b>	
37	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	0	0	Reserve.
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energ	20	20	0	90045	
40	Patana 50MW PP (Baraka)	IPP	8*6.98	50	46	851520	
41	Kapali Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	46	1056000	Unit-2 under maint
42	Sikalbaha 225MW	PDB	1*150+1*175	225	176	4666132	
43	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
44	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	0	0	Reserve.
45	Hafazari 100 MW Peaking PP	PDB	1*18.9	98	0	0	Under maint.
46	Dohazari-Kalesi 100 MW Peaki	IPP	6*17	102	51	163453	Low demand
47	Juidah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	10	19320	Low demand
48	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	1697280	
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	433632	Engine problem
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	15	412320	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	50	150720	Low demand
51	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	21480	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	198	3029664	Transformer OIL
53	Jodac Power	IPP	3*18.55+1*3.6	54	54	1223650	
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
	Juidah unit-2 (Acom)	IPP	8*13.6	100	100	974400	
	Anilima Energy Ltd.	IPP	6*21.2	0	0	37636	
<b>Chattogram area Total</b>				<b>2266</b>	<b>866</b>	<b>14823552</b>	
55	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas shortage.
	Ashuganj TPP Unit-4	APSCL	1*150	129	140	2453960	
	Ashuganj TPP Unit-5	APSCL	1*150	134	100	271506	Gas shortage
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	182	4576000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	0	Under maint
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	0	0	Under maint
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	567964	Gas shortage
60	Ashuganj 55 MW PP (Precision)	RPP	15.4	55	10	790980	
62	Ashuganj 185MW PP (APSCL-Unit)	IPP	20*9.23+1*16	185	26	672486	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1183385	
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	30	1187636	Low demand
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Under maint.
68	Chandpur 200MW (Desh energy)	IPP	0	200	120	1648320	High Voltage.
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	485604	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	124560	Engine problem
**	Imporrt (Tripura)	Imported power	0	160	106	2094720	
71	Jangalla 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	820000	
72	Jangalla 52 MW PP (Lakdanavi)	IPP	6*8.92	52	34	209952	Low demand
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	457730	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve.
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	28	476290	Low demand
<b>Cumilla Area Total</b>				<b>2980</b>	<b>936</b>	<b>20455350</b>	
75	RRCL 210MW CCPP	IPP	4*35+1*70	202	99	2482160	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	422640	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	351360	
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	3250	
79	Mymensingh 200 MW PP (United)	IPP	200	200	24	112800	Low demand
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	95	1258800	#REF!
	Sutakhal 50 MW Solar PP	IPP	50	50	0	144980	
<b>Mymensingh Area Total</b>				<b>687</b>	<b>333</b>	<b>4785990</b>	
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	60	1434000	
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	31	758040	GT-4 under maint.
83	Kushara 163 MW CCPP (KP)	IPP	1*108+1*54	163	163	3991336	
84	Shahbazar 330 MW CCPP	PDB	3*110	330	263	4457000	Gas shortage
85	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	53	1167000	
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	50	1079856	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	158500	
88	Shahbazar GTTP Unit- 8 & 9	PDB	2*35	66	35	816672	
89	Shahbazar 88MW PP (Shahibaz)	RPP	32*2.90	86	75	1722240	Engine problem
91	Sylhet 225 MW CCPP	PDB	1*142+1*88	231	150	3361100	
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	258000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	397296	Engine problem
95	Bibiana-II 341 MW CCPP (Summ)	IPP	1*222+1*119	341	290	7282750	FGMO
96	Bibiana-III 400 MW CCPP	PDB	400 MW	400	398	9293000	
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	0	0	Engine problem
	Bibiana South 400 MW	PDB	400 MW	0	0	0	On test
<b>Sylhet Area Total</b>				<b>1988</b>	<b>1613</b>	<b>36206790</b>	
98	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	672	11239728	
99	Khuila 115 PP MW (KPCL-2)	QRPP	7*17	115	32	103680	Low demand
100	Fairdip 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
101	Khuila 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
102	Gosairani 100 MW Peaking PP	PDB	16*6.88	109	0	0	Reserve.
103	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Under maint.
104	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	0	0	Reserve.
105	Noapara 100 MW PP (Bangla Tr)	IPP	70*1.4	100	0	0	Reserve.
106	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	90	1428000	Engine problem
107	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
<b>Khuila Area Total</b>				<b>2284</b>	<b>794</b>	<b>12771408</b>	
108	Bansil 110 MW PP (Summit)	IPP	7*17.076	110	0	8214	Low demand
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	27	500500	Engine problem
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	0	0	Under maint.
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	93	1316453	
	Payra 1320 MW	BCPCL	1*622	622	660	11119300	
	Bhola Nulan Biddut BD LTD	IPP	220	0	7	530670	
	United Payra Power Ltd.	IPP	8*18.5+1*9.5	0	0	0	On test.
<b>Barisal Area Total</b>				<b>1064</b>	<b>787</b>	<b>13476139</b>	
113	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	Reserve.
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
116	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	0	0	Fuel Shortage
117	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Fuel Shortage
118	Katakhal 50 MW Peaking PP	PDB	6*8.9	50	0	8399	Reserve.
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0		