

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2020					Day : Tuesday				Date : 15.12.20				
Probable Maximum Demand : 9000 MW					Probable Maximum Generation : 13405 MW					Rule Curve = 104.70 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 99.25 ft. Today = 99.21 ft.					14.12.20 (Yesterday) 15.12.20 (Today)			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.12.20 (Yesterday)		15.12.20 (Today)		14.12.20 (Yesterday)		15.12.20 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW				
(A) Plants in operation:													
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.	
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	99	0	0	0		170	Under maint.	
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	STG Commissioning	
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	115	115	115	115	75		Gas Shortage	
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+ 1x 126	365	365	300	300	300	300				
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	6	52	100	100	56		Gas Shortage	
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78		Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	346	310	166	360				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	360	225	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	368	339	412	412				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.	
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	20	100	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305		Gas Shortage	
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	100	100	100	100				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	15	100	100				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	4	41	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	60	62	40	100				
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	0	100	100				
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	13	16	19	19				
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	53	53	58	58				
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	43	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	50	105	105				
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	84	150	150				
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	53	54	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	300	300	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	118	149	149	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300				
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
33	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	100				
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	0	17	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	90	90	90				
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	0	0				
Dhaka Zone Total				6281	6057	2354	2763	3218	3987	849	885		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	47	48	47	47	182		Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50				
45	Sikalbaha 105 MW PP (Baraka Siku)	HFO (IPP)	6x18.415	105	105	0	0	100	100				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	205	176	215	225				
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	162	160	300	300				
49	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	85	85				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	15	5	15				
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	102	102				
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	53	54	54				
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	50	100	100				
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0				
Chattogram Zone Total				2326	2266	660	737	1435	1430	512	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	0	0	0	135		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	80	80	150	150	49		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	10	20	20				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	160	221	225	225				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	170	0	0	190		Was Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Under maint.	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	10	10				
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	26	26	187		Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	118	150	150	150				
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under Maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	42	120	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	20	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.02	200	200	0	0	0	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	26	9	113	113				
**	Impoport (Tijura)	India		160	160	88	106	139	148				
Cumilla Zone Total				3040	2980	825	1005	1336	1596	695	523		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	89	92	110	110	110		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	95		95				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	8	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	1	0	1.6	0				
84	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	14	0	50	0				
	Tangail 22 MW PP(Pali Power Gen	HFO (SIPP)				26	26	26	26				
Mymensingh Zone Total				695	687	265	356	523	566	110	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.12.20 (Yesterday)		15.12.20 (Today)		14.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	20	20	20	20				
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	22	42	43	43				
87	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	47	53	51	51				
88	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	50	50	44	44				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	110	163	163				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	35	36	36	36				
92	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	120	156	156	156	174		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	75	86	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	125	120	150	150				
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20				
96	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	14	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0				
100	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	328	327	400	400				
	Bibiyana South 400 MW	Gas (PDB)				50	100	65	65				
	Shahjibazar 100 MW GTTP	Gas (PDB)				100	0	0	0				
Sylhet Zone Total						2033	1988	1099	1134	1261	1261	174	0
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	335	300	410	410				
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	65	65				
105	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
106	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	65	115	115				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	100				
108	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	90	105	105				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	544	782	551	792				
Khulna Zone Total						2288	2284	949	1237	1411	1988	0	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	80	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	26	26	26				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x96	95	95	14	13	95	95				
115	Payra 1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	380	550	600	660				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				37	0	0	0				
	United Payra Power Ltd.	HFO (IPP)				0	0	0	0				
Barishal Zone Total						1054	1054	451	669	831	891	0	194
116	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	12	34	34				
121	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	95	100	100				
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	33				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Under maint.	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	173	154	225	225				
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	369	368	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
130	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	0	90	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	84	111	113	113				
Rajshahi Zone Total						2193	2183	656	863	1370	1493	381	220
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
136	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
137	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
138	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	113	113	113				
139	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Majpara, Tatulia 8 MW Solar PP (Sympa P)	Solar (IPP)	1 x 8	8	8	1	0	8	0				
Rangpur Zone Total						685	605	1	113	201	193	85	274
Sub-total: Plants in operation						20595	20104	7260.0	8877	11586	13405	2806	2276
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						6867	8396	10958	12679				
(B) Contract expired power plants													
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0				
Gross Total				20595	20104	7260	8877	11586	13405	2806	2276		
(C) Actual data of 14.12.20 (Yesterday) Monday :													
01.	Max. Demand (Generation end)	:	8877.00 MW, at = 19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand (Sub-station end)	:	8396.00 MW, at = 19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	8877.00 MW, at = 19:30 hrs										
04.	Minimum Generation (Generation end)	:	5589.00 MW, at = 5:00 hrs	Dhaka	3050	3050	0	Mymensingh	674	674	0		
05.	Day-peak Generation (Generation end)	:	7260.00 MW, at = 12:00 hrs	Chattogram	866	866	0	Sylhet	316	316	0		
06.	Evening-peak Generation (Generation end)	:	8877.00 MW, at = 19:30 hrs	Khulna	1058	1058	0	Barishal	230	230	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 19:30 hrs	Rajshahi	870	870	0	Rangpur	585	585	0		
08.	Actual Minimum Generation up to 8:00 hrs.	:	5649.00 MW, at = 7:00 hrs and	Cumilla	747	747	0						
09.	Generation shortfall at evening peak due to :	:						Total	8396	8396	0		
	a) Gas limitation	:	2539 MW	13.	Fuel cost :	(a) Gas = 124641242 Taka	(c) Coal = 50016587 Taka						
	d) Coal supply Limitation	:	85 MW			(b) Oil = 266368460 Taka	Total = 441026290 Taka						
	b) Low water level in Kaptai lake	:	182 MW										
	c) Plants under shut down/ maintenance	:	2276 MW	14.	Maximum Temperature in Dhaka was :	26.7° C							
10.	Total Energy (Generation + India Import)	:	171.62 MKWh	15.	Export through East-West interconnections :								
	By Gas = 110.560 MKWh		33.450 MKWh		At evening peak-hour	:	-22 MW, at 19:30 hrs						
	By Coal = 11.393 MKWh		1.107 MKWh		Maximum	:	-79 MW, at 13:00 hrs						
	By Solar= 0.256 MKWh				Energy	:	0.2325 MKWh						
11.	Total Gas Supplied	:	862.77 MMCFD										
(D) Forecast of 15.12.20 (Today) Tuesday :													
01.	Maximum Demand	:	9000 MW (Generation end)	04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	13405 MW (Generation end)	05.	Total Generation	:	173.99 MKWh						
03.	Maximum Shortage	:	-4405 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	27.2° C						

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation