

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2020					Day : Thursday				Date : 24.12.20					
Probable Maximum Demand : 8900 MW					Probable Maximum Generation : 13152 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.77 ft Today = 98.70 ft.					Rule Curve = 103.80 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.12.20 (Yesterday)		24.12.20 (Today)		23.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
(A) Plants in operation:														
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.		
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	44	44	44	44	126		Gas Shortage		
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	STG Commissioning		
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.		
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	310	300	300					
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	102	52	108	108					
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	256	252	280	280					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	357	373	412	412					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.		
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	15	100	100	100					
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305		Gas Shortage		
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	25	100	100	100					
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	15	64	100	100					
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	55	55					
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	70	86	85	85					
19	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	0	0	100	100					
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	16	16					
21	Summit Power,(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	37	57	58	58					
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	17	17	17					
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33					
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52					
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105					
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	82	150	150					
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50					
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54					
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	115	262	300	300					
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	36	130	149	149					
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300					
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
33	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	100					
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	0	0	55	55					
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
36	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	104	104	104					
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	72	100	160					
Dhaka Zone Total				6281	6057	1811	2518	3417	3767	1069	905			
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	43	48	49	49	182		Low Water Level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	31	50	50	50					
45	Sikalbaha 105 MW PP (Baraka Siku)	HFO (IPP)	6x18.415	105	105	0	0	100	100					
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	162	163	160	160	62		Gas Shortage		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	162	216	300	300					
49	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100					
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	100	100	100					
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	100	100					
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	16	16					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	25	10	20					
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	93	102	102					
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	34	54	54	54					
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110					
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	70	100	100	100					
	Anilma Energy Ltd.	HFO (IPP)				20	0	0	0					
Chattogram Zone Total				2326	2266	654	969	1401	1386	574	180			
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	135	135	135		Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	80	80	129	129					
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	26	23	23					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	199	197	0	0					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	360	350	360	360					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Under maint.		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	51	51	50		Gas Shortage		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	140	135	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	50	50	50					
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	50	100	200	200					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	25	25					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	24	43	43					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	20	21					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.02	200	200	0	0	0	200					
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	26	17	113	113					
**	Impoport (Tripura)	India		160	160	76	102	139	148					
Cumilla Zone Total				3040	2980	1135	1231	1640	1900	506	360			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	101	106	115	115	96		Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20					
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	90	95	95					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	60	200	200					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	2	0	1.6	0					
84	Sutakihali 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0					
	Tangail 22 MW PP(Pali Power Gen	HFO (SIPP)				0	0	0	0					
Mymensingh Zone Total				695	687	296	391	597	545	96	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.12.20 (Yesterday)		24.12.20 (Today)		23.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0				
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30				
87	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	48	25	51	51				
88	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	47	50	44	44				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	33	33	33				
92	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	156	155	158	158	175		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	73	75	86	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	137	202	215	215				
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20				
96	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	13	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Under maint.	
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	160	299	270	300	101		Gas Shortage	
	Bibiyana South 400 MW	Gas (PDB)				0	0	0	0				
	Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	100	100				
Sylhet Zone Total						828	1077	1197	1227	276	341		
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	280	225	300	300	185		Gas Shortage	
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	35	35				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70				
105	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
106	Khulna 115 PP MW (KPC-2)	HFO (QRPP)	7x17	115	115	0	93	115	115				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
108	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	90	90	90				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	540	628	569	810				
Khulna Zone Total						2288	2284	1919	1796	185	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	64	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	28	25	25				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	10	10	10	10				
115	Payra 1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	440	530	600	660				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				36	35	35	35				
	United Payra Power Ltd.	HFO (IPP)				0	0	0	0				
Barishal Zone Total						1054	1054	648	780	840	0	194	
116	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
120	Amnura 50 MW PP(Sirha)	HFO (QRPP)	7x7.79	50	50	12	12	35	35				
121	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	43	70	100	100				
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	149	147	220	220				
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	326	398	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22				
130	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	0	100	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	111	111	113	113				
Rajshahi Zone Total						2193	2183	1366	1490	601	0		
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	83	80	88	88				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
136	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
137	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
138	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	113	113	113				
139	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Majpara, Tatulia 8 MW Solar PP (Sympa P)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
Rangpur Zone Total						685	605	87	193	209	201	85	274
Sub-total: Plants in operation						20595	20104	6930.0	8950	11926	13152	3392	2254
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						6541	8447	11255	12413				
(B) Contract expired power plants													
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0				
Gross Total						20595	20104	6930	8950	11926	13152	3392	2254
(C) Actual data of 23.12.20 (Yesterday) Wednesday :													
01.	Max. Demand (Generation end)	:	8950.00	MW, at = 19:30 hrs		12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand (Sub-station end)	:	8447.00	MW, at = 19:30 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	8950.00	MW, at = 19:30 hrs		MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	5555.00	MW, at = 5:30 hrs		Dhaka	2957	2957	0	Mymensingh	678	678	0
05.	Day-peak Generation (Generation end)	:	6930.00	MW, at = 12:00 hrs		Chattogram	1011	1011	0	Sylhet	314	314	0
06.	Evening-peak Generation (Generation end)	:	8950.00	MW, at = 19:30 hrs		Khulna	1063	1063	0	Barishal	220	220	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 19:30 hrs		Rajshahi	886	886	0	Rangpur	588	588	0
08.	Actual Minimum Generation up to 8:00 hrs.	:	5510.00	MW, at = 7:00 hrs and		Cumilla	730	730	0				
09.	Generation shortfall at evening peak due to :	:								Total	8447	8447	0
	a) Gas limitation	:	3125	MW		13.	Fuel cost :	(a) Gas = 117181690 Taka	(c) Coal = 61357839 Taka				
	d) Coal supply Limitation	:	85	MW			(b) Oil = 294770481 Taka	Total = 473310010 Taka					
	b) Low water level in Kaptai lake	:	182	MW									
	c) Plants under shut down/ maintenance	:	2254	MW		14.	Maximum Temperature in Dhaka was :	26.0° C					
10.	Total Energy (Generation + India Import)	:	169.15	MKWh		15.	Export through East-West interconnections :						
	By Gas = 102.744	MKWh		37.587	MKWh		At evening peak-hour	:	-156	MW, at	19:30 hrs		
	By Coal = 13.249	MKWh		1.033	MKWh		Maximum	:	-196	MW, at	20:00 hrs		
	By Solar= 0.424	MKWh					Energy	:	0.4455	MKWh			
11.	Total Gas Supplied	:	795.49	MMCFD									
(D) Forecast of 24.12.20 (Today) Thursday :													
01.	Maximum Demand	:	8900	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13152	MW (Generation end)		05.	Total Generation	:	168.21	MKWh			
03.	Maximum Shortage	:	-4252	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	25.6° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation