

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2020					Day : Tuesday				Date : 29.12.20				
Probable Maximum Demand : 8900 MW					Probable Maximum Generation : 13822 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.38 ft Today = 98.32 ft.					Rule Curve = 103.30 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.12.20 (Yesterday)		29.12.20 (Today)		28.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0	85	Under maint.		
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	94	94	102	102	76	Gas Shortage		
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	STG Commissioning		
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.		
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300				
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12				
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	275	270	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	315	418	412	412				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.		
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	15	100	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305	Gas Shortage		
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	82	82	100	100				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	65	100	100				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	28	55	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	92	84	100	100				
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	24	100	100				
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19				
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	57	58	58	58				
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	17	17				
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	34	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	105	105				
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	115	150	150				
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	270	300	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	112	149	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300				
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
33	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	100				
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	0	35	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
36	Bosila 108MW PP(IEI)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104				
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	100	160				
Dhaka Zone Total				6281	6057	1872	2687	3447	3797	1019	905		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	47	46	45	45	184	Low Water Level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	39	50	50				
45	Sikalbaha 105 MW PP (Baraka Siku)	HFO (IPP)	6x18.415	105	105	0	0	100	100				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Gas Shortage		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	163	0	160	160	225	Gas Shortage		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	161	217	300	300				
49	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	30	100	100				
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	100	100				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	19	19				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	15	10	15				
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	52	102	102				
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	54	54				
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	70	100	100	100				
	Anlima Energy Ltd.	HFO (IPP)				38	0	0	0				
Chattogram Zone Total				2326	2266	678	755	1400	1380	739	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	100	135	110	110	0	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	100	70	80	80				
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	0	0	60	200				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	325	350	360	360				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Under maint.		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	57	5	5				
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	45	8	8	150	Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	135	143	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	49	50	50				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	90	85	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	25	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	10	25	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	22	20	22				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.02	200	200	0	0	0	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	113	113				
**	Impoport (Tripura)	India		160	160	70	108	110	148				
Cumilla Zone Total				3040	2980	1104	1231	1554	1992	284	360		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	89	92	110	110	110	Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	20	20				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	42	90	95	95				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	32	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	2	0	1.6	0				
84	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	38	0	50	0				
	Tangail 22 MW PP(Pali Power Gen	HFO (SIPP)				0	0	0	22				
Mymensingh Zone Total				695	687	306	351	592	562	110	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.12.20 (Yesterday)		29.12.20 (Today)		28.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)					
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	20	30	30	30							
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	32	32	30	30							
87	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	49	53	51	51							
88	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	47	47	44	44							
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	163	163							
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11							
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	34	33	33							
92	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	152	152	155	155	178		Gas Shortage				
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	73	72	86	86							
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	122	215	200	200							
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	19	20	20							
96	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0							
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0							
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	15	16	16	16							
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	295	320	320							
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Gas Shortage				
	Bibiyana South 400 MW	Gas (PDB)				0	20	280	280							
	Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	100	100							
Sylhet Zone Total						871	996	1539	1539	578	0					
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16							
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	225	190	230	230	220		Gas Shortage				
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	35	35							
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70							
105	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220							
106	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	115	115	115							
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100							
108	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40							
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	90	90	90							
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100							
**	Bheramara (HVDC)	India		1000	1000	569	806	581	821							
Khulna Zone Total						2288	2284	884	1201	1311	1837	220	0			
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110							
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	28	25	25							
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	10	69	10	10							
115	Payra 1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	360	450	600	660							
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				15	31	35	35							
	United Payra Power Ltd.	HFO (IPP)				55	55	55	55							
Barishal Zone Total						1054	1054	454	649	835	895	0	194			
116	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage				
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50							
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200							
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40							
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	12	34	35	35							
121	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	53	34	100	100							
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50							
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50							
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34							
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage				
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage				
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	140	143	220	220							
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	409	293	400	400							
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22							
130	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0							
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11							
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52							
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	0	113	113	113							
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	111	111	113	113							
Rajshahi Zone Total						2193	2183	752	761	1366	1490	601	0			
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	64	64	68	68							
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage				
136	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	149	149		274	Under maint.				
137	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
138	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	37	113	113	113							
139	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
140	Majpara, Tatulia 8 MW Solar PP (Sympa P)	Solar (IPP)	1 x 8	8	8	4	0	8	0							
Rangpur Zone Total						685	605	105	177	338	330	85	274			
Sub-total: Plants in operation						20595	20104	7026.0	8808	12382	13822	3636	1913			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						6674	8367	11762	13130							
(B) Contract expired power plants																
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0							
Gross Total				20595	20104	7026	8808	12382	13822	3636	1913					
(C) Actual data of 28.12.20 (Yesterday) Monday :																
01.	Max. Demand (Generation end)	:	8808.00 MW, at = 19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
02.	Max. Demand (Sub-station end)	:	8367.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
03.	Highest Generation (Generation end)	:	8808.00 MW, at = 19:00 hrs													
04.	Minimum Generation (Generation end)	:	5588.00 MW, at = 5:00 hrs	Dhaka	2957	2957	0	Mymensingh	710	710	0					
05.	Day-peak Generation (Generation end)	:	7026.00 MW, at = 12:00 hrs	Chattogram	878	878	0	Sylhet	313	313	0					
06.	Evening-peak Generation (Generation end)	:	8808.00 MW, at = 19:00 hrs	Khulna	1092	1092	0	Barishal	239	239	0					
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 19:00 hrs	Rajshahi	866	866	0	Rangpur	585	585	0					
08.	Actual Minimum Generation up to 8:00 hrs.	:	5419.00 MW, at = 7:00 hrs	Cumilla	727	727	0									
09.	Generation shortfall at evening peak due to :	:						Total	8367	8367	0					
	a) Gas limitation	:	3367 MW	13. Fuel cost :				(a) Gas = 117242964 Taka	(c) Coal = 57862850 Taka							
	d) Coal supply Limitation	:	85 MW					(b) Oil = 295372739 Taka	Total = 470478553 Taka							
	b) Low water level in Kaptai lake	:	184 MW													
	c) Plants under shut down/ maintenance	:	1913 MW													
10.	Total Energy (Generation + India Import)	:	170.22 MKWh	14. Maximum Temperature in Dhaka was :				25.4° C								
	By Gas = 101.771 MKWh		39.011 MKWh	15. Export through East-West interconnections :												
	By Coal = 12.483 MKWh		1.094 MKWh					At evening peak-hour	:	-162 MW, at	19:00 hrs					
	By Solar= 0.358 MKWh							Maximum	:	-164 MW, at	20:00 hrs					
11.	Total Gas Supplied	:	825.37 MMCFD					Energy	:	0.455 MKWh						
(D) Forecast of 29.12.20 (Today) Tuesday :																
01.	Maximum Demand	:	8900 MW (Generation end)	04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)								
02.	Maximum Generation	:	13822 MW (Generation end)	05.	Total Generation	:	172.00 MKWh									
03.	Maximum Shortage	:	-4922 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	25.2° C									

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation