

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2021					Day : Friday				Date : 01.01.21				
Probable Maximum Demand : 8000 MW					Probable Maximum Generation : 12833 MW					Rule Curve = 103.00 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.21 ft		Today = 98.15 ft.						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.12.20 (Yesterday)		01.01.21 (Today)		31.12.20 (Yesterday)		01.01.21 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW		Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85		Under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170			Gas Shortage
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	10	0	0		170		STG Commissioning
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190		Under maint.
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	330	300	300	300				
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	90	100	100				
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78			Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20			Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	342	287	360	360				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	310	380	412	412				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335		Under maint.
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	50	100	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305			Gas Shortage
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	50	100	100	100				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	48	81	100	100				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	93	100	100	100				
19	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	32	0	100	100				
20	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	16	19	19				
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	57	57	58	58				
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	17	17				
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	33	33	33				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	25	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	105	105				
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	149	150	150				
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	285	300	300	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	101	131	149	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	78	100	300				
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
33	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	100				
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	35	25	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	55	55				
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	70	90	104	104				
38	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	162	162	162	162				
Dhaka Zone Total				6281	6057	2269	2950	3525	3815	1113	895		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	45	45	184			Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	32	50	50	50				
45	Sikalbaha 105 MW PP (Baraka Siku)	HFO (IPP)	6x18.415	105	105	0	0	100	100				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Gas Shortage
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225			Gas Shortage
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	161	0	300	300				
49	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	70	100	100				
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	26	100	100	100				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	19	19	19				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	34	25	35				
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	71	102	102				
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	38	0	54	54				
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	96	100	100	100				
	Anlima Energy Ltd.	HFO (IPP)				65	123	124	124				
Chattogram Zone Total				2326	2266	509	740	1381	1366	739	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	140	140	135	135				
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	223	183	221	221				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	110	110				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	5	0	195	195		360		Under maint.
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	25	5	5	30			Gas Shortage
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187			Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	147	133	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	50	50	50				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	120	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	15	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	21	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.02	200	200	0	0	0	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	24	46	113	113				
**	Impoport (Tripura)	India		160	160	78	104	110	148				
Cumilla Zone Total				3040	2980	938	985	1615	1903	480	360		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	101	109	150	150	93			Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	90	95	95				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	8	115	115				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	155	200	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	2	0	1.6	0				
84	Sutakihali 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0				
	Tangail 22 MW PP(Pali Power Gen	HFO (SIPP)				26	26	22	22				
Mymensingh Zone Total				695	687	363	455	656	604	93	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.12.20 (Yesterday)		01.01.21 (Today)		31.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	20	20	30	30				
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	22	22	22	22				
87	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	8	8	51	51				
88	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	5	5	44	44				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	33	33	33				
92	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	145	145	155	155	185		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	70	67	86	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	152	137	150	150				
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	20	20				
96	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	280	320	320				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Gas Shortage	
	Bibiyana South 400 MW	Gas (PDB)				364	415	300	400				
	Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0				
Sylhet Zone Total						2033	1988	1107	1143	1238	1338	585	0
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	220	135	225	225	275		Gas Shortage	
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	35	35				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	3	70	70				
105	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
106	Khulna 115 PP MW (KPC-2)	HFO (QRPP)	7x17	115	115	66	66	115	115				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	36	50	100				
108	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.415	105	105	90	105	90	90				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	71	100	100				
**	Bheramara (HVDC)	India		1000	1000	579	814	446	783				
Khulna Zone Total						2288	2284	955	1270	1171	1794	275	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	25	25	25				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x96	95	95	89	88	90	90				
115	Payra 1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	0	0	0	0				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				25	37	35	35				
	United Payra Power Ltd.	HFO (IPP)				0	55	0	0				
Barishal Zone Total						1054	1054	134	237	260	260	0	194
116	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
120	Ammura 50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	24	35	35				
121	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	87	100	100				
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.9	50	50	0	0	50	50				
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	140	127	220	220				
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	431	352	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
130	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	44	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	97	108	113	113				
Rajshahi Zone Total						2193	2183	811	888	1366	1490	601	0
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
136	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150				
137	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
138	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	35	113	113				
139	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Majpara, Tatulia 8 MW Solar PP (Sympa P)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total						685	605	189	185	271	263	170	0
Sub-total: Plants in operation						20595	20104	7275.0	8853	11483	12833	4056	1629
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						6860	8348	10828	12101				
(B) Contract expired power plants													
	Sub-Total: Plants under long term maintenance			0	0	0	0	0	0				
Gross Total						20595	20104	7275	8853	11483	12833	4056	1629
(C) Actual data of 31.12.20 (Yesterday) Thursday :													
01.	Max. Demand (Generation end)	:	8853.00 MW, at = 19:00 hrs			12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand (Sub-station end)	:	8348.00 MW, at = 19:00 hrs			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	8853.00 MW, at = 19:00 hrs			Dhaka	2939	2939	0	Mymensingh	696	696	0
04.	Minimum Generation (Generation end)	:	5571.00 MW, at = 5:00 hrs			Chattogram	931	931	0	Sylhet	309	309	0
05.	Day-peak Generation (Generation end)	:	7275.00 MW, at = 12:00 hrs			Khulna	1075	1075	0	Barishal	233	233	0
06.	Evening-peak Generation (Generation end)	:	8853.00 MW, at = 19:00 hrs			Rajshahi	851	851	0	Rangpur	598	598	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 19:00 hrs			Cumilla	716	716	0				
08.	Actual Minimum Generation up to 8:00 hrs.	:	5422.00 MW, at = 7:00 hrs										
09.	Generation shortfall at evening peak due to :	:								Total	8348	8348	0
	a) Gas limitation	:	3702 MW			13.	Fuel cost :	(a) Gas = 102292183 Taka		(c) Coal = 19990044 Taka			
	d) Coal supply Limitation	:	170 MW					(b) Oil = 335323420 Taka		Total = 457605647 Taka			
	b) Low water level in Kaptai lake	:	184 MW										
	c) Plants under shut down/ maintenance	:	1629 MW			14.	Maximum Temperature in Dhaka was :	26.3° C					
10.	Total Energy (Generation + India Import)	:	161.86 MMCFD			15.	Export through East-West interconnections :						
	By Gas = 91.600 MKWH			49.156 MKWH			At evening peak-hour	: -313 MW, at 19:00 hrs					
	By Coal = 3.688 MKWH			1.083 MKWH			Maximum	: -420 MW, at 20:00 hrs					
	By Solar = 0.450 MKWH						Energy	: 3.4 MKWH					
11.	Total Gas Supplied	:	789.78 MMCFD										
(D) Forecast of 01.01.21 (Today) Friday :													
01.	Maximum Demand	:	8000 MW (Generation end)			04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	12833 MW (Generation end)			05.	Total Generation	:	146.26 MKWH				
03.	Maximum Shortage	:	-4833 MW (Generation end)			06.	Probable Max. Temperature in Dhaka :	:	26.0° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation