

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2021					Day : Monday				Date : 11.01.21				
Probable Maximum Demand : 9500 MW					Probable Maximum Generation : 13464 MW					Rule Curve = 101.10 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 97.59 ft		Today = 97.53 ft.						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.01.21 (Yesterday)		11.01.21 (Today)		10.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.	
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under maint.	
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	110	110	110				
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	380	380	360	360				
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	99	99	50	102				
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	347	363	360	360				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Under maint.	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	367	383	412	412				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	100	97	0	100	113		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.	
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	7	7	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305		Gas Shortage	
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	16	74	100	100				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	64	80	100	100				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	50	86	100	100				
19	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	16	16	100	100				
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
21	Summit Power,(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.3	80	80	50	53	58	58				
22	Meona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	25	25				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	25	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	70	105	105				
26	Kodda 150MW PP	HFO (BPD&RPCL)	9x17.06	149	149	64	98	149	149				
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	285	300	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	100	128	149	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300				
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
33	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	100				
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	55	55	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	35				
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	104	90	90				
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	72	162	162				
Dhaka Zone Total				6281	6057	2078	2732	3388	3830	1071	885		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	45	48	45	45	182		Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	32	46	50	50				
45	Sikalbaha 105 MW PP (Baraka Siku	HFO (IPP)	6x18.415	105	105	0	0	100	100				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Gas Shortage	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	125	215	300	300				
49	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	40	70	100	100				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	17	10	20				
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	10	102	102				
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	54	54				
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	70	100	100	100				
	Anilima Energy Ltd.	HFO (IPP)				0	0	0	0				
Chattogram Zone Total				2326	2266	390	704	1240	1225	737	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	70	70	70	70	64		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	160	218	225	225				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	260	215	300	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	285	295	300	360				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	50	50	50		Gas shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	98	112	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	91	84	90	90				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	37	101	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	25	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	17	20	22				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+4x0.15+15x1.05	200	200	0	0	0	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	45	45	113	113				
**	Impoport (Tripura)	India		160	160	90	102	134	146				
Cumilla Zone Total				3040	2980	1250	1380	1957	2311	565	0		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	107	106	120	140	96		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	72	95	95				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	16	115	115				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	120	200	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
84	Sutahikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	34	0	50	0				
85	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	24	23	22	22				
Mymensingh Zone Total				717	709	324	439	626	594	96	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.01.21 (Yesterday)		11.01.21 (Today)		10.01.21 (Yesterday)		11.01.21 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	45	45						
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	10	22	22	22						
88	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	53	53	51	51						
89	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	50	50	44	44						
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0						
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	65	67	68	68						
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	0	0	0	0		330			Under maint.	25/01/2021
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	70	70	70						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	143	143	200	200						
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20						
97	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	7	9	9						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	16	16						
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	310	330	330						
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400				Gas Shortage	
	Bibiyana South 400 MW	Gas (PDB)				130	130	0	0						
	Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0					On Test	
Sylhet Zone Total						877	919	886	886	400	330				
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16						
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	310	260	300	325	150				Gas Shortage	
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	35	35						
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70						
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220						
107	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	99	115	115	115						
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	60	0	50	100						
109	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	33	40	40	40						
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	105	105						
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100						
**	Bheramara (HVDC)	India		1000	1000	662	731	694	838						
Khulna Zone Total						2288	2284	1181	1163	1509	1964	150	0		
112	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110						
113	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	26	24	26						
114	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194			Under maint.	
115	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x96	95	95	21	52	60	61						
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	380	500	600	600						
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				50	19	50	56						
	United Payra Power Ltd.	HFO (IPP)				54	54	54	54						
Barishal Zone Total						1676	1676	524	667	898	907	0	194		
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71				Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100				Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50						
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200						
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40						
121	Ammura 50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	0	35	35						
122	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	43	96	94	94						
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50						
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50						
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34						
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210				Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220				Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	149	180	220	220						
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	413	395	400	400						
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	22	22						
131	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0						
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11						
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	24	52	52						
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	70	113	113	113						
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	90	113	113	113						
Rajshahi Zone Total						2193	2183	788	947	1360	1484	601	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85				Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85				Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150						
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	70	99	113	113						
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
141	Majpara, Tatulia 8 MW Solar PP (Sympa P)	Solar (IPP)	1 x 8	8	8	3	0	8	0						
Rangpur Zone Total						685	605	223	249	271	263	170	0		
Sub-total: Plants in operation						21239	20748	7635.0	9200	12135	13464	3790	1589		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7262	8750	11541	12805						
(B) Contract expired power plants															
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0						
Gross Total				21239	20748	7635	9200	12135	13464	3790	1589				
(C) Actual data of 10.01.21 (Yesterday) Sunday :															
01.	Max. Demand (Generation end)	:	9200.00 MW, at = 19:00 hrs			12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand (Sub-station end)	:	8750.00 MW, at = 19:00 hrs			Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	9200.00 MW, at = 19:00 hrs			MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	5757.00 MW, at = 5:00 hrs			Dhaka	3127	3127	0	Mymensingh	754	754	0		
05.	Day-peak Generation (Generation end)	:	7635.00 MW, at = 12:00 hrs			Chattogram	945	945	0	Sylhet	328	328	0		
06.	Evening-peak Generation (Generation end)	:	9200.00 MW, at = 19:00 hrs			Khulna	1096	1096	0	Barishal	240	240	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 19:00 hrs			Rajshahi	912	912	0	Rangpur	589	589	0		
08.	Actual Minimum Generation up to 8:00 hrs.	:	5886.00 MW, at = 7:00 hrs			Cumilla	759	759	0						
09.	Generation shortfall at evening peak due to :	:								Total	8750	8750	0		
	a) Gas limitation	:	3438 MW			13.	Fuel cost :	(a) Gas = 112969655 Taka	(c) Coal = 67531776 Taka						
	d) Coal supply Limitation	:	170 MW				(b) Oil = 298466490 Taka	Total = 478967921 Taka							
	b) Low water level in Kaptai lake	:	182 MW												
	c) Plants under shut down/ maintenance	:	1589 MW			14.	Maximum Temperature in Dhaka was :	28.2° C							
10.	Total Energy (Generation + India Import)	:	178.25 MKWh			15.	Export through East-West interconnections :								
	By Gas = 105.266 MKWh		40.270 MKWh				At evening peak-hour	:	35 MW, at 19:00 hrs						
	By Coal = 14.524 MKWh		By Hydro = 1.120 MKWh				Maximum	:	-22 MW, at 20:00 hrs						
	By Solar = 0.332 MKWh						Energy	:	0.022 MKWh						
11.	Total Gas Supplied	:	814.37 MMCFD												
(D) Forecast of 11.01.21 (Today) Monday :															
01.	Maximum Demand	:	9500 MW (Generation end)			04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	13464 MW (Generation end)			05.	Total Generation	:	184.07 MKWh						
03.	Maximum Shortage	:	-3964 MW (Generation end)			06.	Probable Max. Temperature in Dhaka :	:	29.3° C						

*