

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2021					Day : Tuesday				Date : 12.01.21				
Probable Maximum Demand : 9500 MW					Probable Maximum Generation : 13148 MW					Rule Curve = 100.91 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 97.53 ft		Today = 97.47 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.01.21 (Yesterday)		12.01.21 (Today)		11.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0	85	Under maint.		
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.		
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	150	170				
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	360	365	360	360				
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	50	102	108	Gas Shortage		
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	293	244	360	360				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under maint.		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	368	353	412	412				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	7	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305	Gas Shortage		
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	28	100	100	100				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	64	80	80	80				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	76	86	85	86				
19	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	61	0	100	100				
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
21	Summit Power,(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	57	56	58	58				
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	52	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	2	90	105	105				
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	133	149	149				
27	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	6	50	50				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	5	54	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	286	286	300	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	103	120	149	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	274	100	300				
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	30	50	100				
33	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	54	60	100				
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	55	55	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	9	37	35	37				
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	36	36	36	36				
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	90	90				
Dhaka Zone Total				6281	6057	2103	2873	3275	3640	1276	885		
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	47	45	47	183	Low Water Level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	25	25	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	46	46	50	50				
45	Sikalbaha 105 MW PP (Baraka Siki	HFO (IPP)	6x18.415	105	105	0	0	0	100				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Gas Shortage		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Gas Shortage		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	308	50	300	300				
49	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	60	100	100				
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	19	10	20				
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	93	90	93				
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
56	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100				
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0				
Chattogram Zone Total				2326	2266	694	713	1128	1218	738	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	5	5				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	150	124	225	225				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	275	260	300	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	270	300	360				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas shortage		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	112	143	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	51	40	60	60				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	85	70	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	24	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	22	20	22				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.05	200	200	0	0	0	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	34	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	64	75	113	113				
**	Impoport (Tripura)	India		160	160	92	104	134	146				
Cumilla Zone Total				3040	2980	1259	1295	1791	2145	635	0		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	104	106	120	120	96	Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	65	72	95	95				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	65	115	115				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	200	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
84	Sutiali 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0				
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	24	24	24	24				
Mymensing Zone Total				717	709	414	487	628	576	96	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.01.21 (Yesterday)		12.01.21 (Today)		11.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW				
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30					
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	22	22	22	22					
88	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	50	53	51	51					
89	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	50	50	44	44					
90	Kushlara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	35	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	66	68	68					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	0	0	0	0		330	Under maint.	25/01/2021	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	69	72	70	70					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0					
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20					
97	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	9	9					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	310	330	330					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Gas Shortage		
	Bibiyana South 400 MW	Gas (PDB)				100	120	120	120					
	Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0			On Test		
Sylhet Zone Total				2033	1988	743	804	946	946	400	330			
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	248	195	300	300	215		Gas Shortage		
104	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	2	4	35	35					
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70					
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
107	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	115	115	115					
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	85	50	100					
109	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	8	40	40	40					
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	105	105					
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	681	728	694	838					
Khulna Zone Total				2288	2284	1039	1184	1509	1939	215	0			
112	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110					
113	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	27	24	27					
114	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.		
115	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	32	87	90	90					
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	420	560	600	600					
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				31	17	50	56					
	United Payra Power Ltd.	HFO (IPP)				0	0	54	54					
Barishal Zone Total				1676	1676	502	723	928	937	0	194			
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	50					
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40					
121	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	25	25	25					
122	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	52	104	104	104					
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50					
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	24	50	50					
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34					
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	143	135	220	220					
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	345	321	400	400					
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	22	22					
131	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0					
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11					
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	52	52	52					
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	113	113	113					
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113					
Rajshahi Zone Total				2193	2183	805	947	1360	1484	601	0			
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150					
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	107	113	113					
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Majpara, Tatalia 8 MW Solar PP (Sympla P)	Solar (IPP)	1 x 8	8	8	3	0	8	0					
Rangpur Zone Total				685	605	187	257	271	263	170	0			
Sub-total: Plants in operation				21239	20748	7746.0	9283	11836	13148	4131	1589			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7441	8918	11370	12631					
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0					
Gross Total				21239	20748	7746	9283	11836	13148	4131	1589			
(C) Actual data of 11.01.21 (Yesterday) Monday :														
01.	Max. Demand (Generation end)	:	9283.00 MW, at = 19:30 hrs			12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand (Sub-station end)	:	8918.00 MW, at = 19:30 hrs			Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	9283.00 MW, at = 19:30 hrs			MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	5886.00 MW, at = 5:00 hrs			Dhaka	3226	3226	0	Mymensingh	770	770	0	
05.	Day-peak Generation (Generation end)	:	7746.00 MW, at = 12:00 hrs			Chattogram	1050	1050	0	Sylhet	323	323	0	
06.	Evening-peak Generation (Generation end)	:	9283.00 MW, at = 19:30 hrs			Khulna	1092	1092	0	Barishal	242	242	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 19:30 hrs			Rajshahi	890	890	0	Rangpur	576	576	0	
08.	Actual Minimum Generation up to 8:00 hrs.	:	5981.00 MW, at = 7:00 hrs			Cumilla	749	749	0					
09.	Generation shortfall at evening peak due to :	:								Total	8918	8918	0	
	a) Gas limitation	:	3778 MW			13.	Fuel cost :	(a) Gas = 104211277 Taka	(c) Coal = 69790349 Taka					
	d) Coal supply Limitation	:	170 MW					(b) Oil = 422905339 Taka	Total = 596906965 Taka					
	b) Low water level in Kaptai lake	:	183 MW											
	c) Plants under shut down/ maintenance	:	1589 MW			14.	Maximum Temperature in Dhaka was : 28.1° C							
10.	Total Energy (Generation + India Import)	:	183.43 MKWh			15.	Export through East-West interconnections :							
	By Gas = 96.612 MKWh		53.247 MKWh				At evening peak-hour	:	121 MW, at 19:30 hrs					
	By Coal = 15.034 MKWh		By Hydro = 1.136 MKWh				Maximum	:	24 MW, at 18:30 hrs					
	By Solar= 0.152 MKWh						Energy	:	0.006 MKWh					
11.	Total Gas Supplied	:	735.15 MMCFD											
(D) Forecast of 12.01.21 (Today) Tuesday :														
01.	Maximum Demand	:	9500 MW (Generation end)			04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	13148 MW (Generation end)			05.	Total Generation : 187.72 MKWh							
03.	Maximum Shortage	:	-3648 MW (Generation end)			06.	Probable Max. Temperature in Dhaka : 27.5° C							

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation