

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS							Page -2
20-Jan-21							
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Enerov Generated	Remarks
			Unit No. X Capacity	Generation			
			MW	MW	MW		
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	231	5543000	
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	380	8610027	
3	Ghorashal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	324	7915832	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	215	5790000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	0	0	Under maint.
9	Meghnaghat 100 MW(IEI)	QRPP	12*8.9	100	68	633600	Low demand
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	100	1412808	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	375280	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	86	1721521	Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	342828	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	70	848640	Low demand
18	Siddhirganj 335 MW CCPP	EGCB	1*217+118	335	0	0	Under maint.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	74	912960	Low demand
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Reserve.
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	35	528480	Low demand
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	100	1131840	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	609968	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	853044	
25	Bacila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	45	998340	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	0	492700	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	583900	Engine problem
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	0	Reserve.
30	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	5040762	
32	Keraniganj 300 MW PP (APR)	IPP	25*1.4	300	0	0	Reserve.
33	Brahmangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	128	1598830	Engine problem
36	Gazipur 100 MW PP	RPCL	100 MW	105	52	667596	Low demand
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1898880	
38	Manikganj 162MW PP(MPL)	IPP	9*18	162	144	3477600	Engine problem
Dhaka area Total				6057	2662	51988796	
39	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
40	Razcan 25 MW PP	IPP	3*8.9	25	25	366456	
41	Teknaf 20MW PP (Solartech)	Teknaf Solartech Ener	20	20	0	62505	
42	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	634080	
43	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	45	1111593	Unit-2 under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Gas shortage
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
46	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	0	Reserve.
47	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
48	Dohazari-Kalash 100 MW Peaking	PDB	6*17	102	85	293592	
49	Judish 100 MW Unit-1 (Accorn)	QRPP	8*13.45	100	0	47760	Reserve.
50	Jukdah 100 MW PP Unit-3 (Accorn)	IPP	0	100	100	738240	
51	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	457584	Engine problem
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	14	402720	
52	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	12	76800	Low demand
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	14406	
54	Anwara 300 MW PP (United)	IPP	300 MW	300	288	6581345	
55	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1301486	
56	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
57	Judish unit-2 (Accorn)	IPP	8*13.6	100	100	2281920	
	Anilma Energy Ltd.	IPP	6*21.2	0	0	0	on test
Chattogram area Total				2265	792	14360486	
58	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage
59	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	174	3912000	Gas shortage
60	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	270	6660100	Gas shortage
61	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	235	5810000	Gas shortage
62	Ashuganj 50 MW PP	APSCL	14*3.68	45	3	71064	Gas shortage
63	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	0	0	Gas shortage
64	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	217454	Gas shortage
65	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1233565	
66	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	75	1545600	Engine problem
67	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
68	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	36	868410	Machine problem
69	Chandpur 200MW (Desh energy)	IPP	0	200	50	661920	High Voltage.
70	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	445752	
71	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	189000	Engine problem
**	Impoport (Tripura)	Imported power	0	160	106	2087040	
72	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	701100	Machine problem
73	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	8	44040	Low demand
74	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	466310	Machine problem
75	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve.
76	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.
77	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	26	628320	Low demand
Cumilla Area Total				2980	1115	2541675	
78	RPCL 210MW CCPP	IPP	4*35+1*70	202	105	2377520	Gas shortage
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	461484	
80	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	72	939840	Engine problem
81	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	4300	
82	Mymensingh 200 MW PP (United)	IPP	200	200	200	3566800	Low demand
83	Jamalpur 115 MW PP (United)	IPP	115 MW	115	45	403200	#REF!
84	Sutiakhal 50 MW Solar PP	IPP	50	50	0	83600	
85	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	25	418560	
Mymensingh Area Total				709	464	8245304	
86	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	0	0	Gas shortage & GT-2 under maint.
87	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	30	720000	GT-4 under maint.
88	Kushia 163 MW CCPP (KP)	IPP	1*109+1*54	163	140	3323291	Frequency Control
89	Shajibazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.
90	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	47	426600	
91	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	50	748368	
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	260100	
93	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	20	583008	Gas shortage
94	Shahjibazar 80MW PP (Shahjibazar)	RPP	32*2.90	86	72	1681920	Engine problem
95	Shahjibazar 100 MW GTTP	PDB	1*100	0	0	315000	On test.
96	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	194	3751880	
97	Sylhet 20 MW GTTP	PDB	1*20	20	0	23000	Engine problem
98	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
99	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	190144	Engine problem
99	Bibiana-I 341 MW CCPP (Summit)	IPP	1*222+1*119	341	290	7268500	FGMO
100	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Gas shortage & Bibiyana south test
101	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	81540	
	Bibiyana South 400 MW	PDB	400 MW	0	120	5149480	On test
Sylhet Area Total				1988	991	24522151	
102	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	867	15992000	
103	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	2015040	
104	Fandipur 50 MW Peaking PP	PDB	8*6.89	54	5	115060	Low demand
105	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
106	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	6	24120	Low demand
107	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	300	8084160	Gas shortage
108	Noapara 40 MW PP (Kharajahan Ali)	QRPP	5*8.5	40	33	113775	
109	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Reserve.
110	Rupsha 105 MW PP (Onon rupsha)	IPP	6*18.445	105	92	1251360	Engine problem
111	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1418	27599115	
112	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	16	70464	Low demand
113	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	22	483700	Engine problem
114	Bhola 225 MW CCPP	PDB	2*63+1*68	194	0	0	Under maint.
115	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	68	1226410	Engine problem
116	Payra 1320 MW	BPCL	2*622	1244	550	11167700	High Voltage.
	Brook Nelson Special 80 LTD	IPP	220	0	57	126018	On test.
	United Payra Power Ltd.	IPP	8*18.5+1*9.5	0	0	0	On test.
Barisal Area Total				1676	713	14209092	
117	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
118	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	124144	
119	Bera						