

Date : 22-Jan-21			Page -2				
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CCPP Unit-1	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	242018	Gas shortage
3	Ghorasah 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Contract Expired
4	Ghorasah 108MW PP (Regent)	IPP	34*3.35	108	107	1244090	
5	Haripur GTTP	SEBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	349	8239100	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	304	6742000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	0	0	Under maint.
9	Meghnaghat 100 MW(IEEL)	QRPP	12*8.9	100	100	672960	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	99	1096728	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	15	299644	High Voltage.
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	74	1400530	Engine problem
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	345744	Under maint.
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla	QRPP	12*8.9	100	15	114240	High Voltage.
18	Siddhirgonj 335 MW CCPP	EGCB	1*21+1*118	335	0	0	Under maint.
19	Gagragar 102 MW PP (Digital Po	IPP	12*8.924	102	58	1069920	High Voltage.
20	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Reserve.
21	Kamalaghat 54 MW PP (Banco En	IPP	3*18	54	17	250200	High Voltage.
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	48	395040	High Voltage.
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	285547	Engine problem
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	849962	
25	Bostia 108MW PP(CLO)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
26	Summit Power (Madhabadi+Ashuli	SIPP, REB	3*3.67+4*8.73	80	52	1078620	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	582600	Engine problem
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	571400	
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	0	Reserve.
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit	IPP	18*17.076	300	300	5462289	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	55	110114	
33	Bramhangaoan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit	IPP	149	149	101	1363680	High Voltage.
36	Gazipur 100 MW PP	RPCL	100 MW	105	17	150492	High Voltage.
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*5	104	90	1486080	Engine problem
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	144	3134880	Engine problem
Dhaka area Total				8057	2109	39367878	
39	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.
40	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
41	Raozan 25 MW PP	IPP	3*8.9	25	0	0	Reserve.
42	Teknaf 20MW PP (Solartech)Teknaf	Solartech Energy	20	20	0	117045	
43	Paterga 50MW PP (Baraka)	IPP	8*6.88	50	50	863630	
44	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	47	1123113	Unit-2 under maint.
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Gas shortage
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
47	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	0	0	Reserve.
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
49	Dohazari-Kalash 100 MW Peakir	PDB	6*17	102	85	391518	
50	Juddah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	0	0	Reserve.
51	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	50	838080	High Voltage.
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	463488	Engine problem
53	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	40	931680	
54	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Reserve.
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	25801	
56	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	250	5748327	Low demand
57	Jodiad Power	IPP	3*18.55+1*3.6	54	54	665636	
58	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
59	Juddah unit-2 (Acorn)	IPP	8*13.6	100	100	2213760	
60	Anlima Energy Ltd.	IPP	6*21.2	0	0	0	on test
Chattogram area Total				2266	695	13374768	
61	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas shortage
62	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
63	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
64	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	177	4040000	Gas shortage
65	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	150	4174500	Gas shortage
66	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	230	5751000	Gas shortage
67	Ashuganj 50 MW PP	APSCL	14*3.968	45	3	70560	Gas shortage
68	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	0	0	Gas shortage
69	Ashuganj 195MW PP (APSCL-Un	IPP	20*9.3+1*16	195	8	293227	Gas shortage
70	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1248090	
71	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	50	1117381	Engine problem
72	Titlas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
73	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	50	898880	Machine problem
74	Chandpur 200MW (Desh energy)	IPP	0	200	34	524640	High Voltage.
75	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	451620	
76	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	110520	Engine problem
77	Impoport (Tripura)	Imported power	0	160	96	1776960	
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	740000	
79	Jangalia 52 MW PP (Lakdanav)	IPP	6*8.92	52	0	0	Reserve.
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	22	470130	
81	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
82	Feni Lanka Power Ltd (Summit)	IPP	7*18.415+1*9.78	114	0	0	Reserve.
83	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	75	1162560	High Voltage.
Cumilla Area Total				2980	1006	22728568	
84	RPCL 210MW CCPP	IPP	4*35+1*70	202	105	2794840	Gas shortage
85	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	487980	
86	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	82	663360	High Voltage.
87	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	3950	
88	Mymensingh 200 MW PP (Uniled)	IPP	200	200	200	3583200	Low demand
89	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	8	52800	#REF!
90	Sutakhal 50 MW Solar PP	IPP	50	50	0	170630	
91	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	25	351360	
Mymensingh Area Total				709	442	8108120	
92	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	30	498000	Gas shortage & GT-2 under
93	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	0	0	GT-4 under maint.
94	Kushlira 163 MW CCPP (KP)	IPP	1*109+1*54	163	0	0	High Voltage.
95	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.
96	Fenchugonj 51 MW PP (Barakata	RPP	19*2.90	51	48	652800	
97	Fenchugonj 44MW (Energyprima	RPP	12*3.3+5*2	44	50	771624	
98	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	264000	
99	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	30	722880	GT-8 Under maint.
100	Shahjibazar 60MW PP (Shahjibaz	RPP	32*2.90	96	71	1473600	Engine problem
101	Shahjibazar 100 MW GTTP	PDB	1*100	0	100	228000	On test.
102	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	215	4233750	
103	Sylhet 20 MW GTTP	PDB	1*20	20	19	439000	
104	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
105	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	196176	Engine problem
106	Bibiana-II 341 MW CCPP (Summit	IPP	1*222+1*119	341	315	7485000	FGMO
107	Bibiana-III 490 MW CCPP	PDB	490 MW	0	0	0	Gas shortage & Bibiyana sou
108	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	210600	
109	Bibiana South 400 MW	PDB	400 MW	0	0	3864900	On test
Sylhet Area Total				1988	906	23092330	
110	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
111	Bheramara (HVDC)	Imported power	2*500	1000	713	11823273	
112	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	2188800	
113	Fandpur 50 MW PP (Peaking PP	PDB	8*6.89	54	0	0	Reserve.
114	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
115	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
116	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	320	7547328	Gas shortage
117	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	40	40	199500	
118	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	0	0	Reserve.
119	Rupshah 105 MW PP (Orion rupsh	IPP	6*18.445	105	90	836160	Engine problem
120	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1278	22595061	
121	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
122	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	25	430500	Engine problem
123	Bhola 225 MW CCPP	PDB	2*63+1*68	194	0	0	Under maint.
124	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	72	1442401	High Voltage.
125	Payra 1320 MW	BCPCL	2*622	1244	560	11606900	High Voltage.
126	Bhola Nutan Sadat BD LTD	IPP	220	21	12	125627	On test.
127	Uniled Payra Power Ltd.	IPP	8*18.5+1*9.5	0	0	0	On test.
Barisal Area Total				1676	678	14694828	
128	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage.
129	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
130	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	Reserve.
131	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
132	Amnura 50 MW PP (Sinha)	QRPP	7*7.79	50	25	191450	Engine problem
133	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Reserve.
134	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	0	0	Reserve.
135	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
136	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	Gas shortage