

Date : 26-Jan-21		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CCGP Unit-1	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCGP Unit-2	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	180	4221000	
2	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	108	2564500	
5	Hanipur GTTP	SEU, PDB	2*32	20	0	0	Under maint.
6	Hanipur 412 MW CCGP	EGCB	1*273+1*139	412	0	0	Under maint.
7	Hanipur 360MW CCGP(HPL)	IPP	1*235+1*125	360	353	8348000	
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	0	0	Under maint.
9	Meghnaghat 100 MW(IEEL)	QRPP	12*8.9	100	100	1346880	
10	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	245	6802647	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	25	1312104	High Voltage.
12	Madanganj 35 MW PP(Summit)	(IPP)	3*11.08+1*11.3	55	25	473362	High Voltage.
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	73	1775143	Engine problem
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	454608	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	180	4192000	
17	Siddhirgonj 100 PPI/Dutch Bangla	QRPP	12*8.9	100	30	527040	High Voltage.
18	Siddhirgonj 335 MW CCGP	EGCB	1*21+1*118	335	0	0	Under maint.
19	Gaguar 102 MW PP (Digital Po	IPP	12*8.924	102	102	1602000	
20	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Reserve.
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	35	605880	High Voltage.
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	115	1610400	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	508229	Engine problem
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1123064	
25	Bostia 108MW RPCL/O	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
26	Summit Power (Madhabadi+Ashuli	SIPP,REB	3*3.67+4*8.73	80	56	1316940	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	17	421700	Engine problem
28	Rugganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	838900	
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	0	Reserve.
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	250	5627889	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	100	926502	Low demand
33	Bramhangaoan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit	IPP	149	149	135	2184624	Engine problem
36	Gazipur 100 MW PP	RPCL	100 MW	105	75	861600	Engine problem
37	Meghnaghat 104 MW PP (QPCL)	IPP	18*5.3	104	104	2149440	Engine problem
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	128	2789280	Engine problem
Dhaka area Total				8057	2579	54583732	
39	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW PP	IPP	3*8.9	25	25	268902	
41	Teknaf 20MW PP (Solartech/Teknaf	Solartech Energy	20	20	0	111105	
42	Paterga 50MW PP (Baraka)	IPP	8*6.88	50	0	263300	Reserve.
43	Kaptai Hydro Unit-1,2,3,4, 5	IPP	2*40+3*50	230	67	1537702	Unit-2 under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Gas shortage
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
46	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	34	403963	Low demand
47	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under maint.
48	Dahadgaon-Kalash 100 MW Peakin	PDB	6*17	102	85	987216	
49	Judiah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	20	180480	High Voltage.
50	Judiah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1607040	
51	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	461136	
*	Malancha, Ctg, EPZ (Uniled)		5*8.73+3*9.34	0	28	594720	
52	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	51	356160	High Voltage.
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	27721	
54	Anwara 300 MW PP (Uniled)	IPP	380 MW	300	307	721645	
55	Jodiad Power	IPP	3*18.55+1*3.6	54	54	390745	
56	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
57	Judiah unit-2 (Acorn)	IPP	8*13.6	100	100	2285760	
	Anlima Energy Ltd.	IPP	6*21.2	0	0	0	on test
Chattogram area Total				2266	891	16457115	
58	Ashuganj TPP Unit- 3	APSCL	1*150	135	85	642594	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage
59	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	184	4956000	Gas shortage
60	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	0	1450800	Gas shortage
61	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	355	7577000	Gas shortage
62	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	398232	Gas shortage
63	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	56	766560	Gas shortage
64	Ashuganj 195MW PP(APSCL-Un	IPP	20*9.73+1*16	195	26	418181	Gas shortage
65	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1220751	
66	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	20	470036	Engine problem
67	Titlas 50 MW Peaking PP	PDB	6*8.92	52	8	41704	Low demand
68	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	91	2338830	Machine problem
69	Chandpur 200MW (Desh energy)	IPP	0	200	17	264000	High Voltage.
70	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	465568	
71	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	180000	Engine problem
**	Import (Tripura)	Imported power	0	160	106	2038080	
72	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	408300	
73	Jangalia 52 MW PP (Lakdanav)	IPP	6*8.92	52	0	11515	Reserve.
74	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	502630	
75	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
76	Feni Lanka Power (Summit)	IPP	7*18.415+1*9.78	114	0	0	Reserve.
77	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	85	1150800	Low demand
Cumilla Area Total				2980	1193	25301601	
78	RPCL 210MW CCGP	IPP	4*35+1*70	202	106	2504160	Gas shortage
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	473148	
80	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	40	688320	High Voltage.
81	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	7300	
82	Mymensingh 200 MW PP (Uniled)	IPP	200	200	200	4272000	Engine problem
83	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	72	493200	#REF!
84	Sutakhal 50 MW Solar PP	IPP	50	50	0	6560	
85	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	23	443040	
Mymensingh Area Total				709	463	8887728	
86	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	30	713000	Gas shortage & GT-2 under r
87	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	0	0	Under maint.
88	Kushlara 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3633791	
89	Shajibazar 330 MW CCGP	PDB	3*110	330	0	0	Under maint.
90	Fenchugonj 51 MW PP (Barakata	RPP	19*2.90	51	53	1219800	
91	Fenchuganj 44MW (Energyprima	RPP	12*3.3+5*2	44	50	1195200	
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	264000	
93	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	0	0	GT-8,9 Under maint.
94	Shajibazar 60MW PP (Shajibaz	RPP	32*2.90	86	70	171680	Engine problem
95	Shajibazar 100 MW GTTP	PDB	0	1*100	0	75	On test
96	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	0	1995520	Sync at 19.28
97	Sylhet 20 MW GTTP	PDB	1*20	20	19	443000	
98	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
99	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	354624	Engine problem
100	Bibiana-II 341 MW CCGP (Summ	IPP	1*222+1*119	341	320	7503500	FGMO
101	Bibiana-III 490 MW CCGP	PDB	400 MW	0	0	0	Gas shortage & Bibiana sou
102	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	209160	
103	Bibiyana South 400 MW	PDB	400 MW	0	420	6351000	On test
Sylhet Area Total				1988	1228	27674800	
102	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	869	17144000	
103	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	2450880	
104	Fandpur 50 MW Peaking PP	PDB	8*6.89	54	21	386240	Low demand
105	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve.
106	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	7	33040	Low demand
107	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	340	7471584	
108	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	40	40	451875	
109	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	80	275520	Low demand
110	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	76	1842560	Engine problem
111	Mochmurat 100 MW PP	SWPGCL	100 MW	105	67	610272	High Voltage.
Khulna Area Total				2284	1615	30385971	
112	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	96	1324032	
113	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	23	462000	Engine problem
114	Bhola 225 MW CCGP	PDB	2*63+1*68	194	0	0	Under maint.
115	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	90	2107235	
116	Payra 1320 MW	BCPCL	2*622	1244	0	0	Under maint.
	Bhola Nutan Bidut BD LTD	IPP	220	0	0	0	On test
	Uniled Payra Power Ltd.	IPP	8*18.5+1*9.5	0	35	170400	On test.
Barisal Area Total				1676	244	4063667	
117	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
118	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	597216	
119	Bera 70 MW Peaking PP	PDB	9*8.29	71	10	130905	Low demand
120	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	25	386760	Engine problem
121	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	125064	Engine problem
122	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	0	0	Reserve.
123	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
124	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	167	1830927	Gas shortage
125	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	220	4349755	
126	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	0	60218	
127	Santahar 50 MW Peaking PP	PDB	6*8.7	50	32	287938	
128	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	511440	
129	Bogura 20 MW PP (Energyprima)	RPP	5*3.3+5*2	10	0	0	Contract Expired
130	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	236952	
131	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	500640	
132	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	105	704088	
133	Baghabari 200 MW PP (Paramou	IPP	200 MW	200	0	0	Reserve.
134	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	0	0	Under maint.
135	Confidence Power Bogura Unit-1	IPP	6*18.55	113	76	1123968	Engine problem
Rajshahi Area Total				2183	770	10905871	
136	Barapukuria TPP Unit-1	PDB	1*125	85	0	0	Under maint.
	Barapukuria TPP Unit-2	PDB	1*125	85	0	0	Under maint.
	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	150	3858600	