

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2021					Day : Wednesday				Date : 27.01.21				
Probable Maximum Demand : 9400 MW					Probable Maximum Generation : 12498 MW					Rule Curve = 98.00 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.39 ft		Today = 96.28 ft.						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.01.21 (Yesterday)		27.01.21 (Today)		26.01.21 (Yesterday)		27.01.21 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.	
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under maint.	
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	180	180	180				
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+ 1x 126	365	365	0	0	0	0		365	Under maint.	
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	106	108	108	108				
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0			Contract Expired	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	371	353	360	360				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Under maint.	9/2/2021
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under Maint.	8/2/2021
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	183	180	200	200	30		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.	
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	40	30	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	280	245	305	305	60		Gas Shortage	
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	95	100	100	100				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	80	25	100	100				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	25	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	74	73	100	100				
19	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	80	102	100	100				
20	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	57	56	58	58				
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	25	25				
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	25	75	105	105				
26	Kodda 150MW PP	HFO (BPD&RPCL)	9x17.06	149	149	100	115	149	149				
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	35	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	250	250	300	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	102	135	149	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	82	100	100	100				
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
33	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	55	55	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	91	104	104	104				
38	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	126	126	162	162				
Dhaka Zone Total				6281	6057	2558	2579	3311	3561	665	1662		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	67	67	68	68	163		Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	0	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	50	50				
45	Sikalbaha 105 MW PP (Baraka Sikr	HFO (IPP)	6x18.415	105	105	26	34	0	100				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Gas Shortage	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	306	307	300	300				
49	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	20	100	100				
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	85	102	102				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	28	40	25				
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	25	51	97	97				
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	54	54				
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100				
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0				
Chattogram Zone Total				2326	2266	752	891	1168	1253	718	180		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	85	135	135	50		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26	19		Gas Shortage	
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	183	184	180	180				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	350	355	350	350				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0		360	Under Maint.	3/2/2021
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	35	56	5	5				
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	26	26	26	169		Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	20	20	20				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	8	0	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	100	91	100	100				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	21	20	20				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	11	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	7	0	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	22				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.05	200	200	0	0	0	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	103	85	113	113				
**	Impoport (Tripura)	India		160	160	88	106	135	147				
Cumilla Zone Total				3040	2980	1027	1193	1591	1855	501	360		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	109	106	110	110	96		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	48	40	92	92				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	25	72	115	115				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	200	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
84	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0				
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	23	22	22				
Mymensingh Zone Total				717	709	422	463	613	561	96	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.01.21 (Yesterday)		27.01.21 (Today)		26.01.21 (Yesterday)		27.01.21 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30						
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0						
88	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	48	53	50	50						
89	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	47	50	50	50						
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163						
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0		66			Under maint.	
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	0	0	0	0	330				Gas Shortage	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	69	70	73	73						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	120	120						
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	19	19	20	20						
97	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	9	9						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8						
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	320	341	341						
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400				Gas Shortage	
	Bibiyana South 400 MW	Gas (PDB)				240	420	400	400						
	Shahjibazar 100 MW GTTP	Gas (PDB)				100	75	100	100					On Test	
Sylhet Zone Total						2033	1988	1034	1228	1375	1375	730	66		
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16						
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	380	340	410	410						
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	14	21	25	25						
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	7	70	70						
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220						
107	Khulna 115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	115	115	115	115						
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	80	50	100						
109	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	40	40	40	40						
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	76	90	90						
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	32	67	100	100						
**	Bheramara (HVDC)	India		1000	1000	727	869	732	876						
Khulna Zone Total						2288	2284	1398	1615	1632	2062	0	0		
112	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	60	96	110	110						
113	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	23	22	22						
114	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194			Under maint.	
115	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x96	95	95	89	90	95	95						
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0						
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0						
	United Payra Power Ltd.	HFO (IPP)				0	35	150	150						
Barishal Zone Total						1676	1676	166	244	377	377	0	194		
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71				Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100				Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	50	50	0	50						
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200						
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	40						
121	Ammura 50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	25	25	25	25						
122	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	105	104	104						
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50						
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	50	0	50	50						
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	34						
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210				Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	17	167	220	220	53				Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	147	220	220	220						
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0		414			Under Maint.	13/2/2021
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22						
131	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0						
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52						
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	35	76	113	113						
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	0	0	0	0						
Rajshahi Zone Total						2193	2183	409	770	1067	1191	434	414		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85				Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85				Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150						
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	107	113	113						
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
141	Majpara, Tatulia 8 MW Solar PP (Sympa P)	Solar (IPP)	1 x 8	8	8	1	0	8	0						
Rangpur Zone Total						685	605	151	257	271	263	170	0		
Sub-total: Plants in operation						21239	20748	7917.0	9240	11405	12498	3314	2876		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7602	8872	10950	12000						
(B) Contract expired power plants															
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0						
Gross Total						21239	20748	7917	9240	11405	12498	3314	2876		
(C) Actual data of 26.01.21 (Yesterday) Tuesday :															
01.	Max. Demand (Generation end)	:	9240.00 MW, at = 19:00 hrs			12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand (Sub-station end)	:	8872.00 MW, at = 19:00 hrs			Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	9240.00 MW, at = 19:00 hrs			MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	5815.00 MW, at = 5:00 hrs			Dhaka	2995	2995	0	Mymensingh	803	803	0		
05.	Day-peak Generation (Generation end)	:	7917.00 MW, at = 10:00 hrs			Chattogram	950	950	0	Sylhet	334	334	0		
06.	Evening-peak Generation (Generation end)	:	9240.00 MW, at = 19:00 hrs			Khulna	1100	1100	0	Barishal	229	229	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 19:00 hrs			Rajshahi	986	986	0	Rangpur	706	706	0		
08.	Actual Minimum Generation up to 8:00 hrs.	:	5748.00 MW, at = 7:00 hrs			Cumilla	769	769	0						
09.	Generation shortfall at evening peak due to :	:								Total	8872	8872	0		
	a) Gas limitation	:	2981 MW			13.	Fuel cost :	(a) Gas = 100620129 Taka	(c) Coal = 20913612 Taka						
	d) Coal supply Limitation	:	170 MW					(b) Oil = 452480343 Taka	Total = 574014084 Taka						
	b) Low water level in Kaptai lake	:	163 MW												
	c) Plants under shut down/ maintenance	:	2876 MW			14.	Maximum Temperature in Dhaka was :	24.3° C							
10.	Total Energy (Generation + India Import)	:	182.71 MCKWh			15.	Export through East-West interconnections :								
	By Gas = 92.421 MCKWh			65.532 MCKWh			At evening peak-hour	:	-288 MW, at 19:00 hrs						
	By Coal = 3.859 MCKWh			1.538 MCKWh			Maximum	:	-701 MW, at 13:00 hrs						
	By Solar= 0.177 MCKWh						Energy	:	5.0115 MCKWh						
11.	Total Gas Supplied	:	822.21 MMCFD												
(D) Forecast of 27.01.21 (Today) Wednesday :															
01.	Maximum Demand	:	9400 MW (Generation end)			04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	12498 MW (Generation end)			05.	Total Generation	:	185.87 MCKWh						
03.	Maximum Shortage	:	-3098 MW (Generation end)			06.	Probable Max. Temperature in Dhaka :	:	25.1° C						