

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2021						Day : Monday				Date : 15.02.21					
Probable Maximum Demand :						9500 MW		Probable Maximum Generation :				13360 MW			
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 93.78 ft		Today = 93.66 ft.				Rule Curve = 95.04 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.02.21 (Yesterday)		15.02.21 (Today)		14.02.21 (Yesterday)		15.02.21 (Today)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal Limitation MW						
(A) Plants in operation:															
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under maint.			
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190						
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.			
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	100	108	108						
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0			Contract Expired			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage			
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	320	270	0	0						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Under maint.			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	334	304	0	300						
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.			
13	Siddhirgonj 100 PP(Dutch Bangle)	HFO (QRPP)	12x8.9	100	100	30	85	100	100						
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	220	230	110	110						
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	24	69	100	100						
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	99	98	100	100						
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55						
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	61	61	80	80						
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	64	100	102						
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22						
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	53	43	58	58						
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	20	25	25						
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33						
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52						
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	70	105	105						
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	32	149	149						
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	1	50	50						
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54						
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	245	295	300	300						
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	131	149	149						
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300						
32	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100						
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100						
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	17	35	35	35						
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55						
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0						
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	70	104	104	104						
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	144	144	144						
	Spectra Solar Plant Ltd.	Solar (IPP)				27	0	30	0						
Dhaka Zone Total				6171	5972	2224	2557	2558	3080	785	1165				
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160		Low Water Level			
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0							
42	Raoczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	16	25	25						
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0						
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	43	44	50	50						
45	Sikalbaha 105 MW PP (Baraka Siku)	HFO (IPP)	6x18.415	105	105	0	0	8	100						
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage			
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Gas Shortage			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	306	306	300	300						
49	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	20	100	100						
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	60	100	100	100						
51	Dohazari- Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	85	85						
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0						
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	14	12	25						
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	50	102	102						
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	54	54						
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110						
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100						
58	Chattogram 116 MW PP (Anlima Er	HFO (IPP)	6x21.06	116	116	0	0	116	116						
Chattogram Zone Total				2442	2382	697	824	1279	1359	715	180				
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage			
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage			
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage			
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	26	26	40		Gas Shortage			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	172	160	220	220						
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	275	255	280	280						
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	275	280	280						
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	2	2	5	5	53		Gas Shortage			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas shortage			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51		Gas Shortage			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150		Gas Shortage			
68	Titos 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	0	50						
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	45	50	80						
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	85	200	200						
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	22	22						
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11						
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
74	Jangalia 52 MW PP (Lakdhanvi)	HFO (IPP)	6x8.92	52	52	0	8	52	52						
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	20	19	19						
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+40x1.515+15x1.056	200	200	0	0	0	200						
77	Feni 114 MW Power Plant(Lakdhanvi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114						
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	55	113	113						
**	Import (Tirupura)	India		160	160	84	0	135	147						
	Bharob 54.5 MW	HFO (IPP)				0	0	0	0						
Cumilla Zone Total				3040	2980	954	1021	1568	1860	879	0				
79	RPCL 210MW CCPP	Gas (SIPP)	4x35+1x70	210	202	74	107	105	105	95		Gas Shortage			
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22						
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	24	32	80	80						
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	116	115	115						
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	184	200	200	200						
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0						
86	Tangail 22 MW PP(PPL)	HFO (IPP)													

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.02.21 (Yesterday)		15.02.21 (Today)		14.02.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0				
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	32	32	30	30				
89	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	8	8	51	51				
90	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	5	5	0	0				
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	110	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0		66	Under maint.	
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	0	70	135	135	260		Gas Shortage	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	74	74	74				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	137	122	120	120	109		Gas Shortage	
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	20	20				
98	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0				
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	16	16				
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	270	341	341				
102	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	352	292	350	350				
	Bibiyana South 400 MW	Gas (PDB)				281	432	300	300				
	Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	100	100			On Test	
Sylhet Zone Total						2033	1988	1378	1441	1721	1721	369	66
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	355	300	410	410				
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	7	25	25				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	10	60	60				
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	115	115	115				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	95	95	95				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	817	835	833	930				
Khulna Zone Total						2288	2284	1242	1362	1728	2111	0	0
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110				
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	26	26	26				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.	
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	37	55	95	95				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	410	400	620	620				
118	Potuaekhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0				
Barishal Zone Total						1826	1826	467	529	1001	1001	0	194
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	0	50				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
123	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	12	12	12	12				
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	104	104				
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	8	50	50				
126	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	195	161	220	220				
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	336	380	400	400				
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
133	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	70	113	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
Rajshahi Zone Total						2193	2183	765	996	1297	1421	601	0
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150				
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		20	Under Overhauling	
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	70	92	113	113				
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara, Tatulia 8 MW Solar PP (Sympa P)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total						685	605	225	242	271	263	170	20
Sub-total: Plants in operation						21395	20929	8389.0	9370	12019	13360	3614	1625
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8034	8973	11509	12794				
(B) Contract expired power plants													
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0				
Gross Total				21395	20929	8389	9370	12019	13360	3614	1625		
(C) Actual data of 14.02.21 (Yesterday) Sunday :													
01.	Max. Demand (Generation end) : 9370.00 MW, at = 19:00 hrs					12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand (Sub-station end) : 8973.00 MW, at = 19:00 hrs					Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end) : 9370.00 MW, at = 19:00 hrs												
04.	Minimum Generation (Generation end) : 5977.00 MW, at = 5:00 hrs					Dhaka	3189	3189	0	Myemsingh	787	787	0
05.	Day-peak Generation (Generation end) : 8389.00 MW, at = 12:00 hrs					Chattogram	951	951	0	Sylhet	344	344	0
06.	Evening-peak Generation (Generation end) : 9370.00 MW, at = 19:00 hrs					Khulna	1129	1129	0	Barishal	242	242	0
07.	Evening Peak Load-shed (Sub-station end) : 0.00 MW, at = 19:00 hrs					Rajshahi	959	959	0	Rangpur	648	648	0
08.	Actual Minimum Generation up to 8:00 hrs. : 6019.00 MW, at = 7:00 hrs					Cumilla	724	724	0				
09.	Generation shortfall at evening peak due to : :									Total	8973	8973	0
	a) Gas limitation : 3284 MW					13.	Fuel cost :	(a) Gas = 105922901 Taka		(c) Coal = 68290178 Taka		Taka	
	d) Coal supply Limitation : 170 MW							(b) Oil = 301182821 Taka		Total = 475395900 Taka		Taka	
	b) Low water level in Kaptai lake : 160 MW												
	c) Plants under shut down/ maintenance : 1625 MW					14.	Maximum Temperature in Dhaka was : 29.8° C						
10.	Total Energy (Generation + India Import) : 188.87 MKWh					15.	Export through East-West interconnections :						
	By Gas = 104.810 MKWh 47.080 MKWh						At evening peak-hour : 3 MW, at 19:00 hrs						
	By Coal = 14.691 MKWh By Hydro = 1.688 MKWh						Maximum : -54 MW, at 20:00 hrs						
	By Solar= 0.566 MKWh By Hydro = :						Energy : 0.2685 MKWh						
11.	Total Gas Supplied : 824.04 MMCFD												
(D) Forecast of 15.02.21 (Today) Monday :													
01.	Maximum Demand : 9500 MW (Generation end)					04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation : 13360 MW (Generation end)					05.	Total Generation : 191.49 MKWh						
03.	Maximum Shortage : -3860 MW (Generation end)					06.	Probable Max. Temperature in Dhaka : 30.7° C						

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation