

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2021					Day : Saturday				Date : 20.02.21				
Probable Maximum Demand : 9100 MW					Probable Maximum Generation : 13545 MW					Rule Curve = 94.34 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 93.02 ft Today = 92.90 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.02.21 (Yesterday)		20.02.21 (Today)		19.02.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal Limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	a) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.		
	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190				
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	220	200	220	220				
3	Ghorashal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	12	12	52	52				
4	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Under maint.	7/3/2021	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	372	340	412	412				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	59	60	100	100	150	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.		
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	50	100	100				
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	295	295	300	300				
15	Meghnaghat 100 MW(IEU)	HFO (QRPP)	12x8.9	100	100	16	45	100	100				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	48	101	100	100				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	62	60	60	60				
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	0	100	102				
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	22	22				
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	49	58	58				
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105				
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	64	82	149	149				
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	145	215	300	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	16	75	149	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x1.4	300	300	0	0	100	300				
32	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	35	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55				
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	104	104				
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	126	144	144	144				
	Spectra Solar Plant Ltd.	Solar (IPP)				20	0	30	0				
Dhaka Zone Total					6171	5972	1989	2316	3649	3871	500	1160	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
42	Raoczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25				
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	38	46	46				
45	Sikalbaha 105 MW PP (Baraka Siku)	HFO (IPP)	6x18.415	105	105	0	0	50	100				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Gas Shortage		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Gas Shortage		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	265	267	300	300				
49	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	50	100	100				
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	85	85				
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	19	22	22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			21	38	20	30				
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	102	102				
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	54	54				
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
57	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100				
58	Chattogram 116 MW PP (Anilma Er)	HFO (IPP)	6x21.06	116	116	0	0	116	116				
Chattogram Zone Total					2442	2382	601	582	1325	1360	715	180	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26	19	Gas Shortage		
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	201	206	225	225				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	260	260	260	260				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	270	280	300	300				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	10	30	40	40	25	Gas Shortage		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	59	51	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
74	Jangalia 52 MW PP (Lakdhanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	16	19	19				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+40x1.515+15x1.056	200	200	0	0	0	200				
77	Feni 114 MW Power Plant(Lakdhanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	0	113	113				
**	Import (Tirupura)	India		160	160	88	106	135	147				
	Bhairab 54.5 MW	HFO (IPP)				21	0	0	0				
Cumilla Zone Total					3040	2980	1023	1049	1558	1820	830	0	
79	RPCL 210MW CCPP	Gas (SIPP)	4x35+1x70	210	202	102	142	165	160	60	Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	32	0	80	80				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	8	115	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	195	160	200	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	26	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	17	23	22	22				
Mymensingh Zone Total					717	709	404	355	599	60	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.02.21 (Yesterday)		20.02.21 (Today)		19.02.21 (Yesterday)		20.02.21 (Today)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Gas/water/Coal limitation MW	Machines shut down (MW)						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0										
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43										
89	Fenchugonj 51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	50	50	51	51										
90	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0					Contract Expired on 14/02/2021					
91	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	0	0										
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11										
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0			66		Under maint.					
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	119	121	135	135			209		Gas Shortage					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	72	72	72										
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0			231		Gas Shortage					
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	18	20	20										
98	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0					Contract Expired on 04/01/2020					
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	5	5	10	10										
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	16	16										
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	341	341										
102	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	410	388	400	400										
	Bibiyana South 400 MW	Gas (PDB)				0	0	0	0										
	Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0					On Test					
Sylhet Zone Total				2033	1988	1128	1116	1099	1099	440	66								
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16										
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	370	360	410	410										
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25										
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60										
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220										
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	0	115	115										
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100										
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40										
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	70	90	90										
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100										
**	Bheramara (HVDC)	India		1000	1000	633	823	838	935										
Khulna Zone Total				2288	2284	1038	1253	1728	2111	0	0								
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110										
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	27	26	26										
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0			194		Under maint.					
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	86	95	95										
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	360	420	620	620										
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150										
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0										
Barishal Zone Total				1826	1826	379	581	1001	1001	0	194								
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71			Gas Shortage					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100			Gas Shortage					
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50										
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200										
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40										
123	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	12	12	12										
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	104	104										
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50										
126	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0										
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	19	0	34										
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210			Gas Shortage					
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0		220			Gas Shortage					
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	183	174	220	220										
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	320	423	400	400										
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22										
133	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0					Contract Expired on 12/11/2020					
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11										
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	24	52	52										
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	0	113	113	113										
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	113	113	113										
Rajshahi Zone Total				2193	2183	578	1011	1297	1421	601	0								
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85			Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85			Coal Shortage					
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150										
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		20			Under Overhauling					
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	35	113	113	113										
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0										
143	Majpara, Tatulia 8 MW Solar PP (Sympha P)	Solar (IPP)	1 x 8	8	8	5	0	8	0										
Rangpur Zone Total				685	605	190	263	271	263	170	20								
Sub-total: Plants in operation				21395	20929	7330.0	8526	12584	13545	3316	1620								
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7002	8145	12021	12940										
(B) Contract expired power plants																			
Sub-Total: Plants under long term maintenance				0	0	0	0	0	0										
Gross Total				21395	20929	7330	8526	12584	13545	3316	1620								
(C) Actual data of 19.02.21 (Yesterday) Friday :																			
01.	Max. Demand (Generation end) :					8526.00	MW,	at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand (Sub-station end) :					8145.00	MW,	at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end) :					8526.00	MW,	at =	20:00 hrs		MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end) :					6242.00	MW,	at =	5:00 hrs	Dhaka	2704	2704	0	Myringsingh	764	764	0		
05.	Day-peak Generation (Generation end) :					7330.00	MW,	at =	12:00 hrs	Chattogram	855	855	0	Sylhet	318	318	0		
06.	Evening-peak Generation (Generation end) :					8526.00	MW,	at =	20:00 hrs	Khulna	1005	1005	0	Barishal	239	239	0		
07.	Evening Peak Load-shed (Sub-station end) :					0.00	MW,	at =	20:00 hrs	Rajshahi	901	901	0	Rangpur	593	593	0		
08.	Actual Minimum Generation up to 8:00 hrs.					5984.00	MW,	at =	7:00 hrs	Cumilla	766	766	0						
09.	Generation shortfall at evening peak due to :													Total	8145	8145	0		
	a) Gas limitation :					2986	MW			13.	Fuel cost :	(a) Gas = 110848997 Taka		(c) Coal = 65731686 Taka		Taka			
	d) Coal supply Limitation :					170	MW					(b) Oil = 231407469 Taka		Total = 407988151 Taka		Taka			
	b) Low water level in Kaptai lake :					160	MW												
	c) Plants under shut down/ maintenance :					1620	MW												
10.	Total Energy (Generation + India Import) :					175.32	MKWh			14.	Maximum Temperature in Dhaka was :					31.2° C			
	By Gas = 102.408						MKWh			15.	Export through East-West interconnections :								
	By Coal = 14.109						MKWh				At evening peak-hour					: 201	MW,	at	20:00 hrs
	By Solar= 0.572						MKWh				Maximum					: -145	MW,	at	7:00 hrs
	By Hydro =						MKWh				Energy					: 0.243	MKWh		
11.	Total Gas Supplied :					834.50	MMCFD												
(D) Forecast of 20.02.21 (Today) Saturday :																			
01.	Maximum Demand :					9100	MW	(Generation end)		04.	Maximum Load-shed :					0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation :					13545	MW	(Generation end)		05.	Total Generation :					187.13	MKWh		
03.	Maximum Shortage :					-4445	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :					30.1° C			